

項目	単位	基準値	2024/04/03	2024/05/08	2024/06/05	2024/07/03	2024/08/07	2024/09/04	2024/10/02	2024/11/06	2024/12/04	2025/01/08	2025/02/05	2025/03/05	測定回数	不適回数	平均値	最大値	最小値	最大値検出日
			24-SS-00041	24-SS-00429	24-SS-00910	24-SS-01446	24-SS-02068	24-SS-02568	24-SS-03030	24-SS-03437	24-SS-03885	24-SS-04274	24-SS-04707	24-SS-05074						
			SS 上水道																	
水温	℃	-	16.0	19.5	21.0	23.5	27.0	24.5	25.5	21.2	19.0	14.0	15.0	14.0	12	0	20.0	27.0	14.0	2024/08/07
気温	℃	-	13.8	24.2	22.6	29.6	32.0	28.4	29.2	21.1	18.5	8.6	8.4	11.0	12	0	20.6	32.0	8.4	2024/08/07
残留塩素濃度	mg/L	-	0.3	0.3	0.3	0.3	0.2	0.3	0.2	0.2	0.2	0.2	0.2	0.2	12	0	0.2	0.3	0.2	2024/04/03
一般細菌	CFU/mL	100CFU/mL以下	0	0	2	0	0	0	0	0	0	0	0	0	12	0	0	2	0	2024/06/05
大腸菌	-	検出されないこと	検出しない	12	0	---	---	---	---											
カドミウム及びその化合物	mg/L	0.003mg/L以下	---	---	---	---	0.00015未満	---	---	---	---	---	---	---	1	0	0.00015未満	0.00015未満	0.00015未満	---
水銀及びその化合物	mg/L	0.0005mg/L以下	---	---	---	---	0.00005未満	---	---	---	---	---	---	---	1	0	0.00005未満	0.00005未満	0.00005未満	---
セレン及びその化合物	mg/L	0.01mg/L以下	---	---	---	---	0.0005未満	---	---	---	---	---	---	---	1	0	0.0005未満	0.0005未満	0.0005未満	---
鉛及びその化合物	mg/L	0.01mg/L以下	---	---	---	---	0.0006	---	---	---	---	---	---	---	1	0	0.0006	0.0006	0.0006	2024/08/07
ヒ素及びその化合物	mg/L	0.01mg/L以下	---	---	---	---	0.0005未満	---	---	---	---	---	---	---	1	0	0.0005未満	0.0005未満	0.0005未満	---
六価クロム化合物	mg/L	0.02mg/L以下	---	---	---	---	0.002未満	---	---	---	---	---	---	---	1	0	0.002未満	0.002未満	0.002未満	---
亜硝酸態窒素	mg/L	0.04mg/L以下	---	---	---	---	0.004未満	---	---	---	---	---	---	---	1	0	0.004未満	0.004未満	0.004未満	---
シアン化物イオン及び塩化シアン	mg/L	0.01mg/L以下	---	0.001未満	---	4	0	0.001未満	0.001未満	0.001未満	---									
硝酸態窒素及び亜硝酸態窒素	mg/L	10mg/L以下	---	---	---	---	1.0	---	---	---	---	---	---	---	1	0	1.0	1.0	1.0	2024/08/07
フッ素及びその化合物	mg/L	0.8mg/L以下	---	---	---	---	0.05未満	---	---	---	---	---	---	---	1	0	0.05未満	0.05未満	0.05未満	---
ホウ素及びその化合物	mg/L	1.0mg/L以下	---	---	---	---	0.04	---	---	---	---	---	---	---	1	0	0.04	0.04	0.04	2024/08/07
四塩化炭素	mg/L	0.002mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---	---	---	1	0	0.0002未満	0.0002未満	0.0002未満	---
1,4-ジオキサン	mg/L	0.05mg/L以下	---	---	---	---	0.003未満	---	---	---	---	---	---	---	1	0	0.003未満	0.003未満	0.003未満	---
シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン	mg/L	0.04mg/L以下	---	---	---	---	0.0004未満	---	---	---	---	---	---	---	1	0	0.0004未満	0.0004未満	0.0004未満	---
ジクロロメタン	mg/L	0.02mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---	---	---	1	0	0.0002未満	0.0002未満	0.0002未満	---
テトラクロロエチレン	mg/L	0.01mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---	---	---	1	0	0.0002未満	0.0002未満	0.0002未満	---
トリクロロエチレン	mg/L	0.01mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---	---	---	1	0	0.0002未満	0.0002未満	0.0002未満	---
ベンゼン	mg/L	0.01mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---	---	---	1	0	0.0002未満	0.0002未満	0.0002未満	---
塩素酸	mg/L	0.06mg/L以下	---	0.06未満	---	4	0	0.06未満	0.06未満	0.06未満	---									
クロロ酢酸	mg/L	0.02mg/L以下	---	0.002未満	---	4	0	0.002未満	0.002未満	0.002未満	---									
クロロホルム	mg/L	0.06mg/L以下	---	0.0002未満	---	4	0	0.0002未満	0.0002未満	0.0002未満	---									
ジクロロ酢酸	mg/L	0.03mg/L以下	---	0.002未満	---	4	0	0.002未満	0.002未満	0.002未満	---									
ジブロモクロメタン	mg/L	0.1mg/L以下	---	0.0002未満	---	4	0	0.0002未満	0.0002未満	0.0002未満	---									
臭素酸	mg/L	0.01mg/L以下	---	0.001未満	---	4	0	0.001未満	0.001未満	0.001未満	---									
総トリハロメタン	mg/L	0.1mg/L以下	---	0.01未満	---	4	0	0.01未満	0.01未満	0.01未満	---									
トリクロロ酢酸	mg/L	0.03mg/L以下	---	0.002未満	---	4	0	0.002未満	0.002未満	0.002未満	---									
ブロモジクロロメタン	mg/L	0.03mg/L以下	---	0.0002未満	---	4	0	0.0002未満	0.0002未満	0.0002未満	---									
ブロモホルム	mg/L	0.09mg/L以下	---	0.0002未満	---	4	0	0.0002未満	0.0002未満	0.0002未満	---									
ホルムアルデヒド	mg/L	0.08mg/L以下	---	0.004未満	---	4	0	0.004未満	0.004未満	0.004未満	---									
亜鉛及びその化合物	mg/L	1.0mg/L以下	---	---	---	---	0.004	---	---	---	---	---	---	---	1	0	0.004	0.004	0.004	2024/08/07
アルミニウム及びその化合物	mg/L	0.2mg/L以下	---	---	---	---	0.005未満	---	---	---	---	---	---	---	1	0	0.005未満	0.005未満	0.005未満	---
鉄及びその化合物	mg/L	0.3mg/L以下	---	---	---	---	0.02未満	---	---	---	---	---	---	---	1	0	0.02未満	0.02未満	0.02未満	---
銅及びその化合物	mg/L	1.0mg/L以下	---	---	---	---	0.025	---	---	---	---	---	---	---	1	0	0.025	0.025	0.025	2024/08/07
ナトリウム及びその化合物	mg/L	200mg/L以下	---	---	---	---	9.6	---	---	---	---	---	---	---	1	0	9.6	9.6	9.6	2024/08/07
マンガン及びその化合物	mg/L	0.05mg/L以下	---	---	---	---	0.001未満	---	---	---	---	---	---	---	1	0	0.001未満	0.001未満	0.001未満	---
塩化物イオン	mg/L	200mg/L以下	6.0	6.2	6.1	6.0	6.0	6.1	6.1	5.9	6.0	6.0	6.1	5.8	12	0	6.0	6.2	5.8	2024/05/08
カルシウム、マグネシウム等(硬度)	mg/L	300mg/L以下	---	58	---	---	55	---	---	56	---	---	59	---	4	0	57	59	55	2025/02/05
蒸発残留物	mg/L	500mg/L以下	---	110	---	---	120	---	---	120	---	---	130	---	4	0	120	130	110	2025/02/05
陰イオン界面活性剤	mg/L	0.2mg/L以下	---	---	---	---	0.02未満	---	---	---	---	---	---	---	1	0	0.02未満	0.02未満	0.02未満	---
ジェオスミン	mg/L	0.00001mg/L以下	---	---	---	---	0.000001未満	---	---	---	---	---	---	---	1	0	0.000001未満	0.000001未満	0.000001未満	---
2-メチルイソボルネオール	mg/L	0.00001mg/L以下	---	---	---	---	0.000001未満	---	---	---	---	---	---	---	1	0	0.000001未満	0.000001未満	0.000001未満	---
非イオン界面活性剤	mg/L	0.02mg/L以下	---	---	---	---	0.002未満	---	---	---	---	---	---	---	1	0	0.002未満	0.002未満	0.002未満	---
フェノール類	mg/L	0.005mg/L以下	---	---	---	---	0.0005未満	---	---	---	---	---	---	---	1	0	0.0005未満	0.0005未満	0.0005未満	---
有機物(全有機炭素(TOC)の量)	mg/L	3mg/L以下	0.2未満	12	0	0.2未満	0.2未満	0.2未満	---											
pH値	-	5.8以上8.6以下	6.8	6.9	6.9	6.8	6.8	6.8	6.8	6.8	6.8	6.8	6.8	6.8	12	0	6.8	6.9	6.8	2024/05/08
味	-	異常でないこと	異常なし	12	0	---	---	---	---											
臭気	-	異常でないこと	異常なし	12	0	---	---	---	---											
色度	度	5度以下	0.5未満	12	0	0.5未満	0.5未満	0.5未満	---											
濁度	度	2度以下	0.1未満	12	0	0.1未満	0.1未満	0.1未満	---											
上記項目についての水質基準適合判定			適合																	