

施設名：焼津市上水（新屋公園） 採水場所：焼津市本町2丁目11-1 新屋公園

項目	単位	基準値	2025/04/02	2025/05/07	2025/06/04	2025/07/02	2025/08/06	2025/09/03	2025/10/01	2025/11/05	2025/12/03	2026/01/07			測定回数	不適回数	平均値	最大値	最小値	最大値検出日
			25-SS-00029	25-SS-00424	25-SS-00927	25-SS-01458	25-SS-02035	25-SS-02612	25-SS-02975	25-SS-03414	25-SS-03840	25-SS-04224								
			SS																	
			上水道																	
水温	°C	-	17.0	19.5	20.0	24.1	26.1	26.8	25.0	20.1	18.1	16.0			10	0	21.3	26.8	16.0	2025/09/03
气温	°C	-	15.8	20.8	24.9	26.9	36.7	32.3	21.1	17.2	14.3	8.8			10	0	21.9	36.7	8.8	2025/08/06
残留塩素濃度	mg/L	-	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2			10	0	0.2	0.2	0.2	---
一般細菌	CFU/mL	100CFU/mL以下	0	0	0	0	0	0	0	0	1	0			10	0	0	1	0	2025/12/03
大腸菌	-	検出されないこと	検出しない			10	0	---	---	---	---									
カドミウム及びその化合物	mg/L	0.003mg/L以下	---	---	---	---	0.00015未満	---	---	---	---	---			1	0	0.00015未満	0.00015未満	0.00015未満	---
水銀及びその化合物	mg/L	0.005mg/L以下	---	---	---	---	0.00005未満	---	---	---	---	---			1	0	0.00005未満	0.00005未満	0.00005未満	---
セレン及びその化合物	mg/L	0.01mg/L以下	---	---	---	---	0.0005	---	---	---	---	---			1	0	0.0005	0.0005	0.0005	2025/08/06
鉛及びその化合物	mg/L	0.01mg/L以下	---	---	---	---	0.0005未満	---	---	---	---	---			1	0	0.0005未満	0.0005未満	0.0005未満	---
ヒ素及びその化合物	mg/L	0.01mg/L以下	---	---	---	---	0.0005未満	---	---	---	---	---			1	0	0.0005未満	0.0005未満	0.0005未満	---
六価クロム化合物	mg/L	0.02mg/L以下	---	---	---	---	0.002未満	---	---	---	---	---			1	0	0.002未満	0.002未満	0.002未満	---
亜硝酸態窒素	mg/L	0.04mg/L以下	---	---	---	---	0.004未満	---	---	---	---	---			1	0	0.004未満	0.004未満	0.004未満	---
シアノ化物イオン及び塩化シアノ	mg/L	0.01mg/L以下	---	0.001未満	---	---	0.001未満	---	0.001未満	---	---	---			3	0	0.001未満	0.001未満	0.001未満	---
硝酸態窒素及び亜硝酸態窒素	mg/L	10mg/L以下	---	---	---	---	1.0	---	---	---	---	---			1	0	1.00	1.00	1.00	2025/08/06
フッ素及びその化合物	mg/L	0.8mg/L以下	---	---	---	---	0.05未満	---	---	---	---	---			1	0	0.05未満	0.05未満	0.05未満	---
ホウ素及びその化合物	mg/L	1.0mg/L以下	---	---	---	---	0.04	---	---	---	---	---			1	0	0.04	0.04	0.04	2025/08/06
四塩化炭素	mg/L	0.002mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---			1	0	0.0002未満	0.0002未満	0.0002未満	---
1,4-ジオキサン	mg/L	0.05mg/L以下	---	---	---	---	0.003未満	---	---	---	---	---			1	0	0.003未満	0.003未満	0.003未満	---
シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン	mg/L	0.04mg/L以下	---	---	---	---	0.0004未満	---	---	---	---	---			1	0	0.0004未満	0.0004未満	0.0004未満	---
ジクロロメタン	mg/L	0.02mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---			1	0	0.0002未満	0.0002未満	0.0002未満	---
トトラクロロエチレン	mg/L	0.01mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---			1	0	0.0002未満	0.0002未満	0.0002未満	---
トリクロロエチレン	mg/L	0.01mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---			1	0	0.0002未満	0.0002未満	0.0002未満	---
ベンゼン	mg/L	0.01mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---			1	0	0.0002未満	0.0002未満	0.0002未満	---
塩素酸	mg/L	0.6mg/L以下	---	0.06未満	---	---	0.06未満	---	0.06未満	---	0.06未満	---			3	0	0.06未満	0.06未満	0.06未満	---
クロロ酢酸	mg/L	0.02mg/L以下	---	0.002未満	---	---	0.002未満	---	0.002未満	---	0.002未満	---			3	0	0.002未満	0.002未満	0.002未満	---
クロロホルム	mg/L	0.06mg/L以下	---	0.0002未満	---	---	0.0002未満	---	0.0002未満	---	0.0002未満	---			3	0	0.0002未満	0.0002未満	0.0002未満	---
ジクロロ酢酸	mg/L	0.03mg/L以下	---	0.002未満	---	---	0.002未満	---	0.002未満	---	0.002未満	---			3	0	0.002未満	0.002未満	0.002未満	---
ジブロモクロロメタン	mg/L	0.1mg/L以下	---	0.0002未満	---	---	0.0002未満	---	0.0002未満	---	0.0002未満	---			3	0	0.0002未満	0.0002未満	0.0002未満	---
臭素酸	mg/L	0.01mg/L以下	---	0.001未満	---	---	0.001未満	---	0.001未満	---	0.001未満	---			3	0	0.001未満	0.001未満	0.001未満	---
総トライハロメタン	mg/L	0.1mg/L以下	---	0.01未満	---	---	0.01未満	---	0.01未満	---	0.01未満	---			3	0	0.01未満	0.01未満	0.01未満	---
トリクロロ酢酸	mg/L	0.03mg/L以下	---	0.002未満	---	---	0.002未満	---	0.002未満	---	0.002未満	---			3	0	0.002未満	0.002未満	0.002未満	---
プロモジクロロメタン	mg/L	0.03mg/L以下	---	0.0002未満	---	---	0.0002未満	---	0.0002未満	---	0.0002未満	---			3	0	0.0002未満	0.0002未満	0.0002未満	---
プロモホルム	mg/L	0.09mg/L以下	---	0.0002未満	---	---	0.0002未満	---	0.0002未満	---	0.0002未満	---			3	0	0.0002未満	0.0002未満	0.0002未満	---
ホルムアルデヒド	mg/L	0.08mg/L以下	---	0.004未満	---	---	0.004未満	---	0.004未満	---	0.004未満	---			3	0	0.004未満	0.004未満	0.004未満	---
亜鉛及びその化合物	mg/L	1.0mg/L以下	---	---	---	---	0.002未満	---	---	---	---	---			1	0	0.002未満	0.002未満	0.002未満	---
アルミニウム及びその化合物	mg/L	0.2mg/L以下	---	---	---	---	0.005未満	---	---	---	---	---			1	0	0.005未満	0.005未満	0.005未満	---
鉄及びその化合物	mg/L	0.3mg/L以下	---	---	---	---	0.02未満	---	---	---	---	---			1	0	0.02未満	0.02未満	0.02未満	---
銅及びその化合物	mg/L	1.0mg/L以下	---	---	---	---	0.011	---	---	---	---	---			1	0	0.011	0.011	0.011	2025/08/06
ナトリウム及びその化合物	mg/L	200mg/L以下	---	---	---	---	9.6	---	---	---	---	---			1	0	9.6	9.6	9.6	2025/08/06
マンガン及びその化合物	mg/L	0.05mg/L以下	---	---	---	---	0.001未満	---	---	---	---	---			1	0	0.001未満	0.001未満	0.001未満	---
塩化物イオン	mg/L	200mg/L以下	6.1	5.7	5.7	5.7	5.6	5.4	5.4	5.5	5.6	5.4			10	0	5.6	6.1	5.4	2025/04/02
カルシウム、マグネシウム等(硬度)	mg/L	300mg/L以下	---	59	---	---	56	---	58	---	58	---			3	0	58	59	56	2025/05/07
蒸発残留物	mg/L	500mg/L以下	---	130	---	---	120	---	110	---	110	---			3	0	120	130	110	2025/05/07
陰イオン界面活性剤	mg/L	0.2mg/L以下	---	---	---	---	0.02未満	---	---	---	---	---			1	0	0.02未満	0.02未満	0.02未満	---
ジェオスミン	mg/L	0.00001mg/L以下	---	---	---	---	0.000001未満	---	---	---	---	---			1	0	0.000001未満	0.000001未満	0.000001未満	---
2-メチルイソポルネオール	mg/L	0.00001mg/L以下	---	---	---	---	0.000001未満	---	---	---	---	---			1	0	0.000001未満	0.000001未満	0.000001未満	---
非イオン界面活性剤	mg/L	0.02mg/L以下	---	---	---	---	0.002未満	---	---	---	---	---			1	0	0.002未満	0.002未満	0.002未満	---
フェノール類	mg/L	0.005mg/L以下	---	---	---	---	0.0005未満	---	---	---	---	---			1	0	0.0005未満	0.0005未満	0.0005未満	---
有機物(全有機炭素(TOC)の量)	mg/L	3mg/L以下	0.2未満			10	0	0.2未満	0.2未満	0.2未満	---									
pH値	-	5.8以上6.6以下	6.8	6.8	6.8	6.9	6.9	6.8	6.8	6.8	6.8	6.8			10	0	6.8	6.9	6.8	2025/07/02
味	-	異常でないこと	異常なし			10	0	---	---	---	---									
臭気	-	異常でないこと	異常なし			10	0	---	---	---	---									
色度	度	5度以下	0.5未満			10	0	0.5未満	0.5未満	0.5未満	---									
濁度	度	2度以下	0.1未満			10	0	0.1未満	0.1未満	0.1未満	---									

上記項目についての水質基準適合判定

適合

施設名：焼津市上水（石津浜公園） 採水場所：焼津市石津2420 石津浜公園

項目	単位	基準値	2025/04/02	2025/05/07	2025/06/04	2025/07/02	2025/08/06	2025/09/03	2025/10/01	2025/11/05	2025/12/03	2026/01/07			測定回数	不適回数	平均値	最大値	最小値	最大値検出日
			25-SS-00028	25-SS-00423	25-SS-00926	25-SS-01457	25-SS-02034	25-SS-02611	25-SS-02974	25-SS-03413	25-SS-03839	25-SS-04223								
			SS																	
			上水道																	
水温	°C	-	14.0	18.0	20.1	24.0	28.0	26.0	25.0	18.2	17.0	13.0			10	0	20.3	28.0	13.0	2025/08/06
气温	°C	-	15.1	20.0	24.3	27.4	38.8	34.9	20.7	16.5	14.1	8.2			10	0	22.0	38.8	8.2	2025/08/06
残留塩素濃度	mg/L	-	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2			10	0	0.2	0.2	0.2	---
一般細菌	CFU/mL	100CFU/mL以下	0	0	0	0	0	0	0	0	0	0			10	0	0	0	0	---
大腸菌	-	検出されないこと	検出しない			10	0	---	---	---	---									
カドミウム及びその化合物	mg/L	0.003mg/L以下	---	---	---	---	0.00015未満	---	---	---	---	---			1	0	0.00015未満	0.00015未満	0.00015未満	---
水銀及びその化合物	mg/L	0.005mg/L以下	---	---	---	---	0.00005未満	---	---	---	---	---			1	0	0.00005未満	0.00005未満	0.00005未満	---
セレン及びその化合物	mg/L	0.01mg/L以下	---	---	---	---	0.0005	---	---	---	---	---			1	0	0.0005	0.0005	0.0005	2025/08/06
鉛及びその化合物	mg/L	0.01mg/L以下	---	---	---	---	0.0010	---	---	---	---	---			1	0	0.0010	0.0010	0.0010	2025/08/06
ヒ素及びその化合物	mg/L	0.01mg/L以下	---	---	---	---	0.0005未満	---	---	---	---	---			1	0	0.0005未満	0.0005未満	0.0005未満	---
六価クロム化合物	mg/L	0.02mg/L以下	---	---	---	---	0.002未満	---	---	---	---	---			1	0	0.002未満	0.002未満	0.002未満	---
亜硝酸態窒素	mg/L	0.04mg/L以下	---	---	---	---	0.004未満	---	---	---	---	---			1	0	0.004未満	0.004未満	0.004未満	---
シアノ化物イオン及び塩化シアノ	mg/L	0.01mg/L以下	---	0.001未満	---	---	0.001未満	---	0.001未満	---	---	---			3	0	0.001未満	0.001未満	0.001未満	---
硝酸態窒素及び亜硝酸態窒素	mg/L	10mg/L以下	---	---	---	---	1.0	---	---	---	---	---			1	0	1.00	1.00	1.00	2025/08/06
フッ素及びその化合物	mg/L	0.8mg/L以下	---	---	---	---	0.05未満	---	---	---	---	---			1	0	0.05未満	0.05未満	0.05未満	---
ホウ素及びその化合物	mg/L	1.0mg/L以下	---	---	---	---	0.04	---	---	---	---	---			1	0	0.04	0.04	0.04	2025/08/06
四塩化炭素	mg/L	0.002mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---			1	0	0.0002未満	0.0002未満	0.0002未満	---
1,4-ジオキサン	mg/L	0.05mg/L以下	---	---	---	---	0.003未満	---	---	---	---	---			1	0	0.003未満	0.003未満	0.003未満	---
シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン	mg/L	0.04mg/L以下	---	---	---	---	0.0004未満	---	---	---	---	---			1	0	0.0004未満	0.0004未満	0.0004未満	---
ジクロロメタン	mg/L	0.02mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---			1	0	0.0002未満	0.0002未満	0.0002未満	---
トトラクロロエチレン	mg/L	0.01mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---			1	0	0.0002未満	0.0002未満	0.0002未満	---
トリクロロエチレン	mg/L	0.01mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---			1	0	0.0002未満	0.0002未満	0.0002未満	---
ベンゼン	mg/L	0.01mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---			1	0	0.0002未満	0.0002未満	0.0002未満	---
塩素酸	mg/L	0.6mg/L以下	---	0.06未満	---	---	0.06未満	---	0.06未満	---	0.06未満	---			3	0	0.06未満	0.06未満	0.06未満	---
クロロ酢酸	mg/L	0.02mg/L以下	---	0.002未満	---	---	0.002未満	---	0.002未満	---	0.002未満	---			3	0	0.002未満	0.002未満	0.002未満	---
クロロホルム	mg/L	0.06mg/L以下	---	0.0002未満	---	---	0.0002未満	---	0.0002未満	---	0.0002未満	---			3	0	0.0002未満	0.0002未満	0.0002未満	---
ジクロロ酢酸	mg/L	0.03mg/L以下	---	0.002未満	---	---	0.002未満	---	0.002未満	---	0.002未満	---			3	0	0.002未満	0.002未満	0.002未満	---
ジブロモクロロメタン	mg/L	0.1mg/L以下	---	0.0002未満	---	---	0.0002未満	---	0.0002未満	---	0.0002未満	---			3	0	0.0002未満	0.0002未満	0.0002未満	---
臭素酸	mg/L	0.01mg/L以下	---	0.001未満	---	---	0.001未満	---	0.001未満	---	0.001未満	---			3	0	0.001未満	0.001未満	0.001未満	---
総トドハロメタン	mg/L	0.1mg/L以下	---	0.01未満	---	---	0.01未満	---	0.01未満	---	0.01未満	---			3	0	0.01未満	0.01未満	0.01未満	---
トリクロロ酢酸	mg/L	0.03mg/L以下	---	0.002未満	---	---	0.002未満	---	0.002未満	---	0.002未満	---			3	0	0.002未満	0.002未満	0.002未満	---
プロモジクロロメタン	mg/L	0.03mg/L以下	---	0.0002未満	---	---	0.0002未満	---	0.0002未満	---	0.0002未満	---			3	0	0.0002未満	0.0002未満	0.0002未満	---
プロモホルム	mg/L	0.09mg/L以下	---	0.0002未満	---	---	0.0002未満	---	0.0002未満	---	0.0002未満	---			3	0	0.0002未満	0.0002未満	0.0002未満	---
ホルムアルデヒド	mg/L	0.08mg/L以下	---	0.004未満	---	---	0.004未満	---	0.004未満	---	0.004未満	---			3	0	0.004未満	0.004未満	0.004未満	---
亜鉛及びその化合物	mg/L	1.0mg/L以下	---	---	---	---	0.004	---	---	---	---	---			1	0	0.004	0.004	0.004	2025/08/06
アルミニウム及びその化合物	mg/L	0.2mg/L以下	---	---	---	---	0.005未満	---	---	---	---	---			1	0	0.005未満	0.005未満	0.005未満	---
鉄及びその化合物	mg/L	0.3mg/L以下	---	---	---	---	0.02未満	---	---	---	---	---			1	0	0.02未満	0.02未満	0.02未満	---
銅及びその化合物	mg/L	1.0mg/L以下	---	---	---	---	0.027	---	---	---	---	---			1	0	0.027	0.027	0.027	2025/08/06
ナトリウム及びその化合物	mg/L	200mg/L以下	---	---	---	---	9.8	---	---	---	---	---			1	0	9.8	9.8	9.8	2025/08/06
マンガン及びその化合物	mg/L	0.05mg/L以下	---	---	---	---	0.001未満	---	---	---	---	---			1	0	0.001未満	0.001未満	0.001未満	---
塩化物イオン	mg/L	200mg/L以下	6.1	5.7	5.7	5.6	5.5	5.4	5.4	5.4	5.6	5.4			10	0	5.6	6.1	5.4	2025/04/02
カルシウム、マグネシウム等(硬度)	mg/L	300mg/L以下	---	58	---	---	57	---	56	---	57	---			3	0	57	58	56	2025/05/07
蒸発残留物	mg/L	500mg/L以下	---	130	---	---	110	---	110	---	110	---			3	0	117	130	110	2025/05/07
陰イオン界面活性剤	mg/L	0.2mg/L以下	---	---	---	---	0.02未満	---	---	---	---	---			1	0	0.02未満	0.02未満	0.02未満	---
ジェオスミン	mg/L	0.00001mg/L以下	---	---	---	---	0.000001未満	---	---	---	---	---			1	0	0.000001未満	0.000001未満	0.000001未満	---
2-メチルイソポルネオール	mg/L	0.00001mg/L以下	---	---	---	---	0.000001未満	---	---	---	---	---			1	0	0.000001未満	0.000001未満	0.000001未満	---
非イオン界面活性剤	mg/L	0.02mg/L以下	---	---	---	---	0.002未満	---	---	---	---	---			1	0	0.002未満	0.002未満	0.002未満	---
フェノール類	mg/L	0.005mg/L以下	---	---	---	---	0.0005未満	---	---	---	---	---			1	0	0.0005未満	0.0005未満	0.0005未満	---
有機物(全有機炭素(TOC)の量)	mg/L	3mg/L以下	0.2未満			10	0	0.2未満	0.2未満	0.2未満	---									
pH値	-	5.8以上6.6以下	6.8	6.8	6.8	6.9	6.8	6.9	6.7	6.8	6.8	6.8			10	0	6.8	6.9	6.7	2025/07/02
味	-	異常でないこと	異常なし			10	0	---	---	---	---									
臭気	-	異常でないこと	異常なし			10	0	---	---	---	---									
色度	度	5度以下	0.5未満			10	0	0.5未満	0.5未満	0.5未満	---									
濁度	度	2度以下	0.1未満			10	0	0.1未満	0.1未満	0.1未満	---									

上記項目についての水質基準適合判定

適合 合格 合格

施設名：焼津市上水（大島下ちびっこ広場） 採水場所：焼津市大島1206-1 大島下ちびっこ広場

項目	単位	基準値	2025/04/02	2025/05/07	2025/06/04	2025/07/02	2025/08/06	2025/09/03	2025/10/01	2025/11/05	2025/12/03	2026/01/07			測定回数	不適回数	平均値	最大値	最小値	最大値検出日
			25-SS-00025	25-SS-00420	25-SS-00923	25-SS-01454	25-SS-02023	25-SS-02608	25-SS-02971	25-SS-03410	25-SS-03836	25-SS-04220								
			SS																	
			上水道																	
水温	°C	-	17.0	18.0	18.2	20.0	27.5	21.2	21.0	18.0	17.1	16.0			10	0	19.4	27.5	16.0	2025/08/06
气温	°C	-	17.3	20.9	25.2	29.3	35.4	34.1	24.3	15.2	13.1	9.2			10	0	22.4	35.4	9.2	2025/08/06
残留塩素濃度	mg/L	-	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2			10	0	0.2	0.2	0.2	---
一般細菌	CFU/mL	100CFU/mL以下	0	0	0	0	0	0	0	0	0	0			10	0	0	0	0	---
大腸菌	-	検出されないこと	検出しない			10	0	---	---	---	---									
カドミウム及びその化合物	mg/L	0.003mg/L以下	---	---	---	---	0.00015未満	---	---	---	---	---			1	0	0.00015未満	0.00015未満	0.00015未満	---
水銀及びその化合物	mg/L	0.005mg/L以下	---	---	---	---	0.00005未満	---	---	---	---	---			1	0	0.00005未満	0.00005未満	0.00005未満	---
セレン及びその化合物	mg/L	0.01mg/L以下	---	---	---	---	0.0006	---	---	---	---	---			1	0	0.0006	0.0006	0.0006	2025/08/06
鉛及びその化合物	mg/L	0.01mg/L以下	---	---	---	---	0.0005未満	---	---	---	---	---			1	0	0.0005未満	0.0005未満	0.0005未満	---
ヒ素及びその化合物	mg/L	0.01mg/L以下	---	---	---	---	0.0005未満	---	---	---	---	---			1	0	0.0005未満	0.0005未満	0.0005未満	---
六価クロム化合物	mg/L	0.02mg/L以下	---	---	---	---	0.002未満	---	---	---	---	---			1	0	0.002未満	0.002未満	0.002未満	---
亜硝酸態窒素	mg/L	0.04mg/L以下	---	---	---	---	0.004未満	---	---	---	---	---			1	0	0.004未満	0.004未満	0.004未満	---
シアノ化物イオン及び塩化シアノ	mg/L	0.01mg/L以下	---	0.001未満	---	---	0.001未満	---	0.001未満	---	---	---			3	0	0.001未満	0.001未満	0.001未満	---
硝酸態窒素及び亜硝酸態窒素	mg/L	10mg/L以下	---	---	---	---	1.0	---	---	---	---	---			1	0	1.00	1.00	1.00	2025/08/06
フッ素及びその化合物	mg/L	0.8mg/L以下	---	---	---	---	0.05未満	---	---	---	---	---			1	0	0.05未満	0.05未満	0.05未満	---
ホウ素及びその化合物	mg/L	1.0mg/L以下	---	---	---	---	0.04	---	---	---	---	---			1	0	0.04	0.04	0.04	2025/08/06
四塩化炭素	mg/L	0.002mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---			1	0	0.0002未満	0.0002未満	0.0002未満	---
1,4-ジオキサン	mg/L	0.05mg/L以下	---	---	---	---	0.003未満	---	---	---	---	---			1	0	0.003未満	0.003未満	0.003未満	---
ジメチルジエチレングリコール及びジメチルジエチレン	mg/L	0.04mg/L以下	---	---	---	---	0.0004未満	---	---	---	---	---			1	0	0.0004未満	0.0004未満	0.0004未満	---
ジクロロメタン	mg/L	0.02mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---			1	0	0.0002未満	0.0002未満	0.0002未満	---
トライクロロエチレン	mg/L	0.01mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---			1	0	0.0002未満	0.0002未満	0.0002未満	---
トリクロロエチレン	mg/L	0.01mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---			1	0	0.0002未満	0.0002未満	0.0002未満	---
ベンゼン	mg/L	0.01mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---			1	0	0.0002未満	0.0002未満	0.0002未満	---
塩素酸	mg/L	0.6mg/L以下	---	0.06未満	---	---	0.06未満	---	0.06未満	---	0.06未満	---			3	0	0.06未満	0.06未満	0.06未満	---
クロロ酢酸	mg/L	0.02mg/L以下	---	0.002未満	---	---	0.002未満	---	0.002未満	---	0.002未満	---			3	0	0.002未満	0.002未満	0.002未満	---
クロロホルム	mg/L	0.06mg/L以下	---	0.0002未満	---	---	0.0002未満	---	0.0002未満	---	0.0002未満	---			3	0	0.0002未満	0.0002未満	0.0002未満	---
ジクロロ酢酸	mg/L	0.03mg/L以下	---	0.002未満	---	---	0.002未満	---	0.002未満	---	0.002未満	---			3	0	0.002未満	0.002未満	0.002未満	---
ジブロモクロロメタン	mg/L	0.1mg/L以下	---	0.0002未満	---	---	0.0002未満	---	0.0002未満	---	0.0002未満	---			3	0	0.0002未満	0.0002未満	0.0002未満	---
臭素酸	mg/L	0.01mg/L以下	---	0.001未満	---	---	0.001未満	---	0.001未満	---	0.001未満	---			3	0	0.001未満	0.001未満	0.001未満	---
総ドーハメタン	mg/L	0.1mg/L以下	---	0.01未満	---	---	0.01未満	---	0.01未満	---	0.01未満	---			3	0	0.01未満	0.01未満	0.01未満	---
トリクロロ酢酸	mg/L	0.03mg/L以下	---	0.002未満	---	---	0.002未満	---	0.002未満	---	0.002未満	---			3	0	0.002未満	0.002未満	0.002未満	---
プロモジクロロメタン	mg/L	0.03mg/L以下	---	0.0002未満	---	---	0.0002未満	---	0.0002未満	---	0.0002未満	---			3	0	0.0002未満	0.0002未満	0.0002未満	---
プロモホルム	mg/L	0.09mg/L以下	---	0.0002未満	---	---	0.0002未満	---	0.0002未満	---	0.0002未満	---			3	0	0.0002未満	0.0002未満	0.0002未満	---
ホルムアルデヒド	mg/L	0.08mg/L以下	---	0.004未満	---	---	0.004未満	---	0.004未満	---	0.004未満	---			3	0	0.004未満	0.004未満	0.004未満	---
亜鉛及びその化合物	mg/L	1.0mg/L以下	---	---	---	---	0.004	---	---	---	---	---			1	0	0.004	0.004	0.004	2025/08/06
アルミニウム及びその化合物	mg/L	0.2mg/L以下	---	---	---	---	0.007	---	---	---	---	---			1	0	0.007	0.007	0.007	2025/08/06
鉄及びその化合物	mg/L	0.3mg/L以下	---	---	---	---	0.02未満	---	---	---	---	---			1	0	0.02未満	0.02未満	0.02未満	---
銅及びその化合物	mg/L	1.0mg/L以下	---	---	---	---	0.010	---	---	---	---	---			1	0	0.010	0.010	0.010	2025/08/06
ナトリウム及びその化合物	mg/L	200mg/L以下	---	---	---	---	9.6	---	---	---	---	---			1	0	9.6	9.6	9.6	2025/08/06
マンガン及びその化合物	mg/L	0.05mg/L以下	---	---	---	---	0.001未満	---	---	---	---	---			1	0	0.001未満	0.001未満	0.001未満	---
塩化物イオン	mg/L	200mg/L以下	5.4	5.0	5.0	5.0	4.9	4.8	4.7	4.8	4.9	4.8			10	0	4.9	5.4	4.7	2025/04/02
カルシウム、マグネシウム等(硬度)	mg/L	300mg/L以下	---	73	---	---	71	---	69	---	120	---			3	0	71	73	69	2025/05/07
蒸発残留物	mg/L	500mg/L以下	---	140	---	---	130	---	---	---	120	---			3	0	130	140	120	2025/05/07
陰イオン界面活性剤	mg/L	0.2mg/L以下	---	---	---	---	0.02未満	---	---	---	---	---			1	0	0.02未満	0.02未満	0.02未満	---
ジェオスミン	mg/L	0.00001mg/L以下	---	---	---	---	0.000001未満	---	---	---	---	---			1	0	0.000001未満	0.000001未満	0.000001未満	---
2-メチルイソポルネオール	mg/L	0.00001mg/L以下	---	---	---	---	0.000001未満	---	---	---	---	---			1	0	0.000001未満	0.000001未満	0.000001未満	---
非イオン界面活性剤	mg/L	0.02mg/L以下	---	---	---	---	0.002未満	---	---	---	---	---			1	0	0.002未満	0.002未満	0.002未満	---
フェノール類	mg/L	0.005mg/L以下	---	---	---	---	0.0005未満	---	---	---	---	---			1	0	0.0005未満	0.0005未満	0.0005未満	---
有機物(全有機炭素(TOC)の量)	mg/L	3mg/L以下	0.2未満			10	0	0.2未満	0.2未満	0.2未満	---									
pH値	-	5.8以上8.6以下	7.5	7.6	7.5	6.9	7.6	7.6	7.7	7.6	7.5	7.6			10	0	7.5	7.7	6.9	2025/10/01
味	-	異常でないこと	異常なし			10	0	---	---	---	---									
臭気	-	異常でないこと	異常なし			10	0	---	---	---	---									
色度	度	5度以下	0.5未満			10	0	0.5未満	0.5未満	0.5未満	---									
濁度	度	2度以下	0.1未満			10	0	0.1未満	0.1未満	0.1未満	---									

上記項目についての水質基準適合判定

適合

施設名：焼津市上水（坂本加圧ポンプ所） 採水場所：焼津市坂本413-2 坂本加圧ポンプ所

項目	単位	基準値	2025/04/02	2025/05/07	2025/06/04	2025/07/02	2025/08/06	2025/09/03	2025/10/01	2025/11/05	2025/12/03	2026/01/07			測定回数	不適回数	平均値	最大値	最小値	最大値検出日
			25-SS-00030	25-SS-00425	25-SS-00928	25-SS-01459	25-SS-02036	25-SS-02613	25-SS-02976	25-SS-03415	25-SS-03841	25-SS-04225								
			SS																	
			上水道																	
水温	°C	-	17.0	18.0	19.0	21.1	22.8	22.0	19.0	17.1	16.0				10	0	19.5	22.8	16.0	2025/08/06
气温	°C	-	17.9	23.3	26.7	28.3	37.7	35.7	22.4	17.5	14.2	10.0			10	0	23.4	37.7	10.0	2025/08/06
残留塩素濃度	mg/L	-	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2			10	0	0.2	0.2	0.2	---
一般細菌	CFU/mL	100CFU/mL以下	1	0	0	0	0	0	2	0	0	0			10	0	0	2	0	2025/10/01
大腸菌	-	検出されないこと	検出しない			10	0	---	---	---	---									
カドミウム及びその化合物	mg/L	0.003mg/L以下	---	---	---	---	0.00015未満	---	---	---	---	---			1	0	0.00015未満	0.00015未満	0.00015未満	---
水銀及びその化合物	mg/L	0.005mg/L以下	---	---	---	---	0.00005未満	---	---	---	---	---			1	0	0.00005未満	0.00005未満	0.00005未満	---
セレン及びその化合物	mg/L	0.01mg/L以下	---	---	---	---	0.0006	---	---	---	---	---			1	0	0.0006	0.0006	0.0006	2025/08/06
鉛及びその化合物	mg/L	0.01mg/L以下	---	---	---	---	0.0005未満	---	---	---	---	---			1	0	0.0005未満	0.0005未満	0.0005未満	---
ヒ素及びその化合物	mg/L	0.01mg/L以下	---	---	---	---	0.0005未満	---	---	---	---	---			1	0	0.0005未満	0.0005未満	0.0005未満	---
六価クロム化合物	mg/L	0.02mg/L以下	---	---	---	---	0.002未満	---	---	---	---	---			1	0	0.002未満	0.002未満	0.002未満	---
亜硝酸態窒素	mg/L	0.04mg/L以下	---	---	---	---	0.004未満	---	---	---	---	---			1	0	0.004未満	0.004未満	0.004未満	---
シアノ化物イオン及び塩化シアノ	mg/L	0.01mg/L以下	---	0.001未満	---	---	0.001未満	---	0.001未満	---	---	---			3	0	0.001未満	0.001未満	0.001未満	---
硝酸態窒素及び亜硝酸態窒素	mg/L	10mg/L以下	---	---	---	---	0.9	---	---	---	---	---			1	0	0.90	0.90	0.90	2025/08/06
フッ素及びその化合物	mg/L	0.8mg/L以下	---	---	---	---	0.05未満	---	---	---	---	---			1	0	0.05未満	0.05未満	0.05未満	---
ホウ素及びその化合物	mg/L	1.0mg/L以下	---	---	---	---	0.04	---	---	---	---	---			1	0	0.04	0.04	0.04	2025/08/06
四塩化炭素	mg/L	0.002mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---			1	0	0.0002未満	0.0002未満	0.0002未満	---
1,4-ジオキサン	mg/L	0.05mg/L以下	---	---	---	---	0.003未満	---	---	---	---	---			1	0	0.003未満	0.003未満	0.003未満	---
ジメチルエチレングリコール及びジメチルエチレングリコール	mg/L	0.04mg/L以下	---	---	---	---	0.0004未満	---	---	---	---	---			1	0	0.0004未満	0.0004未満	0.0004未満	---
ジクロロメタン	mg/L	0.02mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---			1	0	0.0002未満	0.0002未満	0.0002未満	---
トライクロロエチレン	mg/L	0.01mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---			1	0	0.0002未満	0.0002未満	0.0002未満	---
トリクロロエチレン	mg/L	0.01mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---			1	0	0.0002未満	0.0002未満	0.0002未満	---
ベンゼン	mg/L	0.01mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---			1	0	0.0002未満	0.0002未満	0.0002未満	---
塩素酸	mg/L	0.6mg/L以下	---	0.06未満	---	---	0.06未満	---	0.06未満	---	0.06未満	---			3	0	0.06未満	0.06未満	0.06未満	---
クロロ酢酸	mg/L	0.02mg/L以下	---	0.002未満	---	---	0.002未満	---	0.002未満	---	0.002未満	---			3	0	0.002未満	0.002未満	0.002未満	---
クロロホルム	mg/L	0.06mg/L以下	---	0.0006	---	---	0.0013	---	0.0005	---	0.0005	---			3	0	0.0008	0.0013	0.0005	2025/08/06
ジクロロ酢酸	mg/L	0.03mg/L以下	---	0.002未満	---	---	0.002未満	---	0.002未満	---	0.002未満	---			3	0	0.002未満	0.002未満	0.002未満	---
ジプロモクロロメタン	mg/L	0.1mg/L以下	---	0.0002	---	---	0.0003	---	0.0002未満	---	0.0002未満	---			3	0	0.0002	0.0003	0.0002未満	2025/08/06
臭素酸	mg/L	0.01mg/L以下	---	0.001未満	---	---	0.001未満	---	0.001未満	---	0.001未満	---			3	0	0.001未満	0.001未満	0.001未満	---
総トリハロメタン	mg/L	0.1mg/L以下	---	0.01未満	---	---	0.01未満	---	0.01未満	---	0.01未満	---			3	0	0.01未満	0.01未満	0.01未満	---
トリクロロ酢酸	mg/L	0.03mg/L以下	---	0.002未満	---	---	0.002未満	---	0.002未満	---	0.002未満	---			3	0	0.002未満	0.002未満	0.002未満	---
ブロモジクロロメタン	mg/L	0.03mg/L以下	---	0.0002未満	---	---	0.0002	---	0.0002未満	---	0.0002未満	---			3	0	0.0001	0.0002	0.0002未満	2025/08/06
ブロモホルム	mg/L	0.09mg/L以下	---	0.0002未満	---	---	0.0002未満	---	0.0002未満	---	0.0002未満	---			3	0	0.0002未満	0.0002未満	0.0002未満	---
ホルムアルデヒド	mg/L	0.08mg/L以下	---	0.004未満	---	---	0.004未満	---	0.004未満	---	0.004未満	---			3	0	0.004未満	0.004未満	0.004未満	---
亜鉛及びその化合物	mg/L	1.0mg/L以下	---	---	---	---	0.002未満	---	---	---	---	---			1	0	0.002未満	0.002未満	0.002未満	---
アルミニウム及びその化合物	mg/L	0.2mg/L以下	---	---	---	---	0.010	---	---	---	---	---			1	0	0.010	0.010	0.010	2025/08/06
鉄及びその化合物	mg/L	0.3mg/L以下	---	---	---	---	0.02未満	---	---	---	---	---			1	0	0.02未満	0.02未満	0.02未満	---
銅及びその化合物	mg/L	1.0mg/L以下	---	---	---	---	0.003	---	---	---	---	---			1	0	0.003	0.003	0.003	2025/08/06
ナトリウム及びその化合物	mg/L	200mg/L以下	---	---	---	---	9.0	---	---	---	---	---			1	0	9.0	9.0	9.0	2025/08/06
マンガン及びその化合物	mg/L	0.05mg/L以下	---	---	---	---	0.001未満	---	---	---	---	---			1	0	0.001未満	0.001未満	0.001未満	---
塩化物イオン	mg/L	200mg/L以下	5.6	5.0	5.4	5.4	5.1	4.9	5.0	4.9	5.2	5.5			10	0	5.2	5.6	4.9	2025/04/02
カルシウム、マグネシウム等(硬度)	mg/L	300mg/L以下	---	65	---	---	60	---	62	---	120	---			3	0	62	65	60	2025/05/07
蒸発残留物	mg/L	500mg/L以下	---	140	---	---	110	---	---	---	120	---			3	0	123	140	110	2025/05/07
陰イオン界面活性剤	mg/L	0.2mg/L以下	---	---	---	---	0.02未満	---	---	---	---	---			1	0	0.02未満	0.02未満	0.02未満	---
ジェオスミン	mg/L	0.00001mg/L以下	---	---	---	---	0.000001未満	---	---	---	---	---			1	0	0.000001未満	0.000001未満	0.000001未満	---
2-メチルイソポルネオール	mg/L	0.00001mg/L以下	---	---	---	---	0.000001未満	---	---	---	---	---			1	0	0.000001未満	0.000001未満	0.000001未満	---
非イオン界面活性剤	mg/L	0.02mg/L以下	---	---	---	---	0.002未満	---	---	---	---	---			1	0	0.002未満	0.002未満	0.002未満	---
フェノール類	mg/L	0.005mg/L以下	---	---	---	---	0.0005未満	---	---	---	---	---			1	0	0.0005未満	0.0005未満	0.0005未満	---
有機物(全有機炭素(TOC)の量)	mg/L	3mg/L以下	0.2未満			10	0	0.2未満	0.2未満	0.2未満	---									
pH値	-	5.8以上6.8以下	7.0	7.2	7.0	6.9	7.1	7.2	7.0	7.1	7.0	7.0			10	0	7.1	7.2	6.9	2025/05/07
味	-	異常でないこと	異常なし			10	0	---	---	---	---									
臭気	-	異常でないこと	異常なし			10	0	---	---	---	---									
色度	度	5度以下	0.5未満			10	0	0.5未満	0.5未満	0.5未満	---									
濁度	度	2度以下	0.1未満			10	0	0.1未満	0.1未満	0.1未満	---									

上記項目についての水質基準適合判定

適合

施設名：焼津市上水（上小杉住生協公園） 採水場所：焼津市上小杉887-95 上小杉住生協公園

項目	単位	基準値	2025/04/02	2025/05/07	2025/06/04	2025/07/02	2025/08/06	2025/09/03	2025/10/01	2025/11/05	2025/12/03	2026/01/07			測定回数	不適回数	平均値	最大値	最小値	最大値検出日
			25-SS-00024	25-SS-00419	25-SS-00922	25-SS-01453	25-SS-02022	25-SS-02607	25-SS-02970	25-SS-03409	25-SS-03835	25-SS-04219								
			SS																	
			上水道																	
水温	°C	-	16.0	18.5	19.2	23.2	25.5	25.1	23.0	18.8	16.8	14.0			10	0	20.0	25.5	14.0	2025/08/06
气温	°C	-	16.3	23.8	25.0	30.0	36.1	34.0	24.6	15.3	13.5	8.9			10	0	22.8	36.1	8.9	2025/08/06
残留塩素濃度	mg/L	-	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2			10	0	0.2	0.2	0.2	---
一般細菌	CFU/mL	100CFU/mL以下	0	0	0	0	0	0	0	0	0	0			10	0	0	0	0	---
大腸菌	-	検出されないこと	検出しない			10	0	---	---	---	---									
カドミウム及びその化合物	mg/L	0.003mg/L以下	---	---	---	---	0.00015未満	---	---	---	---	---			1	0	0.00015未満	0.00015未満	0.00015未満	---
水銀及びその化合物	mg/L	0.005mg/L以下	---	---	---	---	0.00005未満	---	---	---	---	---			1	0	0.00005未満	0.00005未満	0.00005未満	---
セレン及びその化合物	mg/L	0.01mg/L以下	---	---	---	---	0.0005未満	---	---	---	---	---			1	0	0.0005未満	0.0005未満	0.0005未満	---
鉛及びその化合物	mg/L	0.01mg/L以下	---	---	---	---	0.0005未満	---	---	---	---	---			1	0	0.0005未満	0.0005未満	0.0005未満	---
ヒ素及びその化合物	mg/L	0.01mg/L以下	---	---	---	---	0.0005未満	---	---	---	---	---			1	0	0.0005未満	0.0005未満	0.0005未満	---
六価クロム化合物	mg/L	0.02mg/L以下	---	---	---	---	0.002未満	---	---	---	---	---			1	0	0.002未満	0.002未満	0.002未満	---
亜硝酸態窒素	mg/L	0.04mg/L以下	---	---	---	---	0.004未満	---	---	---	---	---			1	0	0.004未満	0.004未満	0.004未満	---
シアノ化物イオン及び塩化シアノ	mg/L	0.01mg/L以下	---	0.001未満	---	---	0.001未満	---	0.001未満	---	---	---			3	0	0.001未満	0.001未満	0.001未満	---
硝酸態窒素及び亜硝酸態窒素	mg/L	10mg/L以下	---	---	---	---	0.3	---	---	---	---	---			1	0	0.30	0.30	0.30	2025/08/06
フッ素及びその化合物	mg/L	0.8mg/L以下	---	---	---	---	0.05未満	---	---	---	---	---			1	0	0.05未満	0.05未満	0.05未満	---
ホウ素及びその化合物	mg/L	1.0mg/L以下	---	---	---	---	0.03	---	---	---	---	---			1	0	0.03	0.03	0.03	2025/08/06
四塩化炭素	mg/L	0.002mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---			1	0	0.0002未満	0.0002未満	0.0002未満	---
1,4-ジオキサン	mg/L	0.05mg/L以下	---	---	---	---	0.003未満	---	---	---	---	---			1	0	0.003未満	0.003未満	0.003未満	---
シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン	mg/L	0.04mg/L以下	---	---	---	---	0.0004未満	---	---	---	---	---			1	0	0.0004未満	0.0004未満	0.0004未満	---
ジクロロメタン	mg/L	0.02mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---			1	0	0.0002未満	0.0002未満	0.0002未満	---
トトラクロロエチレン	mg/L	0.01mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---			1	0	0.0002未満	0.0002未満	0.0002未満	---
トリクロロエチレン	mg/L	0.01mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---			1	0	0.0002未満	0.0002未満	0.0002未満	---
ベンゼン	mg/L	0.01mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---			1	0	0.0002未満	0.0002未満	0.0002未満	---
塩素酸	mg/L	0.6mg/L以下	---	0.06未満	---	---	0.06未満	---	0.06未満	---	0.06未満	---			3	0	0.06未満	0.06未満	0.06未満	---
クロロ酢酸	mg/L	0.02mg/L以下	---	0.002未満	---	---	0.002未満	---	0.002未満	---	0.002未満	---			3	0	0.002未満	0.002未満	0.002未満	---
クロロホルム	mg/L	0.06mg/L以下	---	0.0012	---	---	0.0014	---	0.0012	---	0.0012	---			3	0	0.0013	0.0014	0.0012	2025/08/06
ジクロロ酢酸	mg/L	0.03mg/L以下	---	0.002未満	---	---	0.002未満	---	0.002未満	---	0.002未満	---			3	0	0.002未満	0.002未満	0.002未満	---
ジプロモクロロメタン	mg/L	0.1mg/L以下	---	0.0002	---	---	0.0002	---	0.0002	---	0.0002	---			3	0	0.0002	0.0002	0.0002	---
臭素酸	mg/L	0.01mg/L以下	---	0.001未満	---	---	0.001未満	---	0.001未満	---	0.001未満	---			3	0	0.001未満	0.001未満	0.001未満	---
総トドハロメタン	mg/L	0.1mg/L以下	---	0.01未満	---	---	0.01未満	---	0.01未満	---	0.01未満	---			3	0	0.01未満	0.01未満	0.01未満	---
トリクロロ酢酸	mg/L	0.03mg/L以下	---	0.002未満	---	---	0.002未満	---	0.002未満	---	0.002未満	---			3	0	0.002未満	0.002未満	0.002未満	---
ブロモジクロロメタン	mg/L	0.03mg/L以下	---	0.0003	---	---	0.0003	---	0.0002	---	0.0002	---			3	0	0.0003	0.0003	0.0002	2025/05/07
ブロモホルム	mg/L	0.09mg/L以下	---	0.0002未満	---	---	0.0002未満	---	0.0002未満	---	0.0002未満	---			3	0	0.0002未満	0.0002未満	0.0002未満	---
ホルムアルデヒド	mg/L	0.08mg/L以下	---	0.004未満	---	---	0.004未満	---	0.004未満	---	0.004未満	---			3	0	0.004未満	0.004未満	0.004未満	---
亜鉛及びその化合物	mg/L	1.0mg/L以下	---	---	---	0.007	---	---	---	---	---	---			1	0	0.007	0.007	0.007	2025/08/06
アルミニウム及びその化合物	mg/L	0.2mg/L以下	---	---	---	0.010	---	---	---	---	---	---			1	0	0.010	0.010	0.010	2025/08/06
鉄及びその化合物	mg/L	0.3mg/L以下	---	---	---	---	0.02未満	---	---	---	---	---			1	0	0.02未満	0.02未満	0.02未満	---
銅及びその化合物	mg/L	1.0mg/L以下	---	---	---	0.010	---	---	---	---	---	---			1	0	0.010	0.010	0.010	2025/08/06
ナトリウム及びその化合物	mg/L	200mg/L以下	---	---	---	7.7	---	---	---	---	---	---			1	0	7.7	7.7	7.7	2025/08/06
マンガン及びその化合物	mg/L	0.05mg/L以下	---	---	---	0.001未満	---	---	---	---	---	---			1	0	0.001未満	0.001未満	0.001未満	---
塩化物イオン	mg/L	200mg/L以下	3.2	3.1	3.2	3.3	3.5	3.4	3.3	3.4	3.4	4.2			10	0	3.4	4.2	3.1	2026/01/07
カルシウム、マグネシウム等(硬度)	mg/L	300mg/L以下	---	60	---	---	59	---	56	---	110	---			3	0	58	60	56	2025/05/07
蒸発残留物	mg/L	500mg/L以下	---	120	---	---	120	---	---	---	110	---			3	0	117	120	110	2025/05/07
陰イオン界面活性剤	mg/L	0.2mg/L以下	---	---	---	0.02未満	---	---	---	---	---	---			1	0	0.02未満	0.02未満	0.02未満	---
ジェオスミン	mg/L	0.0001mg/L以下	---	---	---	0.000001未満	---	---	---	---	---	---			1	0	0.000001未満	0.000001未満	0.000001未満	---
2-メチルイソポルネオール	mg/L	0.00001mg/L以下	---	---	---	0.000001未満	---	---	---	---	---	---			1	0	0.000001未満	0.000001未満	0.000001未満	---
非イオン界面活性剤	mg/L	0.02mg/L以下	---	---	---	0.002未満	---	---	---	---	---	---			1	0	0.002未満	0.002未満	0.002未満	---
フェノール類	mg/L	0.005mg/L以下	---	---	---	0.0005未満	---	---	---	---	---	---			1	0	0.0005未満	0.0005未満	0.0005未満	---
有機物(全有機炭素(TOC)の量)	mg/L	3mg/L以下	0.2未満			10	0	0.2未満	0.2未満	0.2未満	---									
pH値	-	5.8以上6.6以下	7.2	7.2	7.2	7.2	7.2	7.3	7.2	7.2	7.3	7.3			10	0	7.2	7.2	7.2	2025/10/01
味	-	異常でないこと	異常なし			10	0	---	---	---	---									
臭気	-	異常でないこと	異常なし			10	0	---	---	---	---									
色度	度	5度以下	0.5未満			10	0	0.5未満	0.5未満	0.5未満	---									
濁度	度	2度以下	0.1未満			10	0	0.1未満	0.1未満	0.1未満	---									

上記項目についての水質基準適合判定

項目	適合																			
水温	適合																			
气温	適合																			
残留塩素濃度	適合																			
一般細菌	適合	適合	適合	適合	適合															

施設名：焼津市上水（下小杉児童公園） 採水場所：焼津市下小杉 480-1 下小杉児童公園

項目	単位	基準値	2025/04/02	2025/05/07	2025/06/04	2025/07/02	2025/08/06	2025/09/03	2025/10/01	2025/11/05	2025/12/03	2026/01/07			測定回数	不適回数	平均値	最大値	最小値	最大値検出日
			25-SS-00027	25-SS-00422	25-SS-00925	25-SS-01456	25-SS-02025	25-SS-02610	25-SS-02973	25-SS-03412	25-SS-03838	25-SS-04222								
			SS																	
			上水道																	
水温	°C	-	16.0	20.5	22.2	28.0	28.0	32.0	29.0	20.2	17.5	13.0			10	0	22.6	32.0	13.0	2025/09/03
気温	°C	-	18.6	23.6	25.6	28.7	36.8	33.2	24.5	16.7	14.0	9.3			10	0	23.1	36.8	9.3	2025/08/06
残留塩素濃度	mg/L	-	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2			10	0	0.2	0.2	0.2	---
一般細菌	CFU/mL	100CFU/mL以下	1	0	0	0	0	0	0	0	0	0			10	0	0	1	0	2025/04/02
大腸菌	-	検出されないこと	検出しない			10	0	---	---	---	---									
カドミウム及びその化合物	mg/L	0.003mg/L以下	---	---	---	---	0.00015未満	---	---	---	---	---			1	0	0.00015未満	0.00015未満	0.00015未満	---
水銀及びその化合物	mg/L	0.005mg/L以下	---	---	---	---	0.00005未満	---	---	---	---	---			1	0	0.00005未満	0.00005未満	0.00005未満	---
セレン及びその化合物	mg/L	0.01mg/L以下	---	---	---	---	0.0005未満	---	---	---	---	---			1	0	0.0005未満	0.0005未満	0.0005未満	---
鉛及びその化合物	mg/L	0.01mg/L以下	---	---	---	---	0.0005未満	---	---	---	---	---			1	0	0.0005未満	0.0005未満	0.0005未満	---
ヒ素及びその化合物	mg/L	0.01mg/L以下	---	---	---	---	0.0005未満	---	---	---	---	---			1	0	0.0005未満	0.0005未満	0.0005未満	---
六価クロム化合物	mg/L	0.02mg/L以下	---	---	---	---	0.002未満	---	---	---	---	---			1	0	0.002未満	0.002未満	0.002未満	---
亜硝酸態窒素	mg/L	0.04mg/L以下	---	---	---	---	0.004未満	---	---	---	---	---			1	0	0.004未満	0.004未満	0.004未満	---
シアノ化物イオン及び塩化シアノ	mg/L	0.01mg/L以下	---	0.001未満	---	---	0.001未満	---	0.001未満	---	---	---			3	0	0.001未満	0.001未満	0.001未満	---
硝酸態窒素及び亜硝酸態窒素	mg/L	10mg/L以下	---	---	---	---	0.3	---	---	---	---	---			1	0	0.30	0.30	0.30	2025/08/06
フッ素及びその化合物	mg/L	0.8mg/L以下	---	---	---	---	0.05未満	---	---	---	---	---			1	0	0.05未満	0.05未満	0.05未満	---
ホウ素及びその化合物	mg/L	1.0mg/L以下	---	---	---	---	0.03	---	---	---	---	---			1	0	0.03	0.03	0.03	2025/08/06
四塩化炭素	mg/L	0.002mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---			1	0	0.0002未満	0.0002未満	0.0002未満	---
1,4-ジオキサン	mg/L	0.05mg/L以下	---	---	---	---	0.003未満	---	---	---	---	---			1	0	0.003未満	0.003未満	0.003未満	---
ジメチルエチレングリコール及びジメチルエチレングリコール	mg/L	0.04mg/L以下	---	---	---	---	0.0004未満	---	---	---	---	---			1	0	0.0004未満	0.0004未満	0.0004未満	---
ジクロロメタン	mg/L	0.02mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---			1	0	0.0002未満	0.0002未満	0.0002未満	---
トライクロロエチレン	mg/L	0.01mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---			1	0	0.0002未満	0.0002未満	0.0002未満	---
トリクロロエチレン	mg/L	0.01mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---			1	0	0.0002未満	0.0002未満	0.0002未満	---
ベンゼン	mg/L	0.01mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---			1	0	0.0002未満	0.0002未満	0.0002未満	---
塩素酸	mg/L	0.6mg/L以下	---	0.06未満	---	---	0.06未満	---	0.06未満	---	0.06未満	---			3	0	0.06未満	0.06未満	0.06未満	---
クロロ酢酸	mg/L	0.02mg/L以下	---	0.002未満	---	---	0.002未満	---	0.002未満	---	0.002未満	---			3	0	0.002未満	0.002未満	0.002未満	---
クロロホルム	mg/L	0.06mg/L以下	---	0.0013	---	---	0.0016	---	0.0013	---	0.0013	---			3	0	0.0014	0.0016	0.0013	2025/08/06
ジクロロ酢酸	mg/L	0.03mg/L以下	---	0.002未満	---	---	0.002未満	---	0.002未満	---	0.002未満	---			3	0	0.002未満	0.002未満	0.002未満	---
ジブロモクロロメタン	mg/L	0.1mg/L以下	---	0.0003	---	---	0.0004	---	0.0003	---	0.0003	---			3	0	0.0003	0.0004	0.0003	2025/08/06
臭素酸	mg/L	0.01mg/L以下	---	0.001未満	---	---	0.001未満	---	0.001未満	---	0.001未満	---			3	0	0.001未満	0.001未満	0.001未満	---
総ドーハメタン	mg/L	0.1mg/L以下	---	0.01未満	---	---	0.01未満	---	0.01未満	---	0.01未満	---			3	0	0.01未満	0.01未満	0.01未満	---
トリクロロ酢酸	mg/L	0.03mg/L以下	---	0.002未満	---	---	0.002未満	---	0.002未満	---	0.002未満	---			3	0	0.002未満	0.002未満	0.002未満	---
プロモジクロロメタン	mg/L	0.03mg/L以下	---	0.0004	---	---	0.0004	---	0.0003	---	0.0003	---			3	0	0.0004	0.0004	0.0003	2025/05/07
プロモホルム	mg/L	0.09mg/L以下	---	0.0002未満	---	---	0.0002	---	0.0002未満	---	0.0002未満	---			3	0	0.0001	0.0002	0.0002未満	2025/08/06
ホルムアルデヒド	mg/L	0.08mg/L以下	---	0.004未満	---	---	0.004未満	---	0.004未満	---	0.004未満	---			3	0	0.004未満	0.004未満	0.004未満	---
亜鉛及びその化合物	mg/L	1.0mg/L以下	---	---	---	---	0.009	---	---	---	---	---			1	0	0.009	0.009	0.009	2025/08/06
アルミニウム及びその化合物	mg/L	0.2mg/L以下	---	---	---	---	0.009	---	---	---	---	---			1	0	0.009	0.009	0.009	2025/08/06
鉄及びその化合物	mg/L	0.3mg/L以下	---	---	---	---	0.02未満	---	---	---	---	---			1	0	0.02未満	0.02未満	0.02未満	---
銅及びその化合物	mg/L	1.0mg/L以下	---	---	---	---	0.014	---	---	---	---	---			1	0	0.014	0.014	0.014	2025/08/06
ナトリウム及びその化合物	mg/L	200mg/L以下	---	---	---	---	7.6	---	---	---	---	---			1	0	7.6	7.6	7.6	2025/08/06
マンガン及びその化合物	mg/L	0.05mg/L以下	---	---	---	---	0.001未満	---	---	---	---	---			1	0	0.001未満	0.001未満	0.001未満	---
塩化物イオン	mg/L	200mg/L以下	3.3	3.1	3.3	3.5	3.5	3.4	3.3	3.4	3.4	4.1			10	0	3.4	4.1	3.1	2026/01/07
カルシウム、マグネシウム等(硬度)	mg/L	300mg/L以下	---	61	---	---	58	---	58	---	100	---			3	0	59	61	58	2025/05/07
蒸発残留物	mg/L	500mg/L以下	---	120	---	---	110	---	---	---	100	---			3	0	110	120	100	2025/05/07
陰イオン界面活性剤	mg/L	0.2mg/L以下	---	---	---	---	0.02未満	---	---	---	---	---			1	0	0.02未満	0.02未満	0.02未満	---
ジェオスミン	mg/L	0.0001mg/L以下	---	---	---	---	0.000001未満	---	---	---	---	---			1	0	0.000001未満	0.000001未満	0.000001未満	---
2-メチルイソポルネオール	mg/L	0.00001mg/L以下	---	---	---	---	0.000001未満	---	---	---	---	---			1	0	0.000001未満	0.000001未満	0.000001未満	---
非イオン界面活性剤	mg/L	0.02mg/L以下	---	---	---	---	0.002未満	---	---	---	---	---			1	0	0.002未満	0.002未満	0.002未満	---
フェノール類	mg/L	0.005mg/L以下	---	---	---	---	0.0005未満	---	---	---	---	---			1	0	0.0005未満	0.0005未満	0.0005未満	---
有機物(全有機炭素(TOC)の量)	mg/L	3mg/L以下	0.2未満			10	0	0.2未満	0.2未満	0.2未満	---									
pH値	-	5.8以上6.6以下	7.3	7.2	7.3	7.3	7.4	7.3	7.2	7.2	7.3				10	0	7.3	7.4	7.2	2025/09/03
味	-	異常でないこと	異常なし			10	0	---	---	---	---									
臭気	-	異常でないこと	異常なし			10	0	---	---	---	---									
色度	度	5度以下	0.5未満			10	0	0.5未満	0.5未満	0.5未満	---									
濁度	度	2度以下	0.1未満			10	0	0.1未満	0.1未満	0.1未満	---									

上記項目についての水質基準適合判定

適合 合格 合格

施設名：焼津市上水（吉永森林公园） 採水場所：焼津市吉永 吉永森林公园

項目	単位	基準値	2025/04/02	2025/05/07	2025/06/04	2025/07/02	2025/08/06	2025/09/03	2025/10/01	2025/11/05	2025/12/03	2026/01/07			測定回数	不適回数	平均値	最大値	最小値	最大値検出日
			25-SS-00026	25-SS-00421	25-SS-00924	25-SS-01455	25-SS-02024	25-SS-02609	25-SS-02972	25-SS-03411	25-SS-03837	25-SS-04221								
			SS																	
			上水道																	
水温	°C	-	15.0	18.5	21.5	26.8	28.5	27.0	21.0	19.0	17.0	13.0			10	0	20.7	28.5	13.0	2025/08/06
气温	°C	-	18.0	22.2	24.9	28.3	37.2	34.3	23.4	15.8	13.8	9.5			10	0	22.7	37.2	9.5	2025/08/06
残留塩素濃度	mg/L	-	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2			10	0	0.2	0.2	0.2	---
一般細菌	CFU/mL	100CFU/mL以下	0	0	0	0	0	0	0	0	0	0			10	0	0	0	0	---
大腸菌	-	検出されないこと	検出しない			10	0	---	---	---	---									
カドミウム及びその化合物	mg/L	0.003mg/L以下	---	---	---	---	0.00015未満	---	---	---	---	---			1	0	0.00015未満	0.00015未満	0.00015未満	---
水銀及びその化合物	mg/L	0.005mg/L以下	---	---	---	---	0.00005未満	---	---	---	---	---			1	0	0.00005未満	0.00005未満	0.00005未満	---
セレン及びその化合物	mg/L	0.01mg/L以下	---	---	---	---	0.0005未満	---	---	---	---	---			1	0	0.0005未満	0.0005未満	0.0005未満	---
鉛及びその化合物	mg/L	0.01mg/L以下	---	---	---	---	0.0005未満	---	---	---	---	---			1	0	0.0005未満	0.0005未満	0.0005未満	---
ヒ素及びその化合物	mg/L	0.01mg/L以下	---	---	---	---	0.0005未満	---	---	---	---	---			1	0	0.0005未満	0.0005未満	0.0005未満	---
六価クロム化合物	mg/L	0.02mg/L以下	---	---	---	---	0.002未満	---	---	---	---	---			1	0	0.002未満	0.002未満	0.002未満	---
亜硝酸態窒素	mg/L	0.04mg/L以下	---	---	---	---	0.004未満	---	---	---	---	---			1	0	0.004未満	0.004未満	0.004未満	---
シアノ化物イオン及び塩化シアノ	mg/L	0.01mg/L以下	---	0.001未満	---	---	0.001未満	---	0.001未満	---	---	---			3	0	0.001未満	0.001未満	0.001未満	---
硝酸態窒素及び亜硝酸態窒素	mg/L	10mg/L以下	---	---	---	---	0.4	---	---	---	---	---			1	0	0.40	0.40	0.40	2025/08/06
フッ素及びその化合物	mg/L	0.8mg/L以下	---	---	---	---	0.05未満	---	---	---	---	---			1	0	0.05未満	0.05未満	0.05未満	---
ホウ素及びその化合物	mg/L	1.0mg/L以下	---	---	---	---	0.03	---	---	---	---	---			1	0	0.03	0.03	0.03	2025/08/06
四塩化炭素	mg/L	0.002mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---			1	0	0.0002未満	0.0002未満	0.0002未満	---
1,4-ジオキサン	mg/L	0.05mg/L以下	---	---	---	---	0.003未満	---	---	---	---	---			1	0	0.003未満	0.003未満	0.003未満	---
シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン	mg/L	0.04mg/L以下	---	---	---	---	0.0004未満	---	---	---	---	---			1	0	0.0004未満	0.0004未満	0.0004未満	---
ジクロロメタン	mg/L	0.02mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---			1	0	0.0002未満	0.0002未満	0.0002未満	---
トトラクロロエチレン	mg/L	0.01mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---			1	0	0.0002未満	0.0002未満	0.0002未満	---
トリクロロエチレン	mg/L	0.01mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---			1	0	0.0002未満	0.0002未満	0.0002未満	---
ベンゼン	mg/L	0.01mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---			1	0	0.0002未満	0.0002未満	0.0002未満	---
塩素酸	mg/L	0.6mg/L以下	---	0.06未満	---	---	0.06未満	---	0.06未満	---	0.06未満	---			3	0	0.06未満	0.06未満	0.06未満	---
クロロ酢酸	mg/L	0.02mg/L以下	---	0.002未満	---	---	0.002未満	---	0.002未満	---	0.002未満	---			3	0	0.002未満	0.002未満	0.002未満	---
クロロホルム	mg/L	0.06mg/L以下	---	0.0002未満	---	---	0.0002未満	---	0.0002未満	---	0.0002未満	---			3	0	0.0002未満	0.0002未満	0.0002未満	---
ジクロロ酢酸	mg/L	0.03mg/L以下	---	0.002未満	---	---	0.002未満	---	0.002未満	---	0.002未満	---			3	0	0.002未満	0.002未満	0.002未満	---
ジブロモクロロメタン	mg/L	0.1mg/L以下	---	0.0002未満	---	---	0.0002未満	---	0.0002未満	---	0.0002未満	---			3	0	0.0002未満	0.0002未満	0.0002未満	---
臭素酸	mg/L	0.01mg/L以下	---	0.001未満	---	---	0.001未満	---	0.001未満	---	0.001未満	---			3	0	0.001未満	0.001未満	0.001未満	---
総トライハロメタン	mg/L	0.1mg/L以下	---	0.01未満	---	---	0.01未満	---	0.01未満	---	0.01未満	---			3	0	0.01未満	0.01未満	0.01未満	---
トリクロロ酢酸	mg/L	0.03mg/L以下	---	0.002未満	---	---	0.002未満	---	0.002未満	---	0.002未満	---			3	0	0.002未満	0.002未満	0.002未満	---
プロモジクロロメタン	mg/L	0.03mg/L以下	---	0.0002未満	---	---	0.0002未満	---	0.0002未満	---	0.0002未満	---			3	0	0.0002未満	0.0002未満	0.0002未満	---
プロモホルム	mg/L	0.09mg/L以下	---	0.0002未満	---	---	0.0002未満	---	0.0002未満	---	0.0002未満	---			3	0	0.0002未満	0.0002未満	0.0002未満	---
ホルムアルデヒド	mg/L	0.08mg/L以下	---	0.004未満	---	---	0.004未満	---	0.004未満	---	0.004未満	---			3	0	0.004未満	0.004未満	0.004未満	---
亜鉛及びその化合物	mg/L	1.0mg/L以下	---	---	---	---	0.03	---	---	---	---	---			1	0	0.003	0.003	0.003	2025/08/06
アルミニウム及びその化合物	mg/L	0.2mg/L以下	---	---	---	---	0.005未満	---	---	---	---	---			1	0	0.005未満	0.005未満	0.005未満	---
鉄及びその化合物	mg/L	0.3mg/L以下	---	---	---	---	0.02未満	---	---	---	---	---			1	0	0.02未満	0.02未満	0.02未満	---
銅及びその化合物	mg/L	1.0mg/L以下	---	---	---	---	0.007	---	---	---	---	---			1	0	0.007	0.007	0.007	2025/08/06
ナトリウム及びその化合物	mg/L	200mg/L以下	---	---	---	---	7.2	---	---	---	---	---			1	0	7.2	7.2	7.2	2025/08/06
マンガン及びその化合物	mg/L	0.05mg/L以下	---	---	---	---	0.001未満	---	---	---	---	---			1	0	0.001未満	0.001未満	0.001未満	---
塩化物イオン	mg/L	200mg/L以下	3.2	3.0	3.0	3.0	2.9	2.8	2.8	2.8	2.9	2.7			10	0	2.9	3.2	2.7	2025/04/02
カルシウム、マグネシウム等(硬度)	mg/L	300mg/L以下	---	63	---	---	59	---	61	---	110	---			3	0	61	63	59	2025/05/07
蒸発残留物	mg/L	500mg/L以下	---	120	---	---	110	---	110	---	110	---			3	0	113	120	110	2025/05/07
陰イオン界面活性剤	mg/L	0.2mg/L以下	---	---	---	---	0.02未満	---	---	---	---	---			1	0	0.02未満	0.02未満	0.02未満	---
ジェオスミン	mg/L	0.0001mg/L以下	---	---	---	---	0.000001未満	---	---	---	---	---			1	0	0.000001未満	0.000001未満	0.000001未満	---
2-メチルイソポルネオール	mg/L	0.00001mg/L以下	---	---	---	---	0.000001未満	---	---	---	---	---			1	0	0.000001未満	0.000001未満	0.000001未満	---
非イオン界面活性剤	mg/L	0.02mg/L以下	---	---	---	---	0.002未満	---	---	---	---	---			1	0	0.002未満	0.002未満	0.002未満	---
フェノール類	mg/L	0.005mg/L以下	---	---	---	---	0.0005未満	---	---	---	---	---			1	0	0.0005未満	0.0005未満	0.0005未満	---
有機物(全有機炭素(TOC)の量)	mg/L	3mg/L以下	0.2未満			10	0	0.2未満	0.2未満	0.2未満	---									
pH値	-	5.8以上8.6以下	7.5	7.5	7.5	7.6	7.5	7.6	7.5	7.5	7.5	7.5			10	0	7.5	7.6	7.5	2025/07/02
味	-	異常でないこと	異常なし			10	0	---	---	---	---									
臭気	-	異常でないこと	異常なし			10	0	---	---	---	---									
色度	度	5度以下	0.5未満			10	0	0.5未満	0.5未満	0.5未満	---									
濁度	度	2度以下	0.1未満			10	0	0.1未満	0.1未満	0.1未満	---									

上記項目についての水質基準適合判定

適合

適合