

項目	単位	基準値	2024/04/03	2024/05/08	2024/06/05	2024/07/03	2024/08/07	2024/09/04	2024/10/02	2024/11/06	2024/12/04	2025/01/08	2025/02/05	2025/03/05	測定回数	不適回数	平均値	最大値	最小値	最大値検出日
			24-SS-00041	24-SS-00429	24-SS-00910	24-SS-01446	24-SS-02068	24-SS-02568	24-SS-03030	24-SS-03437	24-SS-03885	24-SS-04274	24-SS-04707	24-SS-05074						
			SS 上水道																	
水温	℃	-	16.0	19.5	21.0	23.5	27.0	24.5	25.5	21.2	19.0	14.0	15.0	14.0	12	0	20.0	27.0	14.0	2024/08/07
気温	℃	-	13.8	24.2	22.6	29.6	32.0	28.4	29.2	21.1	18.5	8.6	8.4	11.0	12	0	20.6	32.0	8.4	2024/08/07
残留塩素濃度	mg/L	-	0.3	0.3	0.3	0.3	0.2	0.3	0.2	0.2	0.2	0.2	0.2	0.2	12	0	0.2	0.3	0.2	2024/04/03
一般細菌	CFU/mL	100CFU/mL以下	0	0	2	0	0	0	0	0	0	0	0	0	12	0	0	2	0	2024/06/05
大腸菌	-	検出されないこと	検出しない	12	0	---	---	---	---											
カドミウム及びその化合物	mg/L	0.003mg/L以下	---	---	---	---	0.00015未満	---	---	---	---	---	---	---	1	0	0.00015未満	0.00015未満	0.00015未満	---
水銀及びその化合物	mg/L	0.0005mg/L以下	---	---	---	---	0.00005未満	---	---	---	---	---	---	---	1	0	0.00005未満	0.00005未満	0.00005未満	---
セレン及びその化合物	mg/L	0.01mg/L以下	---	---	---	---	0.0005未満	---	---	---	---	---	---	---	1	0	0.0005未満	0.0005未満	0.0005未満	---
鉛及びその化合物	mg/L	0.01mg/L以下	---	---	---	---	0.0006	---	---	---	---	---	---	---	1	0	0.0006	0.0006	0.0006	2024/08/07
ヒ素及びその化合物	mg/L	0.01mg/L以下	---	---	---	---	0.0005未満	---	---	---	---	---	---	---	1	0	0.0005未満	0.0005未満	0.0005未満	---
六価クロム化合物	mg/L	0.02mg/L以下	---	---	---	---	0.002未満	---	---	---	---	---	---	---	1	0	0.002未満	0.002未満	0.002未満	---
亜硝酸態窒素	mg/L	0.04mg/L以下	---	---	---	---	0.004未満	---	---	---	---	---	---	---	1	0	0.004未満	0.004未満	0.004未満	---
シアン化物イオン及び塩化シアン	mg/L	0.01mg/L以下	---	0.001未満	---	4	0	0.001未満	0.001未満	0.001未満	---									
硝酸態窒素及び亜硝酸態窒素	mg/L	10mg/L以下	---	---	---	---	1.0	---	---	---	---	---	---	---	1	0	1.0	1.0	1.0	2024/08/07
フッ素及びその化合物	mg/L	0.8mg/L以下	---	---	---	---	0.05未満	---	---	---	---	---	---	---	1	0	0.05未満	0.05未満	0.05未満	---
ホウ素及びその化合物	mg/L	1.0mg/L以下	---	---	---	---	0.04	---	---	---	---	---	---	---	1	0	0.04	0.04	0.04	2024/08/07
四塩化炭素	mg/L	0.002mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---	---	---	1	0	0.0002未満	0.0002未満	0.0002未満	---
1,4-ジオキサン	mg/L	0.05mg/L以下	---	---	---	---	0.003未満	---	---	---	---	---	---	---	1	0	0.003未満	0.003未満	0.003未満	---
シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン	mg/L	0.04mg/L以下	---	---	---	---	0.0004未満	---	---	---	---	---	---	---	1	0	0.0004未満	0.0004未満	0.0004未満	---
ジクロロメタン	mg/L	0.02mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---	---	---	1	0	0.0002未満	0.0002未満	0.0002未満	---
テトラクロロエチレン	mg/L	0.01mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---	---	---	1	0	0.0002未満	0.0002未満	0.0002未満	---
トリクロロエチレン	mg/L	0.01mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---	---	---	1	0	0.0002未満	0.0002未満	0.0002未満	---
ベンゼン	mg/L	0.01mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---	---	---	1	0	0.0002未満	0.0002未満	0.0002未満	---
塩素酸	mg/L	0.06mg/L以下	---	0.06未満	---	4	0	0.06未満	0.06未満	0.06未満	---									
クロロ酢酸	mg/L	0.02mg/L以下	---	0.002未満	---	4	0	0.002未満	0.002未満	0.002未満	---									
クロロホルム	mg/L	0.06mg/L以下	---	0.0002未満	---	4	0	0.0002未満	0.0002未満	0.0002未満	---									
ジクロロ酢酸	mg/L	0.03mg/L以下	---	0.002未満	---	4	0	0.002未満	0.002未満	0.002未満	---									
ジブロモクロメタン	mg/L	0.1mg/L以下	---	0.0002未満	---	4	0	0.0002未満	0.0002未満	0.0002未満	---									
臭素酸	mg/L	0.01mg/L以下	---	0.001未満	---	4	0	0.001未満	0.001未満	0.001未満	---									
総トリハロメタン	mg/L	0.1mg/L以下	---	0.01未満	---	4	0	0.01未満	0.01未満	0.01未満	---									
トリクロロ酢酸	mg/L	0.03mg/L以下	---	0.002未満	---	4	0	0.002未満	0.002未満	0.002未満	---									
ブロモジクロロメタン	mg/L	0.03mg/L以下	---	0.0002未満	---	4	0	0.0002未満	0.0002未満	0.0002未満	---									
ブロモホルム	mg/L	0.09mg/L以下	---	0.0002未満	---	4	0	0.0002未満	0.0002未満	0.0002未満	---									
ホルムアルデヒド	mg/L	0.08mg/L以下	---	0.004未満	---	4	0	0.004未満	0.004未満	0.004未満	---									
亜鉛及びその化合物	mg/L	1.0mg/L以下	---	---	---	---	0.004	---	---	---	---	---	---	---	1	0	0.004	0.004	0.004	2024/08/07
アルミニウム及びその化合物	mg/L	0.2mg/L以下	---	---	---	---	0.005未満	---	---	---	---	---	---	---	1	0	0.005未満	0.005未満	0.005未満	---
鉄及びその化合物	mg/L	0.3mg/L以下	---	---	---	---	0.02未満	---	---	---	---	---	---	---	1	0	0.02未満	0.02未満	0.02未満	---
銅及びその化合物	mg/L	1.0mg/L以下	---	---	---	---	0.025	---	---	---	---	---	---	---	1	0	0.025	0.025	0.025	2024/08/07
ナトリウム及びその化合物	mg/L	200mg/L以下	---	---	---	---	9.6	---	---	---	---	---	---	---	1	0	9.6	9.6	9.6	2024/08/07
マンガン及びその化合物	mg/L	0.05mg/L以下	---	---	---	---	0.001未満	---	---	---	---	---	---	---	1	0	0.001未満	0.001未満	0.001未満	---
塩化物イオン	mg/L	200mg/L以下	6.0	6.2	6.1	6.0	6.0	6.1	6.1	5.9	6.0	6.0	6.1	5.8	12	0	6.0	6.2	5.8	2024/05/08
カルシウム、マグネシウム等(硬度)	mg/L	300mg/L以下	---	58	---	---	55	---	---	56	---	---	59	---	4	0	57	59	55	2025/02/05
蒸発残留物	mg/L	500mg/L以下	---	110	---	---	120	---	---	120	---	---	130	---	4	0	120	130	110	2025/02/05
陰イオン界面活性剤	mg/L	0.2mg/L以下	---	---	---	---	0.02未満	---	---	---	---	---	---	---	1	0	0.02未満	0.02未満	0.02未満	---
ジェオスミン	mg/L	0.00001mg/L以下	---	---	---	---	0.000001未満	---	---	---	---	---	---	---	1	0	0.000001未満	0.000001未満	0.000001未満	---
2-メチルイソボルネオール	mg/L	0.00001mg/L以下	---	---	---	---	0.000001未満	---	---	---	---	---	---	---	1	0	0.000001未満	0.000001未満	0.000001未満	---
非イオン界面活性剤	mg/L	0.02mg/L以下	---	---	---	---	0.002未満	---	---	---	---	---	---	---	1	0	0.002未満	0.002未満	0.002未満	---
フェノール類	mg/L	0.005mg/L以下	---	---	---	---	0.0005未満	---	---	---	---	---	---	---	1	0	0.0005未満	0.0005未満	0.0005未満	---
有機物(全有機炭素(TOC)の量)	mg/L	3mg/L以下	0.2未満	12	0	0.2未満	0.2未満	0.2未満	---											
pH値	-	5.8以上8.6以下	6.8	6.9	6.9	6.8	6.8	6.8	6.8	6.8	6.8	6.8	6.8	6.8	12	0	6.8	6.9	6.8	2024/05/08
味	-	異常でないこと	異常なし	12	0	---	---	---	---											
臭気	-	異常でないこと	異常なし	12	0	---	---	---	---											
色度	度	5度以下	0.5未満	12	0	0.5未満	0.5未満	0.5未満	---											
濁度	度	2度以下	0.1未満	12	0	0.1未満	0.1未満	0.1未満	---											
上記項目についての水質基準適合判定			適合																	

項目	単位	基準値	2024/04/03	2024/05/08	2024/06/05	2024/07/03	2024/08/07	2024/09/04	2024/10/02	2024/11/06	2024/12/04	2025/01/08	2025/02/05	2025/03/05	測定回数	不適回数	平均値	最大値	最小値	最大値検出日
			24-SS-00040	24-SS-00428	24-SS-00909	24-SS-01445	24-SS-02067	24-SS-02567	24-SS-03029	24-SS-03436	24-SS-03884	24-SS-04273	24-SS-04706	24-SS-05073						
			SS 上水道																	
水温	℃	-	15.5	19.0	20.5	25.0	27.0	26.0	26.5	19.2	15.0	10.0	12.0	10.5	12	0	18.9	27.0	10.0	2024/08/07
気温	℃	-	12.9	24.5	22.8	30.7	31.9	28.0	29.7	20.1	15.5	7.1	6.9	11.2	12	0	20.1	31.9	6.9	2024/08/07
残留塩素濃度	mg/L	-	0.3	0.3	0.3	0.3	0.2	0.3	0.2	0.2	0.2	0.2	0.2	0.2	12	0	0.2	0.3	0.2	2024/04/03
一般細菌	CFU/mL	100CFU/mL以下	0	0	0	0	0	0	0	0	0	0	0	0	12	0	0	0	0	---
大腸菌	-	検出されないこと	検出しない	12	0	---	---	---	---											
カドミウム及びその化合物	mg/L	0.003mg/L以下	---	---	---	---	0.00015未満	---	---	---	---	---	---	---	1	0	0.00015未満	0.00015未満	0.00015未満	---
水銀及びその化合物	mg/L	0.0005mg/L以下	---	---	---	---	0.00005未満	---	---	---	---	---	---	---	1	0	0.00005未満	0.00005未満	0.00005未満	---
セレン及びその化合物	mg/L	0.01mg/L以下	---	---	---	---	0.0005未満	---	---	---	---	---	---	---	1	0	0.0005未満	0.0005未満	0.0005未満	---
鉛及びその化合物	mg/L	0.01mg/L以下	---	---	---	---	0.0011	---	---	---	---	---	---	---	1	0	0.0011	0.0011	0.0011	2024/08/07
ヒ素及びその化合物	mg/L	0.01mg/L以下	---	---	---	---	0.0005未満	---	---	---	---	---	---	---	1	0	0.0005未満	0.0005未満	0.0005未満	---
六価クロム化合物	mg/L	0.02mg/L以下	---	---	---	---	0.002未満	---	---	---	---	---	---	---	1	0	0.002未満	0.002未満	0.002未満	---
亜硝酸態窒素	mg/L	0.04mg/L以下	---	---	---	---	0.004未満	---	---	---	---	---	---	---	1	0	0.004未満	0.004未満	0.004未満	---
シアン化物イオン及び塩化シアン	mg/L	0.01mg/L以下	---	0.001未満	---	4	0	0.001未満	0.001未満	0.001未満	---									
硝酸態窒素及び亜硝酸態窒素	mg/L	10mg/L以下	---	---	---	---	1.0	---	---	---	---	---	---	---	1	0	1.0	1.0	1.0	2024/08/07
フッ素及びその化合物	mg/L	0.8mg/L以下	---	---	---	---	0.05未満	---	---	---	---	---	---	---	1	0	0.05未満	0.05未満	0.05未満	---
ホウ素及びその化合物	mg/L	1.0mg/L以下	---	---	---	---	0.04	---	---	---	---	---	---	---	1	0	0.04	0.04	0.04	2024/08/07
四塩化炭素	mg/L	0.002mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---	---	---	1	0	0.0002未満	0.0002未満	0.0002未満	---
1,4-ジオキサン	mg/L	0.05mg/L以下	---	---	---	---	0.003未満	---	---	---	---	---	---	---	1	0	0.003未満	0.003未満	0.003未満	---
シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン	mg/L	0.04mg/L以下	---	---	---	---	0.0004未満	---	---	---	---	---	---	---	1	0	0.0004未満	0.0004未満	0.0004未満	---
ジクロロメタン	mg/L	0.02mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---	---	---	1	0	0.0002未満	0.0002未満	0.0002未満	---
テトラクロロエチレン	mg/L	0.01mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---	---	---	1	0	0.0002未満	0.0002未満	0.0002未満	---
トリクロロエチレン	mg/L	0.01mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---	---	---	1	0	0.0002未満	0.0002未満	0.0002未満	---
ベンゼン	mg/L	0.01mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---	---	---	1	0	0.0002未満	0.0002未満	0.0002未満	---
塩素酸	mg/L	0.06mg/L以下	---	0.06未満	---	4	0	0.06未満	0.06未満	0.06未満	---									
クロロ酢酸	mg/L	0.02mg/L以下	---	0.002未満	---	4	0	0.002未満	0.002未満	0.002未満	---									
クロロホルム	mg/L	0.06mg/L以下	---	0.0002未満	---	4	0	0.0002未満	0.0002未満	0.0002未満	---									
ジクロロ酢酸	mg/L	0.03mg/L以下	---	0.002未満	---	4	0	0.002未満	0.002未満	0.002未満	---									
ジブロモクロメタン	mg/L	0.1mg/L以下	---	0.0002未満	---	4	0	0.0002未満	0.0002未満	0.0002未満	---									
臭素酸	mg/L	0.01mg/L以下	---	0.001未満	---	4	0	0.001未満	0.001未満	0.001未満	---									
総トリハロメタン	mg/L	0.1mg/L以下	---	0.01未満	---	4	0	0.01未満	0.01未満	0.01未満	---									
トリクロロ酢酸	mg/L	0.03mg/L以下	---	0.002未満	---	4	0	0.002未満	0.002未満	0.002未満	---									
ブロモジクロロメタン	mg/L	0.03mg/L以下	---	0.0002未満	---	4	0	0.0002未満	0.0002未満	0.0002未満	---									
ブロモホルム	mg/L	0.09mg/L以下	---	0.0002未満	---	4	0	0.0002未満	0.0002未満	0.0002未満	---									
ホルムアルデヒド	mg/L	0.08mg/L以下	---	0.004未満	---	4	0	0.004未満	0.004未満	0.004未満	---									
亜鉛及びその化合物	mg/L	1.0mg/L以下	---	---	---	---	0.004	---	---	---	---	---	---	---	1	0	0.004	0.004	0.004	2024/08/07
アルミニウム及びその化合物	mg/L	0.2mg/L以下	---	---	---	---	0.005未満	---	---	---	---	---	---	---	1	0	0.005未満	0.005未満	0.005未満	---
鉄及びその化合物	mg/L	0.3mg/L以下	---	---	---	---	0.02未満	---	---	---	---	---	---	---	1	0	0.02未満	0.02未満	0.02未満	---
銅及びその化合物	mg/L	1.0mg/L以下	---	---	---	---	0.028	---	---	---	---	---	---	---	1	0	0.028	0.028	0.028	2024/08/07
ナトリウム及びその化合物	mg/L	200mg/L以下	---	---	---	---	9.7	---	---	---	---	---	---	---	1	0	9.7	9.7	9.7	2024/08/07
マンガン及びその化合物	mg/L	0.05mg/L以下	---	---	---	---	0.001未満	---	---	---	---	---	---	---	1	0	0.001未満	0.001未満	0.001未満	---
塩化物イオン	mg/L	200mg/L以下	6.1	6.2	6.1	6.0	6.0	6.1	6.1	5.9	6.0	6.0	6.1	5.8	12	0	6.0	6.2	5.8	2024/05/08
カルシウム、マグネシウム等(硬度)	mg/L	300mg/L以下	---	55	---	---	56	---	---	56	---	---	57	---	4	0	56	57	55	2025/02/05
蒸発残留物	mg/L	500mg/L以下	---	120	---	---	120	---	---	120	---	---	130	---	4	0	123	130	120	2025/02/05
陰イオン界面活性剤	mg/L	0.2mg/L以下	---	---	---	---	0.02未満	---	---	---	---	---	---	---	1	0	0.02未満	0.02未満	0.02未満	---
ジェオスミン	mg/L	0.00001mg/L以下	---	---	---	---	0.000001未満	---	---	---	---	---	---	---	1	0	0.000001未満	0.000001未満	0.000001未満	---
2-メチルイソボルネオール	mg/L	0.00001mg/L以下	---	---	---	---	0.000001未満	---	---	---	---	---	---	---	1	0	0.000001未満	0.000001未満	0.000001未満	---
非イオン界面活性剤	mg/L	0.02mg/L以下	---	---	---	---	0.002未満	---	---	---	---	---	---	---	1	0	0.002未満	0.002未満	0.002未満	---
フェノール類	mg/L	0.005mg/L以下	---	---	---	---	0.0005未満	---	---	---	---	---	---	---	1	0	0.0005未満	0.0005未満	0.0005未満	---
有機物(全有機炭素(TOC)の量)	mg/L	3mg/L以下	0.2未満	12	0	0.2未満	0.2未満	0.2未満	---											
pH値	-	5.8以上8.6以下	6.8	6.8	6.9	6.8	6.8	6.8	6.8	6.8	6.8	6.8	6.8	6.8	12	0	6.8	6.9	6.8	2024/06/05
味	-	異常でないこと	異常なし	12	0	---	---	---	---											
臭気	-	異常でないこと	異常なし	12	0	---	---	---	---											
色度	度	5度以下	0.5未満	12	0	0.5未満	0.5未満	0.5未満	---											
濁度	度	2度以下	0.1未満	12	0	0.1未満	0.1未満	0.1未満	---											
上記項目についての水質基準適合判定			適合																	

施設名：焼津市上水（大島下ちびっこ広場） 採水場所：焼津市大島1206-1 大島下ちびっこ広場

項目	単位	基準値	2024/04/03	2024/05/08	2024/06/05	2024/07/03	2024/08/07	2024/09/04	2024/10/02	2024/11/06	2024/12/04	2025/01/08	2025/02/05	2025/03/05	測定回数	不適回数	平均値	最大値	最小値	最大値検出日
			24-SS-00037	24-SS-00425	24-SS-00906	24-SS-01442	24-SS-02060	24-SS-02564	24-SS-03026	24-SS-03433	24-SS-03881	24-SS-04270	24-SS-04703	24-SS-05070						
			SS 上水道																	
水温	℃	-	16.0	18.0	19.5	21.0	22.5	22.5	21.5	19.0	18.0	14.5	6.0	13.5	12	0	17.7	22.5	6.0	2024/08/07
気温	℃	-	14.1	23.0	23.0	29.0	34.5	28.2	28.5	20.1	15.7	5.3	4.0	10.7	12	0	19.7	34.5	4.0	2024/08/07
残留塩素濃度	mg/L	-	0.3	0.3	0.3	0.3	0.3	0.3	0.2	0.2	0.2	0.2	0.2	0.2	12	0	0.3	0.3	0.2	2024/04/03
一般細菌	CFU/mL	100CFU/mL以下	0	0	0	0	0	0	0	0	0	0	0	0	12	0	0	0	0	---
大腸菌	-	検出されないこと	検出しない	12	0	---	---	---	---											
カドミウム及びその化合物	mg/L	0.003mg/L以下	---	---	---	---	---	0.00015未満	---	---	---	---	---	---	1	0	0.00015未満	0.00015未満	0.00015未満	---
水銀及びその化合物	mg/L	0.0005mg/L以下	---	---	---	---	---	0.00005未満	---	---	---	---	---	---	1	0	0.00005未満	0.00005未満	0.00005未満	---
セレン及びその化合物	mg/L	0.01mg/L以下	---	---	---	---	---	0.0005未満	---	---	---	---	---	---	1	0	0.0005未満	0.0005未満	0.0005未満	---
鉛及びその化合物	mg/L	0.01mg/L以下	---	---	---	---	---	0.0005未満	---	---	---	---	---	---	1	0	0.0005未満	0.0005未満	0.0005未満	---
ヒ素及びその化合物	mg/L	0.01mg/L以下	---	---	---	---	---	0.0005未満	---	---	---	---	---	---	1	0	0.0005未満	0.0005未満	0.0005未満	---
六価クロム化合物	mg/L	0.02mg/L以下	---	---	---	---	---	0.002未満	---	---	---	---	---	---	1	0	0.002未満	0.002未満	0.002未満	---
亜硝酸態窒素	mg/L	0.04mg/L以下	---	---	---	---	---	0.004未満	---	---	---	---	---	---	1	0	0.004未満	0.004未満	0.004未満	---
シアン化物イオン及び塩化シアン	mg/L	0.01mg/L以下	---	0.001未満	---	---	---	0.001未満	---	0.001未満	---	---	0.001未満	---	4	0	0.001未満	0.001未満	0.001未満	---
硝酸態窒素及び亜硝酸態窒素	mg/L	10mg/L以下	---	---	---	---	1.0	---	---	---	---	---	---	---	1	0	1.0	1.0	1.0	2024/08/07
フッ素及びその化合物	mg/L	0.8mg/L以下	---	---	---	---	0.06	---	---	---	---	---	---	---	1	0	0.06	0.06	0.06	2024/08/07
ホウ素及びその化合物	mg/L	1.0mg/L以下	---	---	---	---	0.04	---	---	---	---	---	---	---	1	0	0.04	0.04	0.04	2024/08/07
四塩化炭素	mg/L	0.002mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---	---	---	1	0	0.0002未満	0.0002未満	0.0002未満	---
1,4-ジオキサン	mg/L	0.05mg/L以下	---	---	---	---	0.003未満	---	---	---	---	---	---	---	1	0	0.003未満	0.003未満	0.003未満	---
シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン	mg/L	0.04mg/L以下	---	---	---	---	0.0004未満	---	---	---	---	---	---	---	1	0	0.0004未満	0.0004未満	0.0004未満	---
ジクロロメタン	mg/L	0.02mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---	---	---	1	0	0.0002未満	0.0002未満	0.0002未満	---
テトラクロロエチレン	mg/L	0.01mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---	---	---	1	0	0.0002未満	0.0002未満	0.0002未満	---
トリクロロエチレン	mg/L	0.01mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---	---	---	1	0	0.0002未満	0.0002未満	0.0002未満	---
ベンゼン	mg/L	0.01mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---	---	---	1	0	0.0002未満	0.0002未満	0.0002未満	---
塩素酸	mg/L	0.06mg/L以下	---	0.06未満	---	4	0	0.06未満	0.06未満	0.06未満	---									
クロロ酢酸	mg/L	0.02mg/L以下	---	0.002未満	---	4	0	0.002未満	0.002未満	0.002未満	---									
クロロホルム	mg/L	0.06mg/L以下	---	0.0002未満	---	4	0	0.0002未満	0.0002未満	0.0002未満	---									
ジクロロ酢酸	mg/L	0.03mg/L以下	---	0.002未満	---	4	0	0.002未満	0.002未満	0.002未満	---									
ジブロモクロメタン	mg/L	0.1mg/L以下	---	0.0002未満	---	4	0	0.0002未満	0.0002未満	0.0002未満	---									
臭素酸	mg/L	0.01mg/L以下	---	0.001未満	---	4	0	0.001未満	0.001未満	0.001未満	---									
総トリハロメタン	mg/L	0.1mg/L以下	---	0.01未満	---	4	0	0.01未満	0.01未満	0.01未満	---									
トリクロロ酢酸	mg/L	0.03mg/L以下	---	0.002未満	---	4	0	0.002未満	0.002未満	0.002未満	---									
ブロモジクロロメタン	mg/L	0.03mg/L以下	---	0.0002未満	---	4	0	0.0002未満	0.0002未満	0.0002未満	---									
ブロモホルム	mg/L	0.09mg/L以下	---	0.0002未満	---	4	0	0.0002未満	0.0002未満	0.0002未満	---									
ホルムアルデヒド	mg/L	0.08mg/L以下	---	0.004未満	---	4	0	0.004未満	0.004未満	0.004未満	---									
亜鉛及びその化合物	mg/L	1.0mg/L以下	---	---	---	---	0.003	---	---	---	---	---	---	---	1	0	0.003	0.003	0.003	2024/08/07
アルミニウム及びその化合物	mg/L	0.2mg/L以下	---	---	---	---	0.007	---	---	---	---	---	---	---	1	0	0.007	0.007	0.007	2024/08/07
鉄及びその化合物	mg/L	0.3mg/L以下	---	---	---	---	0.02未満	---	---	---	---	---	---	---	1	0	0.02未満	0.02未満	0.02未満	---
銅及びその化合物	mg/L	1.0mg/L以下	---	---	---	---	0.006	---	---	---	---	---	---	---	1	0	0.006	0.006	0.006	2024/08/07
ナトリウム及びその化合物	mg/L	200mg/L以下	---	---	---	---	9.6	---	---	---	---	---	---	---	1	0	9.6	9.6	9.6	2024/08/07
マンガン及びその化合物	mg/L	0.05mg/L以下	---	---	---	---	0.001未満	---	---	---	---	---	---	---	1	0	0.001未満	0.001未満	0.001未満	---
塩化物イオン	mg/L	200mg/L以下	5.6	5.7	5.6	5.4	5.4	5.5	5.4	5.3	5.4	5.4	5.5	5.2	12	0	5.5	5.7	5.2	2024/05/08
カルシウム、マグネシウム等(硬度)	mg/L	300mg/L以下	---	68	---	---	68	---	---	68	---	---	73	---	4	0	69	73	68	2025/02/05
蒸発残留物	mg/L	500mg/L以下	---	130	---	---	140	---	---	130	---	---	130	---	4	0	133	140	130	2024/08/07
陰イオン界面活性剤	mg/L	0.2mg/L以下	---	---	---	---	0.02未満	---	---	---	---	---	---	---	1	0	0.02未満	0.02未満	0.02未満	---
ジェオスミン	mg/L	0.00001mg/L以下	---	---	---	---	0.000001未満	---	---	---	---	---	---	---	1	0	0.000001未満	0.000001未満	0.000001未満	---
2-メチルイソボルネオール	mg/L	0.00001mg/L以下	---	---	---	---	0.000001未満	---	---	---	---	---	---	---	1	0	0.000001未満	0.000001未満	0.000001未満	---
非イオン界面活性剤	mg/L	0.02mg/L以下	---	---	---	---	0.002未満	---	---	---	---	---	---	---	1	0	0.002未満	0.002未満	0.002未満	---
フェノール類	mg/L	0.005mg/L以下	---	---	---	---	0.0005未満	---	---	---	---	---	---	---	1	0	0.0005未満	0.0005未満	0.0005未満	---
有機物(全有機炭素(TOC)の量)	mg/L	3mg/L以下	0.2未満	12	0	0.2未満	0.2未満	0.2未満	---											
pH値	-	5.8以上8.6以下	7.5	7.4	7.6	6.9	7.5	7.5	6.9	7.5	7.5	7.5	7.5	7.5	12	0	7.4	7.6	6.9	2024/06/05
味	-	異常でないこと	異常なし	12	0	---	---	---	---											
臭気	-	異常でないこと	異常なし	12	0	---	---	---	---											
色度	度	5度以下	0.5未満	12	0	0.5未満	0.5未満	0.5未満	---											
濁度	度	2度以下	0.1未満	12	0	0.1未満	0.1未満	0.1未満	---											
上記項目についての水質基準適合判定			適合																	

項目	単位	基準値	2024/04/03	2024/05/08	2024/06/05	2024/07/03	2024/08/07	2024/09/04	2024/10/02	2024/11/06	2024/12/04	2025/01/08	2025/02/05	2025/03/05	測定回数	不適回数	平均値	最大値	最小値	最大値検出日
			24-SS-00043	24-SS-00431	24-SS-00912	24-SS-01448	24-SS-02070	24-SS-02570	24-SS-03032	24-SS-03439	24-SS-03887	24-SS-04276	24-SS-04709	24-SS-05076						
			SS 上水道																	
水温	℃	-	15.5	20.0	21.5	25.5	27.0	27.0	26.0	20.0	17.0	10.5	9.0	10.5	12	0	19.1	27.0	9.0	2024/08/07
気温	℃	-	15.3	26.3	25.0	32.6	35.0	30.5	32.2	21.5	18.0	7.5	7.5	12.5	12	0	22.0	35.0	7.5	2024/08/07
残留塩素濃度	mg/L	-	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.2	0.2	0.2	0.2	0.2	12	0	0.3	0.3	0.2	2024/04/03
一般細菌	CFU/mL	100CFU/mL以下	0	0	0	0	0	0	0	0	0	0	1	0	12	0	0	1	0	2025/02/05
大腸菌	-	検出されないこと	検出しない	12	0	---	---	---	---											
カドミウム及びその化合物	mg/L	0.003mg/L以下	---	---	---	---	0.00015未満	---	---	---	---	---	---	---	1	0	0.00015未満	0.00015未満	0.00015未満	---
水銀及びその化合物	mg/L	0.0005mg/L以下	---	---	---	---	0.00005未満	---	---	---	---	---	---	---	1	0	0.00005未満	0.00005未満	0.00005未満	---
セレン及びその化合物	mg/L	0.01mg/L以下	---	---	---	---	0.0005未満	---	---	---	---	---	---	---	1	0	0.0005未満	0.0005未満	0.0005未満	---
鉛及びその化合物	mg/L	0.01mg/L以下	---	---	---	---	0.0005未満	---	---	---	---	---	---	---	1	0	0.0005未満	0.0005未満	0.0005未満	---
ヒ素及びその化合物	mg/L	0.01mg/L以下	---	---	---	---	0.0005未満	---	---	---	---	---	---	---	1	0	0.0005未満	0.0005未満	0.0005未満	---
六価クロム化合物	mg/L	0.02mg/L以下	---	---	---	---	0.002未満	---	---	---	---	---	---	---	1	0	0.002未満	0.002未満	0.002未満	---
亜硝酸態窒素	mg/L	0.04mg/L以下	---	---	---	---	0.004未満	---	---	---	---	---	---	---	1	0	0.004未満	0.004未満	0.004未満	---
シアン化物イオン及び塩化シアン	mg/L	0.01mg/L以下	---	0.001未満	---	4	0	0.001未満	0.001未満	0.001未満	---									
硝酸態窒素及び亜硝酸態窒素	mg/L	10mg/L以下	---	---	---	---	0.8	---	---	---	---	---	---	---	1	0	0.8	0.8	0.8	2024/08/07
フッ素及びその化合物	mg/L	0.8mg/L以下	---	---	---	---	0.05	---	---	---	---	---	---	---	1	0	0.05	0.05	0.05	2024/08/07
ホウ素及びその化合物	mg/L	1.0mg/L以下	---	---	---	---	0.03	---	---	---	---	---	---	---	1	0	0.03	0.03	0.03	2024/08/07
四塩化炭素	mg/L	0.002mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---	---	---	1	0	0.0002未満	0.0002未満	0.0002未満	---
1,4-ジオキサン	mg/L	0.05mg/L以下	---	---	---	---	0.003未満	---	---	---	---	---	---	---	1	0	0.003未満	0.003未満	0.003未満	---
シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン	mg/L	0.04mg/L以下	---	---	---	---	0.0004未満	---	---	---	---	---	---	---	1	0	0.0004未満	0.0004未満	0.0004未満	---
ジクロロメタン	mg/L	0.02mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---	---	---	1	0	0.0002未満	0.0002未満	0.0002未満	---
テトラクロロエチレン	mg/L	0.01mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---	---	---	1	0	0.0002未満	0.0002未満	0.0002未満	---
トリクロロエチレン	mg/L	0.01mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---	---	---	1	0	0.0002未満	0.0002未満	0.0002未満	---
ベンゼン	mg/L	0.01mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---	---	---	1	0	0.0002未満	0.0002未満	0.0002未満	---
塩素酸	mg/L	0.06mg/L以下	---	0.06未満	---	4	0	0.06未満	0.06未満	0.06未満	---									
クロロ酢酸	mg/L	0.02mg/L以下	---	0.002未満	---	4	0	0.002未満	0.002未満	0.002未満	---									
クロロホルム	mg/L	0.06mg/L以下	---	0.0004	---	---	0.0018	---	---	0.0005	---	---	0.0005	---	4	0	0.0008	0.0018	0.0004	2024/08/07
ジクロロ酢酸	mg/L	0.03mg/L以下	---	0.002未満	---	4	0	0.002未満	0.002未満	0.002未満	---									
ジブromクロロメタン	mg/L	0.1mg/L以下	---	0.0002	---	---	0.0003	---	---	0.0002	---	---	0.0002未満	---	4	0	0.0002	0.0003	0.0002未満	2024/08/07
臭素酸	mg/L	0.01mg/L以下	---	0.001未満	---	4	0	0.001未満	0.001未満	0.001未満	---									
総トリハロメタン	mg/L	0.1mg/L以下	---	0.01未満	---	4	0	0.01未満	0.01未満	0.01未満	---									
トリクロロ酢酸	mg/L	0.03mg/L以下	---	0.002未満	---	4	0	0.002未満	0.002未満	0.002未満	---									
ブromジクロロメタン	mg/L	0.03mg/L以下	---	0.0002未満	---	---	0.0004	---	---	0.0002	---	---	0.0002未満	---	4	0	0.0003	0.0004	0.0002未満	2024/08/07
ブromホルム	mg/L	0.09mg/L以下	---	0.0002未満	---	4	0	0.0002未満	0.0002未満	0.0002未満	---									
ホルムアルデヒド	mg/L	0.08mg/L以下	---	0.004未満	---	4	0	0.004未満	0.004未満	0.004未満	---									
亜鉛及びその化合物	mg/L	1.0mg/L以下	---	---	---	---	0.003	---	---	---	---	---	---	---	1	0	0.003	0.003	0.003	2024/08/07
アルミニウム及びその化合物	mg/L	0.2mg/L以下	---	---	---	---	0.016	---	---	---	---	---	---	---	1	0	0.016	0.016	0.016	2024/08/07
鉄及びその化合物	mg/L	0.3mg/L以下	---	---	---	---	0.02未満	---	---	---	---	---	---	---	1	0	0.02未満	0.02未満	0.02未満	---
銅及びその化合物	mg/L	1.0mg/L以下	---	---	---	---	0.010	---	---	---	---	---	---	---	1	0	0.010	0.010	0.010	2024/08/07
ナトリウム及びその化合物	mg/L	200mg/L以下	---	---	---	---	8.2	---	---	---	---	---	---	---	1	0	8.2	8.2	8.2	2024/08/07
マンガン及びその化合物	mg/L	0.05mg/L以下	---	---	---	---	0.001未満	---	---	---	---	---	---	---	1	0	0.001未満	0.001未満	0.001未満	---
塩化物イオン	mg/L	200mg/L以下	5.6	5.5	5.6	5.3	5.3	5.4	5.3	5.3	5.3	5.3	4.9	5.1	12	0	5.3	5.6	4.9	2024/04/03
カルシウム、マグネシウム等(硬度)	mg/L	300mg/L以下	---	64	---	---	61	---	---	64	---	---	66	---	4	0	64	66	61	2025/02/05
蒸発残留物	mg/L	500mg/L以下	---	120	---	---	120	---	---	120	---	---	120	---	4	0	120	120	120	---
陰イオン界面活性剤	mg/L	0.2mg/L以下	---	---	---	---	0.02未満	---	---	---	---	---	---	---	1	0	0.02未満	0.02未満	0.02未満	---
ジェオスミン	mg/L	0.00001mg/L以下	---	---	---	---	0.000001未満	---	---	---	---	---	---	---	1	0	0.000001未満	0.000001未満	0.000001未満	---
2-メチルイソボルネオール	mg/L	0.00001mg/L以下	---	---	---	---	0.000001未満	---	---	---	---	---	---	---	1	0	0.000001未満	0.000001未満	0.000001未満	---
非イオン界面活性剤	mg/L	0.02mg/L以下	---	---	---	---	0.002未満	---	---	---	---	---	---	---	1	0	0.002未満	0.002未満	0.002未満	---
フェノール類	mg/L	0.005mg/L以下	---	---	---	---	0.0005未満	---	---	---	---	---	---	---	1	0	0.0005未満	0.0005未満	0.0005未満	---
有機物(全有機炭素(TOC)の量)	mg/L	3mg/L以下	0.2未満	12	0	0.2未満	0.2未満	0.2未満	---											
pH値	-	5.8以上8.6以下	7.5	7.6	7.6	7.1	7.6	7.6	7.0	7.6	7.6	7.5	7.5	7.5	12	0	7.5	7.6	7.0	2024/05/08
味	-	異常でないこと	異常なし	12	0	---	---	---	---											
臭気	-	異常でないこと	異常なし	12	0	---	---	---	---											
色度	度	5度以下	0.5未満	12	0	0.5未満	0.5未満	0.5未満	---											
濁度	度	2度以下	0.1未満	12	0	0.1未満	0.1未満	0.1未満	---											
上記項目についての水質基準適合判定			適合																	

施設名：焼津市上水（坂本加圧ポンプ所） 採水場所：焼津市坂本4 1 3 - 2 坂本加圧ポンプ所

項目	単位	基準値	2024/04/03	2024/05/08	2024/06/05	2024/07/03	2024/08/07	2024/09/04	2024/10/02	2024/11/06	2024/12/04	2025/01/08	2025/02/05	2025/03/05	測定回数	不適回数	平均値	最大値	最小値	最大値検出日
			24-SS-00042	24-SS-00430	24-SS-00911	24-SS-01447	24-SS-02069	24-SS-02569	24-SS-03031	24-SS-03438	24-SS-03886	24-SS-04275	24-SS-04708	24-SS-05075						
			SS 上水道																	
水温	℃	-	16.0	18.5	19.5	21.0	27.0	22.5	22.0	19.5	18.0	14.5	14.0	15.0	12	0	19.0	27.0	14.0	2024/08/07
気温	℃	-	15.4	26.5	24.8	31.8	34.5	29.4	29.7	20.8	16.4	6.0	6.9	12.5	12	0	21.2	34.5	6.0	2024/08/07
残留塩素濃度	mg/L	-	0.3	0.3	0.3	0.3	0.2	0.3	0.2	0.2	0.2	0.2	0.2	0.2	12	0	0.2	0.3	0.2	2024/04/03
一般細菌	CFU/mL	100CFU/mL以下	0	0	0	0	0	0	0	0	0	0	0	0	12	0	0	0	0	---
大腸菌	-	検出されないこと	検出しない	12	0	---	---	---	---											
カドミウム及びその化合物	mg/L	0.003mg/L以下	---	---	---	---	0.00015未満	---	---	---	---	---	---	---	1	0	0.00015未満	0.00015未満	0.00015未満	---
水銀及びその化合物	mg/L	0.0005mg/L以下	---	---	---	---	0.00005未満	---	---	---	---	---	---	---	1	0	0.00005未満	0.00005未満	0.00005未満	---
セレン及びその化合物	mg/L	0.01mg/L以下	---	---	---	---	0.0005未満	---	---	---	---	---	---	---	1	0	0.0005未満	0.0005未満	0.0005未満	---
鉛及びその化合物	mg/L	0.01mg/L以下	---	---	---	---	0.0005未満	---	---	---	---	---	---	---	1	0	0.0005未満	0.0005未満	0.0005未満	---
ヒ素及びその化合物	mg/L	0.01mg/L以下	---	---	---	---	0.0005未満	---	---	---	---	---	---	---	1	0	0.0005未満	0.0005未満	0.0005未満	---
六価クロム化合物	mg/L	0.02mg/L以下	---	---	---	---	0.002未満	---	---	---	---	---	---	---	1	0	0.002未満	0.002未満	0.002未満	---
亜硝酸態窒素	mg/L	0.04mg/L以下	---	---	---	---	0.004未満	---	---	---	---	---	---	---	1	0	0.004未満	0.004未満	0.004未満	---
シアン化物イオン及び塩化シアン	mg/L	0.01mg/L以下	---	0.001未満	---	4	0	0.001未満	0.001未満	0.001未満	---									
硝酸態窒素及び亜硝酸態窒素	mg/L	10mg/L以下	---	---	---	---	0.9	---	---	---	---	---	---	---	1	0	0.9	0.9	0.9	2024/08/07
フッ素及びその化合物	mg/L	0.8mg/L以下	---	---	---	---	0.05	---	---	---	---	---	---	---	1	0	0.05	0.05	0.05	2024/08/07
ホウ素及びその化合物	mg/L	1.0mg/L以下	---	---	---	---	0.04	---	---	---	---	---	---	---	1	0	0.04	0.04	0.04	2024/08/07
四塩化炭素	mg/L	0.002mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---	---	---	1	0	0.0002未満	0.0002未満	0.0002未満	---
1,4-ジオキサン	mg/L	0.05mg/L以下	---	---	---	---	0.003未満	---	---	---	---	---	---	---	1	0	0.003未満	0.003未満	0.003未満	---
シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン	mg/L	0.04mg/L以下	---	---	---	---	0.0004未満	---	---	---	---	---	---	---	1	0	0.0004未満	0.0004未満	0.0004未満	---
ジクロロメタン	mg/L	0.02mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---	---	---	1	0	0.0002未満	0.0002未満	0.0002未満	---
テトラクロロエチレン	mg/L	0.01mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---	---	---	1	0	0.0002未満	0.0002未満	0.0002未満	---
トリクロロエチレン	mg/L	0.01mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---	---	---	1	0	0.0002未満	0.0002未満	0.0002未満	---
ベンゼン	mg/L	0.01mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---	---	---	1	0	0.0002未満	0.0002未満	0.0002未満	---
塩素酸	mg/L	0.06mg/L以下	---	0.06未満	---	4	0	0.06未満	0.06未満	0.06未満	---									
クロロ酢酸	mg/L	0.02mg/L以下	---	0.002未満	---	4	0	0.002未満	0.002未満	0.002未満	---									
クロロホルム	mg/L	0.06mg/L以下	---	0.0003	---	---	0.0012	---	---	0.0003	---	---	0.0002	---	4	0	0.0005	0.0012	0.0002	2024/08/07
ジクロロ酢酸	mg/L	0.03mg/L以下	---	0.002未満	---	4	0	0.002未満	0.002未満	0.002未満	---									
ジブromクロロメタン	mg/L	0.1mg/L以下	---	0.0002未満	---	---	0.0002未満	---	---	0.0002	---	---	0.0002未満	---	4	0	0.0002	0.0002	0.0002未満	2024/11/06
臭素酸	mg/L	0.01mg/L以下	---	0.001未満	---	4	0	0.001未満	0.001未満	0.001未満	---									
総トリハロメタン	mg/L	0.1mg/L以下	---	0.01未満	---	4	0	0.01未満	0.01未満	0.01未満	---									
トリクロロ酢酸	mg/L	0.03mg/L以下	---	0.002未満	---	4	0	0.002未満	0.002未満	0.002未満	---									
ブromジクロロメタン	mg/L	0.03mg/L以下	---	0.0002未満	---	---	0.0002	---	---	0.0002未満	---	---	0.0002未満	---	4	0	0.0002	0.0002	0.0002未満	2024/08/07
ブromホルム	mg/L	0.09mg/L以下	---	0.0002未満	---	4	0	0.0002未満	0.0002未満	0.0002未満	---									
ホルムアルデヒド	mg/L	0.08mg/L以下	---	0.004未満	---	4	0	0.004未満	0.004未満	0.004未満	---									
亜鉛及びその化合物	mg/L	1.0mg/L以下	---	0.003	---	---	0.003	---	---	---	---	---	---	---	1	0	0.003	0.003	0.003	2024/08/07
アルミニウム及びその化合物	mg/L	0.2mg/L以下	---	---	---	---	0.010	---	---	---	---	---	---	---	1	0	0.010	0.010	0.010	2024/08/07
鉄及びその化合物	mg/L	0.3mg/L以下	---	---	---	---	0.02未満	---	---	---	---	---	---	---	1	0	0.02未満	0.02未満	0.02未満	---
銅及びその化合物	mg/L	1.0mg/L以下	---	---	---	---	0.006	---	---	---	---	---	---	---	1	0	0.006	0.006	0.006	2024/08/07
ナトリウム及びその化合物	mg/L	200mg/L以下	---	---	---	---	8.9	---	---	---	---	---	---	---	1	0	8.9	8.9	8.9	2024/08/07
マンガン及びその化合物	mg/L	0.05mg/L以下	---	---	---	---	0.001未満	---	---	---	---	---	---	---	1	0	0.001未満	0.001未満	0.001未満	---
塩化物イオン	mg/L	200mg/L以下	5.8	5.7	5.8	5.5	5.6	5.7	5.7	5.6	5.6	5.6	5.5	5.4	12	0	5.6	5.8	5.4	2024/04/03
カルシウム、マグネシウム等(硬度)	mg/L	300mg/L以下	---	63	---	---	60	---	---	60	---	---	67	---	4	0	63	67	60	2025/02/05
蒸発残留物	mg/L	500mg/L以下	---	120	---	---	120	---	---	130	---	---	130	---	4	0	125	130	120	2024/11/06
陰イオン界面活性剤	mg/L	0.2mg/L以下	---	---	---	---	0.02未満	---	---	---	---	---	---	---	1	0	0.02未満	0.02未満	0.02未満	---
ジェオスミン	mg/L	0.00001mg/L以下	---	---	---	---	0.000001未満	---	---	---	---	---	---	---	1	0	0.000001未満	0.000001未満	0.000001未満	---
2-メチルイソボルネオール	mg/L	0.00001mg/L以下	---	---	---	---	0.000001未満	---	---	---	---	---	---	---	1	0	0.000001未満	0.000001未満	0.000001未満	---
非イオン界面活性剤	mg/L	0.02mg/L以下	---	---	---	---	0.002未満	---	---	---	---	---	---	---	1	0	0.002未満	0.002未満	0.002未満	---
フェノール類	mg/L	0.005mg/L以下	---	---	---	---	0.0005未満	---	---	---	---	---	---	---	1	0	0.0005未満	0.0005未満	0.0005未満	---
有機物(全有機炭素(TOC)の量)	mg/L	3mg/L以下	0.2未満	12	0	0.2未満	0.2未満	0.2未満	---											
pH値	-	5.8以上8.6以下	7.0	7.1	7.1	7.0	7.1	7.2	6.9	7.1	7.1	7.0	7.2	7.0	12	0	7.1	7.2	6.9	2024/09/04
味	-	異常でないこと	異常なし	12	0	---	---	---	---											
臭気	-	異常でないこと	異常なし	12	0	---	---	---	---											
色度	度	5度以下	0.5未満	12	0	0.5未満	0.5未満	0.5未満	---											
濁度	度	2度以下	0.1未満	12	0	0.1未満	0.1未満	0.1未満	---											
上記項目についての水質基準適合判定			適合																	

項目	単位	基準値	2024/04/03	2024/05/08	2024/06/05	2024/07/03	2024/08/07	2024/09/04	2024/10/02	2024/11/06	2024/12/04	2025/01/08	2025/02/05	2025/03/05	測定回数	不適回数	平均値	最大値	最小値	最大値検出日
			24-SS-00036	24-SS-00424	24-SS-00905	24-SS-01441	24-SS-02059	24-SS-02563	24-SS-03025	24-SS-03432	24-SS-03880	24-SS-04269	24-SS-04702	24-SS-05069						
			SS 上水道																	
水温	℃	-	15.0	19.0	21.5	23.5	25.7	25.0	23.5	20.0	16.0	13.0	8.0	12.0	12	0	18.5	25.7	8.0	2024/08/07
気温	℃	-	14.2	21.8	27.4	28.5	34.8	31.0	27.7	21.6	16.8	5.0	2.8	11.4	12	0	20.3	34.8	2.8	2024/08/07
残留塩素濃度	mg/L	-	0.3	0.3	0.3	0.3	0.3	0.3	0.2	0.2	0.2	0.2	0.2	0.2	12	0	0.3	0.3	0.2	2024/04/03
一般細菌	CFU/mL	100CFU/mL以下	0	0	0	0	0	0	0	0	0	0	0	0	12	0	0	0	0	---
大腸菌	-	検出されないこと	検出しない	12	0	---	---	---	---											
カドミウム及びその化合物	mg/L	0.003mg/L以下	---	---	---	---	---	0.00015未満	---	---	---	---	---	---	1	0	0.00015未満	0.00015未満	0.00015未満	---
水銀及びその化合物	mg/L	0.0005mg/L以下	---	---	---	---	---	0.00005未満	---	---	---	---	---	---	1	0	0.00005未満	0.00005未満	0.00005未満	---
セレン及びその化合物	mg/L	0.01mg/L以下	---	---	---	---	---	0.0005未満	---	---	---	---	---	---	1	0	0.0005未満	0.0005未満	0.0005未満	---
鉛及びその化合物	mg/L	0.01mg/L以下	---	---	---	---	---	0.0010	---	---	---	---	---	---	1	0	0.0010	0.0010	0.0010	2024/08/07
ヒ素及びその化合物	mg/L	0.01mg/L以下	---	---	---	---	---	0.0005未満	---	---	---	---	---	---	1	0	0.0005未満	0.0005未満	0.0005未満	---
六価クロム化合物	mg/L	0.02mg/L以下	---	---	---	---	---	0.002未満	---	---	---	---	---	---	1	0	0.002未満	0.002未満	0.002未満	---
亜硝酸態窒素	mg/L	0.04mg/L以下	---	---	---	---	---	0.004未満	---	---	---	---	---	---	1	0	0.004未満	0.004未満	0.004未満	---
シアン化物イオン及び塩化シアン	mg/L	0.01mg/L以下	---	0.001未満	---	---	---	0.001未満	---	0.001未満	---	---	0.001未満	---	4	0	0.001未満	0.001未満	0.001未満	---
硝酸態窒素及び亜硝酸態窒素	mg/L	10mg/L以下	---	---	---	---	0.3	---	---	---	---	---	---	---	1	0	0.3	0.3	0.3	2024/08/07
フッ素及びその化合物	mg/L	0.8mg/L以下	---	---	---	---	0.05未満	---	---	---	---	---	---	---	1	0	0.05未満	0.05未満	0.05未満	---
ホウ素及びその化合物	mg/L	1.0mg/L以下	---	---	---	---	0.03	---	---	---	---	---	---	---	1	0	0.03	0.03	0.03	2024/08/07
四塩化炭素	mg/L	0.002mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---	---	---	1	0	0.0002未満	0.0002未満	0.0002未満	---
1,4-ジオキサン	mg/L	0.05mg/L以下	---	---	---	---	0.003未満	---	---	---	---	---	---	---	1	0	0.003未満	0.003未満	0.003未満	---
シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン	mg/L	0.04mg/L以下	---	---	---	---	0.0004未満	---	---	---	---	---	---	---	1	0	0.0004未満	0.0004未満	0.0004未満	---
ジクロロメタン	mg/L	0.02mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---	---	---	1	0	0.0002未満	0.0002未満	0.0002未満	---
テトラクロロエチレン	mg/L	0.01mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---	---	---	1	0	0.0002未満	0.0002未満	0.0002未満	---
トリクロロエチレン	mg/L	0.01mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---	---	---	1	0	0.0002未満	0.0002未満	0.0002未満	---
ベンゼン	mg/L	0.01mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---	---	---	1	0	0.0002未満	0.0002未満	0.0002未満	---
塩素酸	mg/L	0.06mg/L以下	---	0.06未満	---	4	0	0.06未満	0.06未満	0.06未満	---									
クロロ酢酸	mg/L	0.02mg/L以下	---	0.002未満	---	4	0	0.002未満	0.002未満	0.002未満	---									
クロロホルム	mg/L	0.06mg/L以下	---	0.0008	---	---	0.0012	---	---	0.0009	---	---	0.0003	---	4	0	0.0008	0.0012	0.0003	2024/08/07
ジクロロ酢酸	mg/L	0.03mg/L以下	---	0.002未満	---	4	0	0.002未満	0.002未満	0.002未満	---									
ジブromクロロメタン	mg/L	0.1mg/L以下	---	0.0002未満	---	---	0.0002未満	---	---	0.0003	---	---	0.0002未満	---	4	0	0.0002	0.0003	0.0002未満	2024/11/06
臭素酸	mg/L	0.01mg/L以下	---	0.001未満	---	4	0	0.001未満	0.001未満	0.001未満	---									
総トリハロメタン	mg/L	0.1mg/L以下	---	0.01未満	---	4	0	0.01未満	0.01未満	0.01未満	---									
トリクロロ酢酸	mg/L	0.03mg/L以下	---	0.002未満	---	4	0	0.002未満	0.002未満	0.002未満	---									
ブromジクロロメタン	mg/L	0.03mg/L以下	---	0.0002	---	---	0.0002	---	---	0.0003	---	---	0.0002未満	---	4	0	0.0002	0.0003	0.0002未満	2024/11/06
ブromホルム	mg/L	0.09mg/L以下	---	0.0002未満	---	4	0	0.0002未満	0.0002未満	0.0002未満	---									
ホルムアルデヒド	mg/L	0.08mg/L以下	---	0.004未満	---	4	0	0.004未満	0.004未満	0.004未満	---									
亜鉛及びその化合物	mg/L	1.0mg/L以下	---	---	---	---	0.010	---	---	---	---	---	---	---	1	0	0.010	0.010	0.010	2024/08/07
アルミニウム及びその化合物	mg/L	0.2mg/L以下	---	---	---	---	0.010	---	---	---	---	---	---	---	1	0	0.010	0.010	0.010	2024/08/07
鉄及びその化合物	mg/L	0.3mg/L以下	---	---	---	---	0.02未満	---	---	---	---	---	---	---	1	0	0.02未満	0.02未満	0.02未満	---
銅及びその化合物	mg/L	1.0mg/L以下	---	---	---	---	0.010	---	---	---	---	---	---	---	1	0	0.010	0.010	0.010	2024/08/07
ナトリウム及びその化合物	mg/L	200mg/L以下	---	---	---	---	7.9	---	---	---	---	---	---	---	1	0	7.9	7.9	7.9	2024/08/07
マンガン及びその化合物	mg/L	0.05mg/L以下	---	---	---	---	0.001未満	---	---	---	---	---	---	---	1	0	0.001未満	0.001未満	0.001未満	---
塩化物イオン	mg/L	200mg/L以下	3.9	3.7	3.7	3.6	3.6	3.7	3.5	3.7	3.5	3.5	3.3	3.2	12	0	3.6	3.9	3.2	2024/04/03
カルシウム、マグネシウム等(硬度)	mg/L	300mg/L以下	---	63	---	---	60	---	---	59	---	---	63	---	4	0	61	63	59	2024/05/08
蒸発残留物	mg/L	500mg/L以下	---	120	---	---	110	---	---	120	---	---	130	---	4	0	120	130	110	2025/02/05
陰イオン界面活性剤	mg/L	0.2mg/L以下	---	---	---	---	0.02未満	---	---	---	---	---	---	---	1	0	0.02未満	0.02未満	0.02未満	---
ジェオスミン	mg/L	0.00001mg/L以下	---	---	---	---	0.000001未満	---	---	---	---	---	---	---	1	0	0.000001未満	0.000001未満	0.000001未満	---
2-メチルイソボルネオール	mg/L	0.00001mg/L以下	---	---	---	---	0.000001未満	---	---	---	---	---	---	---	1	0	0.000001未満	0.000001未満	0.000001未満	---
非イオン界面活性剤	mg/L	0.02mg/L以下	---	---	---	---	0.002未満	---	---	---	---	---	---	---	1	0	0.002未満	0.002未満	0.002未満	---
フェノール類	mg/L	0.005mg/L以下	---	---	---	---	0.0005未満	---	---	---	---	---	---	---	1	0	0.0005未満	0.0005未満	0.0005未満	---
有機物(全有機炭素(TOC)の量)	mg/L	3mg/L以下	0.2未満	12	0	0.2未満	0.2未満	0.2未満	---											
pH値	-	5.8以上8.6以下	7.2	7.2	7.2	7.2	7.2	7.2	7.2	7.3	7.2	7.1	7.2	7.2	12	0	7.2	7.3	7.1	2024/11/06
味	-	異常でないこと	異常なし	12	0	---	---	---	---											
臭気	-	異常でないこと	異常なし	12	0	---	---	---	---											
色度	度	5度以下	0.5未満	12	0	0.5未満	0.5未満	0.5未満	---											
濁度	度	2度以下	0.1未満	12	0	0.1未満	0.1未満	0.1未満	---											
上記項目についての水質基準適合判定			適合																	

項目	単位	基準値	2024/04/03	2024/05/08	2024/06/05	2024/07/03	2024/08/07	2024/09/04	2024/10/02	2024/11/06	2024/12/04	2025/01/08	2025/02/05	2025/03/05	測定回数	不適回数	平均値	最大値	最小値	最大値検出日
			24-SS-00039	24-SS-00427	24-SS-00908	24-SS-01444	24-SS-02062	24-SS-02566	24-SS-03028	24-SS-03435	24-SS-03883	24-SS-04272	24-SS-04705	24-SS-05072						
			SS 上水道																	
水温	℃	-	15.5	21.0	22.0	25.5	30.5	27.5	28.0	21.5	16.0	11.0	12.0	11.5	12	0	20.2	30.5	11.0	2024/08/07
気温	℃	-	13.7	24.6	26.1	30.0	34.6	30.3	29.1	22.3	17.8	5.7	8.3	10.9	12	0	21.1	34.6	5.7	2024/08/07
残留塩素濃度	mg/L	-	0.3	0.3	0.3	0.3	0.3	0.3	0.2	0.2	0.2	0.2	0.2	0.2	12	0	0.3	0.3	0.2	2024/04/03
一般細菌	CFU/mL	100CFU/mL以下	0	0	0	0	0	0	0	1	0	0	0	0	12	0	0	1	0	2024/11/06
大腸菌	-	検出されないこと	検出しない	12	0	---	---	---	---											
カドミウム及びその化合物	mg/L	0.003mg/L以下	---	---	---	---	---	0.00015未満	---	---	---	---	---	---	1	0	0.00015未満	0.00015未満	0.00015未満	---
水銀及びその化合物	mg/L	0.0005mg/L以下	---	---	---	---	---	0.00005未満	---	---	---	---	---	---	1	0	0.00005未満	0.00005未満	0.00005未満	---
セレン及びその化合物	mg/L	0.01mg/L以下	---	---	---	---	---	0.0005未満	---	---	---	---	---	---	1	0	0.0005未満	0.0005未満	0.0005未満	---
鉛及びその化合物	mg/L	0.01mg/L以下	---	---	---	---	---	0.0005未満	---	---	---	---	---	---	1	0	0.0005未満	0.0005未満	0.0005未満	---
ヒ素及びその化合物	mg/L	0.01mg/L以下	---	---	---	---	---	0.0005未満	---	---	---	---	---	---	1	0	0.0005未満	0.0005未満	0.0005未満	---
六価クロム化合物	mg/L	0.02mg/L以下	---	---	---	---	---	0.002未満	---	---	---	---	---	---	1	0	0.002未満	0.002未満	0.002未満	---
亜硝酸態窒素	mg/L	0.04mg/L以下	---	---	---	---	---	0.004未満	---	---	---	---	---	---	1	0	0.004未満	0.004未満	0.004未満	---
シアン化物イオン及び塩化シアン	mg/L	0.01mg/L以下	---	0.001未満	---	---	---	0.001未満	---	0.001未満	---	---	0.001未満	---	4	0	0.001未満	0.001未満	0.001未満	---
硝酸態窒素及び亜硝酸態窒素	mg/L	10mg/L以下	---	---	---	---	0.3	---	---	---	---	---	---	---	1	0	0.3	0.3	0.3	2024/08/07
フッ素及びその化合物	mg/L	0.8mg/L以下	---	---	---	---	0.05未満	---	---	---	---	---	---	---	1	0	0.05未満	0.05未満	0.05未満	---
ホウ素及びその化合物	mg/L	1.0mg/L以下	---	---	---	---	0.03	---	---	---	---	---	---	---	1	0	0.03	0.03	0.03	2024/08/07
四塩化炭素	mg/L	0.002mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---	---	---	1	0	0.0002未満	0.0002未満	0.0002未満	---
1,4-ジオキサン	mg/L	0.05mg/L以下	---	---	---	---	0.003未満	---	---	---	---	---	---	---	1	0	0.003未満	0.003未満	0.003未満	---
シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン	mg/L	0.04mg/L以下	---	---	---	---	0.0004未満	---	---	---	---	---	---	---	1	0	0.0004未満	0.0004未満	0.0004未満	---
ジクロロメタン	mg/L	0.02mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---	---	---	1	0	0.0002未満	0.0002未満	0.0002未満	---
テトラクロロエチレン	mg/L	0.01mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---	---	---	1	0	0.0002未満	0.0002未満	0.0002未満	---
トリクロロエチレン	mg/L	0.01mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---	---	---	1	0	0.0002未満	0.0002未満	0.0002未満	---
ベンゼン	mg/L	0.01mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---	---	---	1	0	0.0002未満	0.0002未満	0.0002未満	---
塩素酸	mg/L	0.06mg/L以下	---	0.06未満	---	4	0	0.06未満	0.06未満	0.06未満	---									
クロロ酢酸	mg/L	0.02mg/L以下	---	0.002未満	---	4	0	0.002未満	0.002未満	0.002未満	---									
クロロホルム	mg/L	0.06mg/L以下	---	0.0008	---	---	0.0015	---	---	0.0010	---	---	0.0004	---	4	0	0.0009	0.0015	0.0004	2024/08/07
ジクロロ酢酸	mg/L	0.03mg/L以下	---	0.002未満	---	4	0	0.002未満	0.002未満	0.002未満	---									
ジブromクロロメタン	mg/L	0.1mg/L以下	---	0.0003	---	---	0.0004	---	---	0.0003	---	---	0.0002未満	---	4	0	0.0003	0.0004	0.0002未満	2024/08/07
臭素酸	mg/L	0.01mg/L以下	---	0.001未満	---	4	0	0.001未満	0.001未満	0.001未満	---									
総トリハロメタン	mg/L	0.1mg/L以下	---	0.01未満	---	4	0	0.01未満	0.01未満	0.01未満	---									
トリクロロ酢酸	mg/L	0.03mg/L以下	---	0.002未満	---	4	0	0.002未満	0.002未満	0.002未満	---									
ブromジクロロメタン	mg/L	0.03mg/L以下	---	0.0003	---	---	0.0005	---	---	0.0003	---	---	0.0002未満	---	4	0	0.0003	0.0005	0.0002未満	2024/08/07
ブromホルム	mg/L	0.09mg/L以下	---	0.0002未満	---	---	0.0002	---	---	0.0002未満	---	---	0.0002未満	---	4	0	0.0002	0.0002	0.0002未満	2024/08/07
ホルムアルデヒド	mg/L	0.08mg/L以下	---	0.004未満	---	4	0	0.004未満	0.004未満	0.004未満	---									
亜鉛及びその化合物	mg/L	1.0mg/L以下	---	0.008	---	---	0.008	---	---	---	---	---	---	---	1	0	0.008	0.008	0.008	2024/08/07
アルミニウム及びその化合物	mg/L	0.2mg/L以下	---	---	---	---	0.011	---	---	---	---	---	---	---	1	0	0.011	0.011	0.011	2024/08/07
鉄及びその化合物	mg/L	0.3mg/L以下	---	---	---	---	0.02未満	---	---	---	---	---	---	---	1	0	0.02未満	0.02未満	0.02未満	---
銅及びその化合物	mg/L	1.0mg/L以下	---	---	---	---	0.016	---	---	---	---	---	---	---	1	0	0.016	0.016	0.016	2024/08/07
ナトリウム及びその化合物	mg/L	200mg/L以下	---	---	---	---	7.6	---	---	---	---	---	---	---	1	0	7.6	7.6	7.6	2024/08/07
マンガン及びその化合物	mg/L	0.05mg/L以下	---	---	---	---	0.001未満	---	---	---	---	---	---	---	1	0	0.001未満	0.001未満	0.001未満	---
塩化物イオン	mg/L	200mg/L以下	4.0	3.7	3.8	3.6	3.5	3.7	3.6	3.7	3.5	3.6	3.3	3.2	12	0	3.6	4.0	3.2	2024/04/03
カルシウム、マグネシウム等(硬度)	mg/L	300mg/L以下	---	65	---	---	59	---	---	61	---	---	61	---	4	0	62	65	59	2024/05/08
蒸発残留物	mg/L	500mg/L以下	---	120	---	---	110	---	---	120	---	---	120	---	4	0	118	120	110	2024/05/08
陰イオン界面活性剤	mg/L	0.2mg/L以下	---	---	---	---	0.02未満	---	---	---	---	---	---	---	1	0	0.02未満	0.02未満	0.02未満	---
ジェオスミン	mg/L	0.00001mg/L以下	---	---	---	---	0.000001未満	---	---	---	---	---	---	---	1	0	0.000001未満	0.000001未満	0.000001未満	---
2-メチルイソボルネオール	mg/L	0.00001mg/L以下	---	---	---	---	0.000001未満	---	---	---	---	---	---	---	1	0	0.000001未満	0.000001未満	0.000001未満	---
非イオン界面活性剤	mg/L	0.02mg/L以下	---	---	---	---	0.002未満	---	---	---	---	---	---	---	1	0	0.002未満	0.002未満	0.002未満	---
フェノール類	mg/L	0.005mg/L以下	---	---	---	---	0.0005未満	---	---	---	---	---	---	---	1	0	0.0005未満	0.0005未満	0.0005未満	---
有機物(全有機炭素(TOC)の量)	mg/L	3mg/L以下	0.2未満	12	0	0.2未満	0.2未満	0.2未満	---											
pH値	-	5.8以上8.6以下	7.2	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.2	7.2	7.2	12	0	7.3	7.3	7.2	2024/05/08
味	-	異常でないこと	異常なし	12	0	---	---	---	---											
臭気	-	異常でないこと	異常なし	12	0	---	---	---	---											
色度	度	5度以下	0.5未満	12	0	0.5未満	0.5未満	0.5未満	---											
濁度	度	2度以下	0.1未満	12	0	0.1未満	0.1未満	0.1未満	---											
上記項目についての水質基準適合判定			適合																	

項目	単位	基準値	2024/04/03	2024/05/08	2024/06/05	2024/07/03	2024/08/07	2024/09/04	2024/10/02	2024/11/06	2024/12/04	2025/01/08	2025/02/05	2025/03/05	測定回数	不適回数	平均値	最大値	最小値	最大値検出日
			24-SS-00038	24-SS-00426	24-SS-00907	24-SS-01443	24-SS-02061	24-SS-02565	24-SS-03027	24-SS-03434	24-SS-03882	24-SS-04271	24-SS-04704	24-SS-05071						
			SS 上水道																	
水温	℃	-	15.0	18.5	21.5	24.0	30.5	27.5	26.5	20.8	16.0	11.0	12.0	11.5	12	0	19.6	30.5	11.0	2024/08/07
気温	℃	-	12.9	24.1	25.8	31.1	36.8	30.4	27.1	20.4	15.6	5.3	5.5	10.7	12	0	20.5	36.8	5.3	2024/08/07
残留塩素濃度	mg/L	-	0.3	0.3	0.3	0.3	0.3	0.3	0.2	0.2	0.2	0.2	0.2	0.2	12	0	0.3	0.3	0.2	2024/04/03
一般細菌	CFU/mL	100CFU/mL以下	0	0	0	0	2	0	0	0	0	0	0	0	12	0	0	2	0	2024/08/07
大腸菌	-	検出されないこと	検出しない	12	0	---	---	---	---											
カドミウム及びその化合物	mg/L	0.003mg/L以下	---	---	---	---	0.00015未満	---	---	---	---	---	---	---	1	0	0.00015未満	0.00015未満	0.00015未満	---
水銀及びその化合物	mg/L	0.0005mg/L以下	---	---	---	---	0.00005未満	---	---	---	---	---	---	---	1	0	0.00005未満	0.00005未満	0.00005未満	---
セレン及びその化合物	mg/L	0.01mg/L以下	---	---	---	---	0.0005未満	---	---	---	---	---	---	---	1	0	0.0005未満	0.0005未満	0.0005未満	---
鉛及びその化合物	mg/L	0.01mg/L以下	---	---	---	---	0.0005未満	---	---	---	---	---	---	---	1	0	0.0005未満	0.0005未満	0.0005未満	---
ヒ素及びその化合物	mg/L	0.01mg/L以下	---	---	---	---	0.0005未満	---	---	---	---	---	---	---	1	0	0.0005未満	0.0005未満	0.0005未満	---
六価クロム化合物	mg/L	0.02mg/L以下	---	---	---	---	0.002未満	---	---	---	---	---	---	---	1	0	0.002未満	0.002未満	0.002未満	---
亜硝酸態窒素	mg/L	0.04mg/L以下	---	---	---	---	0.004未満	---	---	---	---	---	---	---	1	0	0.004未満	0.004未満	0.004未満	---
シアン化物イオン及び塩化シアン	mg/L	0.01mg/L以下	---	0.001未満	---	4	0	0.001未満	0.001未満	0.001未満	---									
硝酸態窒素及び亜硝酸態窒素	mg/L	10mg/L以下	---	---	---	---	0.4	---	---	---	---	---	---	---	1	0	0.4	0.4	0.4	2024/08/07
フッ素及びその化合物	mg/L	0.8mg/L以下	---	---	---	---	0.05未満	---	---	---	---	---	---	---	1	0	0.05未満	0.05未満	0.05未満	---
ホウ素及びその化合物	mg/L	1.0mg/L以下	---	---	---	---	0.02	---	---	---	---	---	---	---	1	0	0.02	0.02	0.02	2024/08/07
四塩化炭素	mg/L	0.002mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---	---	---	1	0	0.0002未満	0.0002未満	0.0002未満	---
1,4-ジオキサン	mg/L	0.05mg/L以下	---	---	---	---	0.003未満	---	---	---	---	---	---	---	1	0	0.003未満	0.003未満	0.003未満	---
シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン	mg/L	0.04mg/L以下	---	---	---	---	0.0004未満	---	---	---	---	---	---	---	1	0	0.0004未満	0.0004未満	0.0004未満	---
ジクロロメタン	mg/L	0.02mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---	---	---	1	0	0.0002未満	0.0002未満	0.0002未満	---
テトラクロロエチレン	mg/L	0.01mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---	---	---	1	0	0.0002未満	0.0002未満	0.0002未満	---
トリクロロエチレン	mg/L	0.01mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---	---	---	1	0	0.0002未満	0.0002未満	0.0002未満	---
ベンゼン	mg/L	0.01mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---	---	---	1	0	0.0002未満	0.0002未満	0.0002未満	---
塩素酸	mg/L	0.06mg/L以下	---	0.06未満	---	---	0.06未満	---	---	0.07	---	---	0.06未満	---	4	0	0.06	0.07	0.06未満	2024/11/06
クロロ酢酸	mg/L	0.02mg/L以下	---	0.002未満	---	4	0	0.002未満	0.002未満	0.002未満	---									
クロロホルム	mg/L	0.06mg/L以下	---	0.0002未満	---	4	0	0.0002未満	0.0002未満	0.0002未満	---									
ジクロロ酢酸	mg/L	0.03mg/L以下	---	0.002未満	---	4	0	0.002未満	0.002未満	0.002未満	---									
ジブロモクロロメタン	mg/L	0.1mg/L以下	---	0.0002未満	---	4	0	0.0002未満	0.0002未満	0.0002未満	---									
臭素酸	mg/L	0.01mg/L以下	---	0.001未満	---	4	0	0.001未満	0.001未満	0.001未満	---									
総トリハロメタン	mg/L	0.1mg/L以下	---	0.01未満	---	4	0	0.01未満	0.01未満	0.01未満	---									
トリクロロ酢酸	mg/L	0.03mg/L以下	---	0.002未満	---	4	0	0.002未満	0.002未満	0.002未満	---									
ブロモジクロロメタン	mg/L	0.03mg/L以下	---	0.0002未満	---	4	0	0.0002未満	0.0002未満	0.0002未満	---									
ブロモホルム	mg/L	0.09mg/L以下	---	0.0002未満	---	4	0	0.0002未満	0.0002未満	0.0002未満	---									
ホルムアルデヒド	mg/L	0.08mg/L以下	---	0.004未満	---	4	0	0.004未満	0.004未満	0.004未満	---									
亜鉛及びその化合物	mg/L	1.0mg/L以下	---	---	---	---	0.004	---	---	---	---	---	---	---	1	0	0.004	0.004	0.004	2024/08/07
アルミニウム及びその化合物	mg/L	0.2mg/L以下	---	---	---	---	0.005未満	---	---	---	---	---	---	---	1	0	0.005未満	0.005未満	0.005未満	---
鉄及びその化合物	mg/L	0.3mg/L以下	---	---	---	---	0.02未満	---	---	---	---	---	---	---	1	0	0.02未満	0.02未満	0.02未満	---
銅及びその化合物	mg/L	1.0mg/L以下	---	---	---	---	0.009	---	---	---	---	---	---	---	1	0	0.009	0.009	0.009	2024/08/07
ナトリウム及びその化合物	mg/L	200mg/L以下	---	---	---	---	7.4	---	---	---	---	---	---	---	1	0	7.4	7.4	7.4	2024/08/07
マンガン及びその化合物	mg/L	0.05mg/L以下	---	---	---	---	0.001未満	---	---	---	---	---	---	---	1	0	0.001未満	0.001未満	0.001未満	---
塩化物イオン	mg/L	200mg/L以下	3.4	3.4	3.3	3.3	3.3	3.3	3.2	3.1	3.2	3.2	3.1	12	0	3.3	3.4	3.1	2024/04/03	
カルシウム、マグネシウム等(硬度)	mg/L	300mg/L以下	---	61	---	---	61	---	---	60	---	---	63	---	4	0	61	63	60	2025/02/05
蒸発残留物	mg/L	500mg/L以下	---	120	---	---	110	---	---	120	---	---	120	---	4	0	118	120	110	2024/05/08
陰イオン界面活性剤	mg/L	0.2mg/L以下	---	---	---	---	0.02未満	---	---	---	---	---	---	---	1	0	0.02未満	0.02未満	0.02未満	---
ジェオスミン	mg/L	0.00001mg/L以下	---	---	---	---	0.000001未満	---	---	---	---	---	---	---	1	0	0.000001未満	0.000001未満	0.000001未満	---
2-メチルイソボルネオール	mg/L	0.00001mg/L以下	---	---	---	---	0.000001未満	---	---	---	---	---	---	---	1	0	0.000001未満	0.000001未満	0.000001未満	---
非イオン界面活性剤	mg/L	0.02mg/L以下	---	---	---	---	0.002未満	---	---	---	---	---	---	---	1	0	0.002未満	0.002未満	0.002未満	---
フェノール類	mg/L	0.005mg/L以下	---	---	---	---	0.0005未満	---	---	---	---	---	---	---	1	0	0.0005未満	0.0005未満	0.0005未満	---
有機物(全有機炭素(TOC)の量)	mg/L	3mg/L以下	0.2未満	12	0	0.2未満	0.2未満	0.2未満	---											
pH値	-	5.8以上8.6以下	7.5	7.5	7.5	7.5	7.5	7.6	7.5	7.5	7.5	7.5	7.5	7.5	12	0	7.5	7.6	7.5	2024/09/04
味	-	異常でないこと	異常なし	12	0	---	---	---	---											
臭気	-	異常でないこと	異常なし	12	0	---	---	---	---											
色度	度	5度以下	0.5未満	12	0	0.5未満	0.5未満	0.5未満	---											
濁度	度	2度以下	0.1未満	12	0	0.1未満	0.1未満	0.1未満	---											
上記項目についての水質基準適合判定			適合																	