

施設名：焼津市上水（大島下ちびっこ広場） 採水場所：焼津市大島1206-1 大島下ちびっこ広場

項目	単位	基準値	2025/04/02	2025/05/07	2025/06/04	2025/07/02	2025/08/06	2025/09/03	2025/10/01	2025/11/05	2025/12/03				測定回数	不適回数	平均値	最大値	最小値	最大値検出日
			25-SS-00025	25-SS-00420	25-SS-00923	25-SS-01454	25-SS-02023	25-SS-02608	25-SS-02971	25-SS-03410	25-SS-03836									
			SS																	
			上水道																	
水温	°C	-	17.0	18.0	18.2	20.0	27.5	21.2	21.0	18.0	17.1				9	0	19.8	27.5	17.0	2025/08/06
气温	°C	-	17.3	20.9	25.2	29.3	35.4	34.1	24.3	15.2	13.1				9	0	23.9	35.4	13.1	2025/08/06
残留塩素濃度	mg/L	-	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2				9	0	0.2	0.2	0.2	---
一般細菌	CFU/mL	100CFU/mL以下	0	0	0	0	0	0	0	0	0				9	0	0	0	0	---
大腸菌	-	検出されないこと	検出しない				9	0	---	---	---	---								
カドミウム及びその化合物	mg/L	0.003mg/L以下	---	---	---	---	0.00015未満	---	---	---	---				1	0	0.00015未満	0.00015未満	0.00015未満	---
水銀及びその化合物	mg/L	0.005mg/L以下	---	---	---	---	0.00005未満	---	---	---	---				1	0	0.00005未満	0.00005未満	0.00005未満	---
セレン及びその化合物	mg/L	0.01mg/L以下	---	---	---	---	0.0006	---	---	---	---				1	0	0.0006	0.0006	0.0006	2025/08/06
鉛及びその化合物	mg/L	0.01mg/L以下	---	---	---	---	0.0005未満	---	---	---	---				1	0	0.0005未満	0.0005未満	0.0005未満	---
ヒ素及びその化合物	mg/L	0.01mg/L以下	---	---	---	---	0.0005未満	---	---	---	---				1	0	0.0005未満	0.0005未満	0.0005未満	---
六価クロム化合物	mg/L	0.02mg/L以下	---	---	---	---	0.002未満	---	---	---	---				1	0	0.002未満	0.002未満	0.002未満	---
亜硝酸態窒素	mg/L	0.04mg/L以下	---	---	---	---	0.004未満	---	---	---	---				1	0	0.004未満	0.004未満	0.004未満	---
シアノ化物イオン及び塩化シアノ	mg/L	0.01mg/L以下	---	0.001未満	---	---	0.001未満	---	0.001未満	---	---				3	0	0.001未満	0.001未満	0.001未満	---
硝酸態窒素及び亜硝酸態窒素	mg/L	10mg/L以下	---	---	---	---	1.0	---	---	---	---				1	0	1.00	1.00	1.00	2025/08/06
フッ素及びその化合物	mg/L	0.8mg/L以下	---	---	---	---	0.05未満	---	---	---	---				1	0	0.05未満	0.05未満	0.05未満	---
ホウ素及びその化合物	mg/L	1.0mg/L以下	---	---	---	---	0.04	---	---	---	---				1	0	0.04	0.04	0.04	2025/08/06
四塩化炭素	mg/L	0.002mg/L以下	---	---	---	---	0.0002未満	---	---	---	---				1	0	0.0002未満	0.0002未満	0.0002未満	---
1,4-ジオキサン	mg/L	0.05mg/L以下	---	---	---	---	0.003未満	---	---	---	---				1	0	0.003未満	0.003未満	0.003未満	---
シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン	mg/L	0.04mg/L以下	---	---	---	---	0.0004未満	---	---	---	---				1	0	0.0004未満	0.0004未満	0.0004未満	---
ジクロロメタン	mg/L	0.02mg/L以下	---	---	---	---	0.0002未満	---	---	---	---				1	0	0.0002未満	0.0002未満	0.0002未満	---
トトラクロロエチレン	mg/L	0.01mg/L以下	---	---	---	---	0.0002未満	---	---	---	---				1	0	0.0002未満	0.0002未満	0.0002未満	---
トリクロロエチレン	mg/L	0.01mg/L以下	---	---	---	---	0.0002未満	---	---	---	---				1	0	0.0002未満	0.0002未満	0.0002未満	---
ベンゼン	mg/L	0.01mg/L以下	---	---	---	---	0.0002未満	---	---	---	---				1	0	0.0002未満	0.0002未満	0.0002未満	---
塩素酸	mg/L	0.6mg/L以下	---	0.06未満	---	---	0.06未満	---	0.06未満	---	0.06未満	---	---		3	0	0.06未満	0.06未満	0.06未満	---
クロロ酢酸	mg/L	0.02mg/L以下	---	0.002未満	---	---	0.002未満	---	0.002未満	---	0.002未満	---	---		3	0	0.002未満	0.002未満	0.002未満	---
クロロホルム	mg/L	0.06mg/L以下	---	0.0002未満	---	---	0.0002未満	---	0.0002未満	---	0.0002未満	---	---		3	0	0.0002未満	0.0002未満	0.0002未満	---
ジクロロ酢酸	mg/L	0.03mg/L以下	---	0.002未満	---	---	0.002未満	---	0.002未満	---	0.002未満	---	---		3	0	0.002未満	0.002未満	0.002未満	---
ジプロモクロロメタン	mg/L	0.1mg/L以下	---	0.0002未満	---	---	0.0002未満	---	0.0002未満	---	0.0002未満	---	---		3	0	0.0002未満	0.0002未満	0.0002未満	---
臭素酸	mg/L	0.01mg/L以下	---	0.001未満	---	---	0.001未満	---	0.001未満	---	0.001未満	---	---		3	0	0.001未満	0.001未満	0.001未満	---
総トライハロメタン	mg/L	0.1mg/L以下	---	0.01未満	---	---	0.01未満	---	0.01未満	---	0.01未満	---	---		3	0	0.01未満	0.01未満	0.01未満	---
トリクロロ酢酸	mg/L	0.03mg/L以下	---	0.002未満	---	---	0.002未満	---	0.002未満	---	0.002未満	---	---		3	0	0.002未満	0.002未満	0.002未満	---
ブロモジクロロメタン	mg/L	0.03mg/L以下	---	0.0002未満	---	---	0.0002未満	---	0.0002未満	---	0.0002未満	---	---		3	0	0.0002未満	0.0002未満	0.0002未満	---
ブロモホルム	mg/L	0.09mg/L以下	---	0.0002未満	---	---	0.0002未満	---	0.0002未満	---	0.0002未満	---	---		3	0	0.0002未満	0.0002未満	0.0002未満	---
ホルムアルデヒド	mg/L	0.08mg/L以下	---	0.004未満	---	---	0.004未満	---	0.004未満	---	0.004未満	---	---		3	0	0.004未満	0.004未満	0.004未満	---
亜鉛及びその化合物	mg/L	1.0mg/L以下	---	---	---	0.004	---	---	---	---	---				1	0	0.004	0.004	0.004	2025/08/06
アルミニウム及びその化合物	mg/L	0.2mg/L以下	---	---	---	0.007	---	---	---	---	---				1	0	0.007	0.007	0.007	2025/08/06
鉄及びその化合物	mg/L	0.3mg/L以下	---	---	---	---	0.02未満	---	---	---	---				1	0	0.02未満	0.02未満	0.02未満	---
銅及びその化合物	mg/L	1.0mg/L以下	---	---	---	0.010	---	---	---	---	---				1	0	0.010	0.010	0.010	2025/08/06
ナトリウム及びその化合物	mg/L	200mg/L以下	---	---	---	9.6	---	---	---	---	---				1	0	9.6	9.6	9.6	2025/08/06
マンガン及びその化合物	mg/L	0.05mg/L以下	---	---	---	0.001未満	---	---	---	---	---				1	0	0.001未満	0.001未満	0.001未満	---
塩化物イオン	mg/L	200mg/L以下	5.4	5.0	5.0	5.0	4.9	4.8	4.7	4.8	4.9				9	0	4.9	5.4	4.7	2025/04/02
カルシウム、マグネシウム等(硬度)	mg/L	300mg/L以下	---	73	---	---	71	---	69	---	120	---			3	0	71	73	69	2025/05/07
蒸発残留物	mg/L	500mg/L以下	---	140	---	---	130	---	---	120	---				3	0	130	140	120	2025/05/07
陰イオン界面活性剤	mg/L	0.2mg/L以下	---	---	---	0.02未満	---	---	---	---	---				1	0	0.02未満	0.02未満	0.02未満	---
ジェオスミン	mg/L	0.00001mg/L以下	---	---	---	0.000001未満	---	---	---	---	---				1	0	0.000001未満	0.000001未満	0.000001未満	---
2-メチルイソポルネオール	mg/L	0.00001mg/L以下	---	---	---	0.000001未満	---	---	---	---	---				1	0	0.000001未満	0.000001未満	0.000001未満	---
非イオン界面活性剤	mg/L	0.02mg/L以下	---	---	---	0.002未満	---	---	---	---	---				1	0	0.002未満	0.002未満	0.002未満	---
フェノール類	mg/L	0.005mg/L以下	---	---	---	0.0005未満	---	---	---	---	---				1	0	0.0005未満	0.0005未満	0.0005未満	---
有機物(全有機炭素(TOC)の量)	mg/L	3mg/L以下	0.2未満				9	0	0.2未満	0.2未満	0.2未満	---								
pH値	-	5.8以上8.6以下	7.5	7.6	7.5	6.9	7.6	7.6	7.7	7.6	7.5				9	0	7.5	7.7	6.9	2025/10/01
味	-	異常でないこと	異常なし				9	0	---	---	---	---								
臭気	-	異常でないこと	異常なし				9	0	---	---	---	---								
色度	度	5度以下	0.5未満				9	0	0.5未満	0.5未満	0.5未満	---								
濁度	度	2度以下	0.1未満				9	0	0.1未満	0.1未満	0.1未満	---								

上記項目についての水質基準適合判定

適合 合格 合格