

施設名：焼津市上水（坂本加圧ポンプ所） 採水場所：焼津市坂本4 1 3 - 2 坂本加圧ポンプ所

| 項目 | 単位 | 基準値 | 2025/04/02 | 2025/05/07 | 2025/06/04 | 2025/07/02 | 2025/08/06 | 2025/09/03 | 2025/10/01 | 2025/11/05 | 2025/12/03 | 2026/01/07 | 2026/02/04 | 2026/03/04 | 測定回数 | 不適回数 | 平均値 | 最大値 | 最小値 | 最大値検出日 |
|------------------------------------|--------|---------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|------|------|------------|------------|------------|------------|
| | | | 25-SS-00030 | 25-SS-00425 | 25-SS-00928 | 25-SS-01459 | 25-SS-02036 | 25-SS-02613 | 25-SS-02976 | 25-SS-03415 | 25-SS-03841 | 25-SS-04225 | 25-SS-04627 | 25-SS-05040 | | | | | | |
| | | | SS 上水道 | SS 上水道 | SS 上水道 | SS 上水道 | SS 上水道 | SS 上水道 | SS 上水道 | SS 上水道 | SS 上水道 | SS 上水道 | SS 上水道 | SS 上水道 | | | | | | |
| 水温 | ℃ | - | 17.0 | 18.0 | 19.0 | 21.1 | 22.8 | 22.0 | 22.0 | 19.0 | 17.1 | 16.0 | 15.2 | 16.0 | 12 | 0 | 18.8 | 22.8 | 15.2 | 2025/08/06 |
| 気温 | ℃ | - | 17.9 | 23.3 | 26.7 | 28.3 | 37.7 | 35.7 | 22.4 | 17.5 | 14.2 | 10.0 | 11.2 | 16.2 | 12 | 0 | 21.8 | 37.7 | 10.0 | 2025/08/06 |
| 残留塩素濃度 | mg/L | - | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 0.2 | 12 | 0 | 0.2 | 0.2 | 0.2 | --- |
| 一般細菌 | CFU/mL | 100CFU/mL以下 | 1 | 0 | 0 | 0 | 0 | 0 | 0 | 2 | 0 | 0 | 0 | 0 | 12 | 0 | 0 | 2 | 0 | 2025/10/01 |
| 大腸菌 | - | 検出されないこと | 検出しない | 検出しない | 検出しない | 検出しない | 検出しない | 検出しない | 検出しない | 検出しない | 検出しない | 検出しない | 検出しない | 検出しない | 12 | 0 | --- | --- | --- | --- |
| カドミウム及びその化合物 | mg/L | 0.003mg/L以下 | --- | --- | --- | --- | --- | 0.00015未満 | --- | --- | --- | --- | --- | --- | 1 | 0 | 0.00015未満 | 0.00015未満 | 0.00015未満 | --- |
| 水銀及びその化合物 | mg/L | 0.0005mg/L以下 | --- | --- | --- | --- | --- | 0.00005未満 | --- | --- | --- | --- | --- | --- | 1 | 0 | 0.00005未満 | 0.00005未満 | 0.00005未満 | --- |
| セレン及びその化合物 | mg/L | 0.01mg/L以下 | --- | --- | --- | --- | 0.0006 | --- | --- | --- | --- | --- | --- | --- | 1 | 0 | 0.0006 | 0.0006 | 0.0006 | 2025/08/06 |
| 鉛及びその化合物 | mg/L | 0.01mg/L以下 | --- | --- | --- | --- | --- | 0.0005未満 | --- | --- | --- | --- | --- | --- | 1 | 0 | 0.0005未満 | 0.0005未満 | 0.0005未満 | --- |
| ヒ素及びその化合物 | mg/L | 0.01mg/L以下 | --- | --- | --- | --- | --- | 0.0005未満 | --- | --- | --- | --- | --- | --- | 1 | 0 | 0.0005未満 | 0.0005未満 | 0.0005未満 | --- |
| 六価クロム化合物 | mg/L | 0.02mg/L以下 | --- | --- | --- | --- | --- | 0.002未満 | --- | --- | --- | --- | --- | --- | 1 | 0 | 0.002未満 | 0.002未満 | 0.002未満 | --- |
| 亜硝酸態窒素 | mg/L | 0.04mg/L以下 | --- | --- | --- | --- | --- | 0.004未満 | --- | --- | --- | --- | --- | --- | 1 | 0 | 0.004未満 | 0.004未満 | 0.004未満 | --- |
| シアン化物イオン及び塩化シアン | mg/L | 0.01mg/L以下 | --- | 0.001未満 | --- | --- | --- | 0.001未満 | --- | 0.001未満 | --- | --- | 0.001未満 | --- | 4 | 0 | 0.001未満 | 0.001未満 | 0.001未満 | --- |
| 硝酸態窒素及び亜硝酸態窒素 | mg/L | 10mg/L以下 | --- | --- | --- | --- | 0.9 | --- | --- | --- | --- | --- | --- | --- | 1 | 0 | 0.90 | 0.90 | 0.90 | 2025/08/06 |
| フッ素及びその化合物 | mg/L | 0.8mg/L以下 | --- | --- | --- | --- | 0.05未満 | --- | --- | --- | --- | --- | --- | --- | 1 | 0 | 0.05未満 | 0.05未満 | 0.05未満 | --- |
| ホウ素及びその化合物 | mg/L | 1.0mg/L以下 | --- | --- | --- | --- | 0.04 | --- | --- | --- | --- | --- | --- | --- | 1 | 0 | 0.04 | 0.04 | 0.04 | 2025/08/06 |
| 四塩化炭素 | mg/L | 0.002mg/L以下 | --- | --- | --- | --- | 0.0002未満 | --- | --- | --- | --- | --- | --- | --- | 1 | 0 | 0.0002未満 | 0.0002未満 | 0.0002未満 | --- |
| 1,4-ジオキサン | mg/L | 0.05mg/L以下 | --- | --- | --- | --- | 0.003未満 | --- | --- | --- | --- | --- | --- | --- | 1 | 0 | 0.003未満 | 0.003未満 | 0.003未満 | --- |
| シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン | mg/L | 0.04mg/L以下 | --- | --- | --- | --- | 0.0004未満 | --- | --- | --- | --- | --- | --- | --- | 1 | 0 | 0.0004未満 | 0.0004未満 | 0.0004未満 | --- |
| ジクロロメタン | mg/L | 0.02mg/L以下 | --- | --- | --- | --- | 0.0002未満 | --- | --- | --- | --- | --- | --- | --- | 1 | 0 | 0.0002未満 | 0.0002未満 | 0.0002未満 | --- |
| テトラクロロエチレン | mg/L | 0.01mg/L以下 | --- | --- | --- | --- | 0.0002未満 | --- | --- | --- | --- | --- | --- | --- | 1 | 0 | 0.0002未満 | 0.0002未満 | 0.0002未満 | --- |
| トリクロロエチレン | mg/L | 0.01mg/L以下 | --- | --- | --- | --- | 0.0002未満 | --- | --- | --- | --- | --- | --- | --- | 1 | 0 | 0.0002未満 | 0.0002未満 | 0.0002未満 | --- |
| ベンゼン | mg/L | 0.01mg/L以下 | --- | --- | --- | --- | 0.0002未満 | --- | --- | --- | --- | --- | --- | --- | 1 | 0 | 0.0002未満 | 0.0002未満 | 0.0002未満 | --- |
| 塩素酸 | mg/L | 0.06mg/L以下 | --- | 0.06未満 | --- | --- | 0.06未満 | --- | --- | 0.06未満 | --- | --- | 0.06未満 | --- | 4 | 0 | 0.06未満 | 0.06未満 | 0.06未満 | --- |
| クロロ酢酸 | mg/L | 0.02mg/L以下 | --- | 0.002未満 | --- | --- | 0.002未満 | --- | --- | 0.002未満 | --- | --- | 0.002未満 | --- | 4 | 0 | 0.002未満 | 0.002未満 | 0.002未満 | --- |
| クロロホルム | mg/L | 0.06mg/L以下 | --- | 0.0006 | --- | --- | 0.0013 | --- | --- | 0.0005 | --- | --- | 0.0002未満 | --- | 4 | 0 | 0.0006 | 0.0013 | 0.0002未満 | 2025/08/06 |
| ジクロロ酢酸 | mg/L | 0.03mg/L以下 | --- | 0.002未満 | --- | --- | 0.002未満 | --- | --- | 0.002未満 | --- | --- | 0.002未満 | --- | 4 | 0 | 0.002未満 | 0.002未満 | 0.002未満 | --- |
| ジブromクロロメタン | mg/L | 0.1mg/L以下 | --- | 0.0002 | --- | --- | 0.0003 | --- | --- | 0.0002未満 | --- | --- | 0.0002未満 | --- | 4 | 0 | 0.0001 | 0.0003 | 0.0002未満 | 2025/08/06 |
| 臭素酸 | mg/L | 0.01mg/L以下 | --- | 0.001未満 | --- | --- | 0.001未満 | --- | --- | 0.001未満 | --- | --- | 0.001未満 | --- | 4 | 0 | 0.001未満 | 0.001未満 | 0.001未満 | --- |
| 総トリハロメタン | mg/L | 0.1mg/L以下 | --- | 0.01未満 | --- | --- | 0.01未満 | --- | --- | 0.01未満 | --- | --- | 0.01未満 | --- | 4 | 0 | 0.01未満 | 0.01未満 | 0.01未満 | --- |
| トリクロロ酢酸 | mg/L | 0.03mg/L以下 | --- | 0.002未満 | --- | --- | 0.002未満 | --- | --- | 0.002未満 | --- | --- | 0.002未満 | --- | 4 | 0 | 0.002未満 | 0.002未満 | 0.002未満 | --- |
| ブromジクロロメタン | mg/L | 0.03mg/L以下 | --- | 0.0002未満 | --- | --- | 0.0002 | --- | --- | 0.0002未満 | --- | --- | 0.0002未満 | --- | 4 | 0 | 0.0001 | 0.0002 | 0.0002未満 | 2025/08/06 |
| ブromホルム | mg/L | 0.09mg/L以下 | --- | 0.0002未満 | --- | --- | 0.0002未満 | --- | --- | 0.0002未満 | --- | --- | 0.0002未満 | --- | 4 | 0 | 0.0002未満 | 0.0002未満 | 0.0002未満 | --- |
| ホルムアルデヒド | mg/L | 0.08mg/L以下 | --- | 0.004未満 | --- | --- | 0.004未満 | --- | --- | 0.004未満 | --- | --- | 0.004未満 | --- | 4 | 0 | 0.004未満 | 0.004未満 | 0.004未満 | --- |
| 亜鉛及びその化合物 | mg/L | 1.0mg/L以下 | --- | --- | --- | --- | 0.002未満 | --- | --- | --- | --- | --- | 0.002未満 | --- | 1 | 0 | 0.002未満 | 0.002未満 | 0.002未満 | --- |
| アルミニウム及びその化合物 | mg/L | 0.2mg/L以下 | --- | --- | --- | --- | 0.010 | --- | --- | --- | --- | --- | --- | --- | 1 | 0 | 0.010 | 0.010 | 0.010 | 2025/08/06 |
| 鉄及びその化合物 | mg/L | 0.3mg/L以下 | --- | --- | --- | --- | 0.02未満 | --- | --- | --- | --- | --- | --- | --- | 1 | 0 | 0.02未満 | 0.02未満 | 0.02未満 | --- |
| 銅及びその化合物 | mg/L | 1.0mg/L以下 | --- | --- | --- | --- | 0.003 | --- | --- | --- | --- | --- | --- | --- | 1 | 0 | 0.003 | 0.003 | 0.003 | 2025/08/06 |
| ナトリウム及びその化合物 | mg/L | 200mg/L以下 | --- | --- | --- | --- | 9.0 | --- | --- | --- | --- | --- | --- | --- | 1 | 0 | 9.0 | 9.0 | 9.0 | 2025/08/06 |
| マンガン及びその化合物 | mg/L | 0.05mg/L以下 | --- | --- | --- | --- | 0.001未満 | --- | --- | --- | --- | --- | --- | --- | 1 | 0 | 0.001未満 | 0.001未満 | 0.001未満 | --- |
| 塩化物イオン | mg/L | 200mg/L以下 | 5.6 | 5.0 | 5.4 | 5.4 | 5.1 | 4.9 | 5.0 | 4.9 | 5.2 | 4.9 | 5.0 | 12 | 0 | 5.2 | 5.6 | 4.9 | 2025/04/02 | |
| カルシウム、マグネシウム等(硬度) | mg/L | 300mg/L以下 | --- | 65 | --- | --- | 60 | --- | --- | 62 | --- | --- | 57 | --- | 12 | 0 | 61 | 65 | 57 | 2025/05/07 |
| 蒸発残留物 | mg/L | 500mg/L以下 | --- | 140 | --- | --- | 110 | --- | --- | 120 | --- | --- | 100 | --- | 4 | 0 | 118 | 140 | 100 | 2025/05/07 |
| 陰イオン界面活性剤 | mg/L | 0.2mg/L以下 | --- | --- | --- | --- | 0.02未満 | --- | --- | --- | --- | --- | --- | --- | 1 | 0 | 0.02未満 | 0.02未満 | 0.02未満 | --- |
| ジェオスミン | mg/L | 0.00001mg/L以下 | --- | --- | --- | --- | 0.000001未満 | --- | --- | --- | --- | --- | --- | --- | 1 | 0 | 0.000001未満 | 0.000001未満 | 0.000001未満 | --- |
| 2-メチルイソボルネオール | mg/L | 0.00001mg/L以下 | --- | --- | --- | --- | 0.000001未満 | --- | --- | --- | --- | --- | --- | --- | 1 | 0 | 0.000001未満 | 0.000001未満 | 0.000001未満 | --- |
| 非イオン界面活性剤 | mg/L | 0.02mg/L以下 | --- | --- | --- | --- | 0.002未満 | --- | --- | --- | --- | --- | --- | --- | 1 | 0 | 0.002未満 | 0.002未満 | 0.002未満 | --- |
| フェノール類 | mg/L | 0.005mg/L以下 | --- | --- | --- | --- | 0.0005未満 | --- | --- | --- | --- | --- | --- | --- | 1 | 0 | 0.0005未満 | 0.0005未満 | 0.0005未満 | --- |
| 有機物(全有機炭素(TOC)の量) | mg/L | 3mg/L以下 | 0.2未満 | 0.2未満 | 0.2未満 | 0.2未満 | 0.2未満 | 0.2未満 | 0.2未満 | 0.2未満 | 0.2未満 | 0.2未満 | 0.2未満 | 0.2未満 | 12 | 0 | 0.2未満 | 0.2未満 | 0.2未満 | --- |
| pH値 | - | 5.8以上8.6以下 | 7.0 | 7.2 | 7.0 | 6.9 | 7.1 | 7.2 | 7.0 | 7.1 | 7.0 | 7.0 | 6.9 | 7.0 | 12 | 0 | 7.0 | 7.2 | 6.9 | 2025/05/07 |
| 味 | - | 異常でないこと | 異常なし | 異常なし | 異常なし | 異常なし | 異常なし | 異常なし | 異常なし | 異常なし | 異常なし | 異常なし | 異常なし | 異常なし | 12 | 0 | --- | --- | --- | --- |
| 臭気 | - | 異常でないこと | 異常なし | 異常なし | 異常なし | 異常なし | 異常なし | 異常なし | 異常なし | 異常なし | 異常なし | 異常なし | 異常なし | 異常なし | 12 | 0 | --- | --- | --- | --- |
| 色度 | 度 | 5度以下 | 0.5未満 | 0.5未満 | 0.5未満 | 0.5未満 | 0.5未満 | 0.5未満 | 0.5未満 | 0.5未満 | 0.5未満 | 0.5未満 | 0.5未満 | 0.5未満 | 12 | 0 | 0.5未満 | 0.5未満 | 0.5未満 | --- |
| 濁度 | 度 | 2度以下 | 0.1未満 | 0.1未満 | 0.1未満 | 0.1未満 | 0.1未満 | 0.1未満 | 0.1未満 | 0.1未満 | 0.1未満 | 0.1未満 | 0.1未満 | 0.1未満 | 12 | 0 | 0.1未満 | 0.1未満 | 0.1未満 | --- |
| 上記項目についての水質基準適合判定 | | | 適合 | 適合 | 適合 | 適合 | 適合 | 適合 | 適合 | 適合 | 適合 | 適合 | 適合 | 適合 | | | | | | |