

施設名：焼津市上水（石津浜公園） 採水場所：焼津市石津 2 4 2 0 石津浜公園

項目	単位	基準値	2024/04/03	2024/05/08	2024/06/05	2024/07/03	2024/08/07	2024/09/04	2024/10/02	2024/11/06	2024/12/04	2025/01/08	2025/02/05	2025/03/05	測定回数	不適回数	平均値	最大値	最小値	最大値検出日
			24-SS-00040	24-SS-00428	24-SS-00909	24-SS-01445	24-SS-02067	24-SS-02567	24-SS-03029	24-SS-03436	24-SS-03884	24-SS-04273	24-SS-04706	24-SS-05073						
			SS 上水道	SS 上水道	SS 上水道	SS 上水道	SS 上水道	SS 上水道	SS 上水道	SS 上水道	SS 上水道	SS 上水道	SS 上水道	SS 上水道						
水温	℃	－	15.5	19.0	20.5	25.0	27.0	26.0	26.5	19.2	15.0	10.0	12.0	10.5	12	0	18.9	27.0	10.0	2024/08/07
気温	℃	－	12.9	24.5	22.8	30.7	31.9	28.0	29.7	20.1	15.5	7.1	6.9	11.2	12	0	20.1	31.9	6.9	2024/08/07
残留塩素濃度	mg/L	－	0.3	0.3	0.3	0.3	0.2	0.3	0.2	0.2	0.2	0.2	0.2	0.2	12	0	0.2	0.3	0.2	2024/04/03
一般細菌	CFU/mL	100CFU/mL以下	0	0	0	0	0	0	0	0	0	0	0	0	12	0	0	0	0	---
大腸菌	－	検出されないこと	検出しない	検出しない	検出しない	検出しない	検出しない	検出しない	検出しない	検出しない	検出しない	検出しない	検出しない	検出しない	12	0	---	---	---	---
カドミウム及びその化合物	mg/L	0.003mg/L以下	---	---	---	---	0.00015未満	---	---	---	---	---	---	---	1	0	0.00015未満	0.00015未満	0.00015未満	---
水銀及びその化合物	mg/L	0.0005mg/L以下	---	---	---	---	0.00005未満	---	---	---	---	---	---	---	1	0	0.00005未満	0.00005未満	0.00005未満	---
セレン及びその化合物	mg/L	0.01mg/L以下	---	---	---	---	0.0005未満	---	---	---	---	---	---	---	1	0	0.0005未満	0.0005未満	0.0005未満	---
鉛及びその化合物	mg/L	0.01mg/L以下	---	---	---	---	0.0011	---	---	---	---	---	---	---	1	0	0.0011	0.0011	0.0011	2024/08/07
ヒ素及びその化合物	mg/L	0.01mg/L以下	---	---	---	---	0.0005未満	---	---	---	---	---	---	---	1	0	0.0005未満	0.0005未満	0.0005未満	---
六価クロム化合物	mg/L	0.02mg/L以下	---	---	---	---	0.002未満	---	---	---	---	---	---	---	1	0	0.002未満	0.002未満	0.002未満	---
亜硝酸態窒素	mg/L	0.04mg/L以下	---	---	---	---	0.004未満	---	---	---	---	---	---	---	1	0	0.004未満	0.004未満	0.004未満	---
シアン化物イオン及び塩化シアン	mg/L	0.01mg/L以下	---	0.001未満	---	---	0.001未満	---	---	0.001未満	---	---	0.001未満	---	4	0	0.001未満	0.001未満	0.001未満	---
硝酸態窒素及び亜硝酸態窒素	mg/L	10mg/L以下	---	---	---	---	1.0	---	---	---	---	---	---	---	1	0	1.0	1.0	1.0	2024/08/07
フッ素及びその化合物	mg/L	0.8mg/L以下	---	---	---	---	0.05未満	---	---	---	---	---	---	---	1	0	0.05未満	0.05未満	0.05未満	---
ホウ素及びその化合物	mg/L	1.0mg/L以下	---	---	---	---	0.04	---	---	---	---	---	---	---	1	0	0.04	0.04	0.04	2024/08/07
四塩化炭素	mg/L	0.002mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---	---	---	1	0	0.0002未満	0.0002未満	0.0002未満	---
1,4-ジオキサン	mg/L	0.05mg/L以下	---	---	---	---	0.003未満	---	---	---	---	---	---	---	1	0	0.003未満	0.003未満	0.003未満	---
シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン	mg/L	0.04mg/L以下	---	---	---	---	0.0004未満	---	---	---	---	---	---	---	1	0	0.0004未満	0.0004未満	0.0004未満	---
ジクロロメタン	mg/L	0.02mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---	---	---	1	0	0.0002未満	0.0002未満	0.0002未満	---
テトラクロロエチレン	mg/L	0.01mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---	---	---	1	0	0.0002未満	0.0002未満	0.0002未満	---
トリクロロエチレン	mg/L	0.01mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---	---	---	1	0	0.0002未満	0.0002未満	0.0002未満	---
ベンゼン	mg/L	0.01mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---	---	---	1	0	0.0002未満	0.0002未満	0.0002未満	---
塩素酸	mg/L	0.06mg/L以下	---	0.06未満	---	---	0.06未満	---	---	0.06未満	---	---	0.06未満	---	4	0	0.06未満	0.06未満	0.06未満	---
クロロ酢酸	mg/L	0.02mg/L以下	---	0.002未満	---	---	0.002未満	---	---	0.002未満	---	---	0.002未満	---	4	0	0.002未満	0.002未満	0.002未満	---
クロロホルム	mg/L	0.06mg/L以下	---	0.0002未満	---	---	0.0002未満	---	---	0.0002未満	---	---	0.0002未満	---	4	0	0.0002未満	0.0002未満	0.0002未満	---
ジクロロ酢酸	mg/L	0.03mg/L以下	---	0.002未満	---	---	0.002未満	---	---	0.002未満	---	---	0.002未満	---	4	0	0.002未満	0.002未満	0.002未満	---
ジブロモクロメタン	mg/L	0.1mg/L以下	---	0.0002未満	---	---	0.0002未満	---	---	0.0002未満	---	---	0.0002未満	---	4	0	0.0002未満	0.0002未満	0.0002未満	---
臭素酸	mg/L	0.01mg/L以下	---	0.001未満	---	---	0.001未満	---	---	0.001未満	---	---	0.001未満	---	4	0	0.001未満	0.001未満	0.001未満	---
総トリハロメタン	mg/L	0.1mg/L以下	---	0.01未満	---	---	0.01未満	---	---	0.01未満	---	---	0.01未満	---	4	0	0.01未満	0.01未満	0.01未満	---
トリクロロ酢酸	mg/L	0.03mg/L以下	---	0.002未満	---	---	0.002未満	---	---	0.002未満	---	---	0.002未満	---	4	0	0.002未満	0.002未満	0.002未満	---
ブロモジクロロメタン	mg/L	0.03mg/L以下	---	0.0002未満	---	---	0.0002未満	---	---	0.0002未満	---	---	0.0002未満	---	4	0	0.0002未満	0.0002未満	0.0002未満	---
ブロモホルム	mg/L	0.09mg/L以下	---	0.0002未満	---	---	0.0002未満	---	---	0.0002未満	---	---	0.0002未満	---	4	0	0.0002未満	0.0002未満	0.0002未満	---
ホルムアルデヒド	mg/L	0.08mg/L以下	---	0.004未満	---	---	0.004未満	---	---	0.004未満	---	---	0.004未満	---	4	0	0.004未満	0.004未満	0.004未満	---
亜鉛及びその化合物	mg/L	1.0mg/L以下	---	---	---	---	0.004	---	---	---	---	---	---	---	1	0	0.004	0.004	0.004	2024/08/07
アルミニウム及びその化合物	mg/L	0.2mg/L以下	---	---	---	---	0.005未満	---	---	---	---	---	---	---	1	0	0.005未満	0.005未満	0.005未満	---
鉄及びその化合物	mg/L	0.3mg/L以下	---	---	---	---	0.02未満	---	---	---	---	---	---	---	1	0	0.02未満	0.02未満	0.02未満	---
銅及びその化合物	mg/L	1.0mg/L以下	---	---	---	---	0.028	---	---	---	---	---	---	---	1	0	0.028	0.028	0.028	2024/08/07
ナトリウム及びその化合物	mg/L	200mg/L以下	---	---	---	---	9.7	---	---	---	---	---	---	---	1	0	9.7	9.7	9.7	2024/08/07
マンガン及びその化合物	mg/L	0.05mg/L以下	---	---	---	---	0.001未満	---	---	---	---	---	---	---	1	0	0.001未満	0.001未満	0.001未満	---
塩化物イオン	mg/L	200mg/L以下	6.1	6.2	6.1	6.0	6.0	6.1	6.1	5.9	6.0	6.0	6.1	5.8	12	0	6.0	6.2	5.8	2024/05/08
カルシウム、マグネシウム等(硬度)	mg/L	300mg/L以下	---	55	---	---	56	---	---	56	---	---	57	---	4	0	56	57	55	2025/02/05
蒸発残留物	mg/L	500mg/L以下	---	120	---	---	120	---	---	120	---	---	130	---	4	0	123	130	120	2025/02/05
陰イオン界面活性剤	mg/L	0.2mg/L以下	---	---	---	---	0.02未満	---	---	---	---	---	---	---	1	0	0.02未満	0.02未満	0.02未満	---
ジェオスミン	mg/L	0.00001mg/L以下	---	---	---	---	0.000001未満	---	---	---	---	---	---	---	1	0	0.000001未満	0.000001未満	0.000001未満	---
2-メチルイソボルネオール	mg/L	0.00001mg/L以下	---	---	---	---	0.000001未満	---	---	---	---	---	---	---	1	0	0.000001未満	0.000001未満	0.000001未満	---
非イオン界面活性剤	mg/L	0.02mg/L以下	---	---	---	---	0.002未満	---	---	---	---	---	---	---	1	0	0.002未満	0.002未満	0.002未満	---
フェノール類	mg/L	0.005mg/L以下	---	---	---	---	0.0005未満	---	---	---	---	---	---	---	1	0	0.0005未満	0.0005未満	0.0005未満	---
有機物(全有機炭素(TOC)の量)	mg/L	3mg/L以下	0.2未満	0.2未満	0.2未満	0.2未満	0.2未満	0.2未満	0.2未満	0.2未満	0.2未満	0.2未満	0.2未満	0.2未満	12	0	0.2未満	0.2未満	0.2未満	---
pH値	－	5.8以上8.6以下	6.8	6.8	6.9	6.8	6.8	6.8	6.8	6.8	6.8	6.8	6.8	6.8	12	0	6.8	6.9	6.8	2024/06/05
味	－	異常でないこと	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	12	0	---	---	---	---
臭気	－	異常でないこと	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	12	0	---	---	---	---
色度	度	5度以下	0.5未満	0.5未満	0.5未満	0.5未満	0.5未満	0.5未満	0.5未満	0.5未満	0.5未満	0.5未満	0.5未満	0.5未満	12	0	0.5未満	0.5未満	0.5未満	---
濁度	度	2度以下	0.1未満	0.1未満	0.1未満	0.1未満	0.1未満	0.1未満	0.1未満	0.1未満	0.1未満	0.1未満	0.1未満	0.1未満	12	0	0.1未満	0.1未満	0.1未満	---
上記項目についての水質基準適合判定			適合	適合	適合	適合	適合	適合	適合	適合	適合	適合	適合	適合						