

項目	単位	基準値	2025/04/02	2025/05/07	2025/06/04	2025/07/02	2025/08/06	2025/09/03	2025/10/01	2025/11/05	2025/12/03				測定回数	不適回数	平均値	最大値	最小値	最大値検出日
			25-SS-00028	25-SS-00423	25-SS-00926	25-SS-01457	25-SS-02034	25-SS-02611	25-SS-02974	25-SS-03413	25-SS-03839									
			SS																	
			上水道																	
水温	°C	-	14.0	18.0	20.1	24.0	28.0	26.0	25.0	18.2	17.0				9	0	21.1	28.0	14.0	2025/08/06
気温	°C	-	15.1	20.0	24.3	27.4	38.8	34.9	20.7	16.5	14.1				9	0	23.5	38.8	14.1	2025/08/06
残留塩素濃度	mg/L	-	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2				9	0	0.2	0.2	0.2	---
一般細菌	CFU/mL	100CFU/mL以下	0	0	0	0	0	0	0	0	0				9	0	0	0	0	---
大腸菌	-	検出されないこと	検出しない				9	0	---	---	---	---								
カドミウム及びその化合物	mg/L	0.003mg/L以下	---	---	---	---	0.00015未満	---	---	---	---				1	0	0.00015未満	0.00015未満	0.00015未満	---
水銀及びその化合物	mg/L	0.005mg/L以下	---	---	---	---	0.00005未満	---	---	---	---				1	0	0.00005未満	0.00005未満	0.00005未満	---
セレン及びその化合物	mg/L	0.01mg/L以下	---	---	---	---	0.0005	---	---	---	---				1	0	0.0005	0.0005	0.0005	2025/08/06
鉛及びその化合物	mg/L	0.01mg/L以下	---	---	---	---	0.0010	---	---	---	---				1	0	0.0010	0.0010	0.0010	2025/08/06
ヒ素及びその化合物	mg/L	0.01mg/L以下	---	---	---	---	0.0005未満	---	---	---	---				1	0	0.0005未満	0.0005未満	0.0005未満	---
六価クロム化合物	mg/L	0.02mg/L以下	---	---	---	---	0.002未満	---	---	---	---				1	0	0.002未満	0.002未満	0.002未満	---
亜硝酸態窒素	mg/L	0.04mg/L以下	---	---	---	---	0.004未満	---	---	---	---				1	0	0.004未満	0.004未満	0.004未満	---
シアノ化物イオン及び塩化シアノ	mg/L	0.01mg/L以下	---	0.001未満	---	---	0.001未満	---	0.001未満	---	---				3	0	0.001未満	0.001未満	0.001未満	---
硝酸態窒素及び亜硝酸態窒素	mg/L	10mg/L以下	---	---	---	---	1.0	---	---	---	---				1	0	1.00	1.00	1.00	2025/08/06
フッ素及びその化合物	mg/L	0.8mg/L以下	---	---	---	---	0.05未満	---	---	---	---				1	0	0.05未満	0.05未満	0.05未満	---
ホウ素及びその化合物	mg/L	1.0mg/L以下	---	---	---	---	0.04	---	---	---	---				1	0	0.04	0.04	0.04	2025/08/06
四塩化炭素	mg/L	0.002mg/L以下	---	---	---	---	0.0002未満	---	---	---	---				1	0	0.0002未満	0.0002未満	0.0002未満	---
1,4-ジオキサン	mg/L	0.05mg/L以下	---	---	---	---	0.003未満	---	---	---	---				1	0	0.003未満	0.003未満	0.003未満	---
ジメチルジオキサン及びジメチルジオキソヘキサン	mg/L	0.04mg/L以下	---	---	---	---	0.0004未満	---	---	---	---				1	0	0.0004未満	0.0004未満	0.0004未満	---
ジクロロメタン	mg/L	0.02mg/L以下	---	---	---	---	0.0002未満	---	---	---	---				1	0	0.0002未満	0.0002未満	0.0002未満	---
トライクロロエチレン	mg/L	0.01mg/L以下	---	---	---	---	0.0002未満	---	---	---	---				1	0	0.0002未満	0.0002未満	0.0002未満	---
トリクロロエチレン	mg/L	0.01mg/L以下	---	---	---	---	0.0002未満	---	---	---	---				1	0	0.0002未満	0.0002未満	0.0002未満	---
ベンゼン	mg/L	0.01mg/L以下	---	---	---	---	0.0002未満	---	---	---	---				1	0	0.0002未満	0.0002未満	0.0002未満	---
塩素酸	mg/L	0.6mg/L以下	---	0.06未満	---	---	0.06未満	---	0.06未満	---	0.06未満				3	0	0.06未満	0.06未満	0.06未満	---
クロロ酢酸	mg/L	0.02mg/L以下	---	0.002未満	---	---	0.002未満	---	0.002未満	---	0.002未満				3	0	0.002未満	0.002未満	0.002未満	---
クロロホルム	mg/L	0.06mg/L以下	---	0.0002未満	---	---	0.0002未満	---	0.0002未満	---	0.0002未満				3	0	0.0002未満	0.0002未満	0.0002未満	---
ジクロロ酢酸	mg/L	0.03mg/L以下	---	0.002未満	---	---	0.002未満	---	0.002未満	---	0.002未満				3	0	0.002未満	0.002未満	0.002未満	---
ジブロモクロロメタン	mg/L	0.1mg/L以下	---	0.0002未満	---	---	0.0002未満	---	0.0002未満	---	0.0002未満				3	0	0.0002未満	0.0002未満	0.0002未満	---
臭素酸	mg/L	0.01mg/L以下	---	0.001未満	---	---	0.001未満	---	0.001未満	---	0.001未満				3	0	0.001未満	0.001未満	0.001未満	---
総ドーハメタン	mg/L	0.1mg/L以下	---	0.01未満	---	---	0.01未満	---	0.01未満	---	0.01未満				3	0	0.01未満	0.01未満	0.01未満	---
トリクロロ酢酸	mg/L	0.03mg/L以下	---	0.002未満	---	---	0.002未満	---	0.002未満	---	0.002未満				3	0	0.002未満	0.002未満	0.002未満	---
プロモジクロロメタン	mg/L	0.03mg/L以下	---	0.0002未満	---	---	0.0002未満	---	0.0002未満	---	0.0002未満				3	0	0.0002未満	0.0002未満	0.0002未満	---
プロモホルム	mg/L	0.09mg/L以下	---	0.0002未満	---	---	0.0002未満	---	0.0002未満	---	0.0002未満				3	0	0.0002未満	0.0002未満	0.0002未満	---
ホルムアルデヒド	mg/L	0.08mg/L以下	---	0.004未満	---	---	0.004未満	---	0.004未満	---	0.004未満				3	0	0.004未満	0.004未満	0.004未満	---
亜鉛及びその化合物	mg/L	1.0mg/L以下	---	---	---	---	0.04	---	---	---	---				1	0	0.004	0.004	0.004	2025/08/06
アルミニウム及びその化合物	mg/L	0.2mg/L以下	---	---	---	---	0.005未満	---	---	---	---				1	0	0.005未満	0.005未満	0.005未満	---
鉄及びその化合物	mg/L	0.3mg/L以下	---	---	---	---	0.02未満	---	---	---	---				1	0	0.02未満	0.02未満	0.02未満	---
銅及びその化合物	mg/L	1.0mg/L以下	---	---	---	---	0.027	---	---	---	---				1	0	0.027	0.027	0.027	2025/08/06
ナトリウム及びその化合物	mg/L	200mg/L以下	---	---	---	---	9.8	---	---	---	---				1	0	9.8	9.8	9.8	2025/08/06
マンガン及びその化合物	mg/L	0.05mg/L以下	---	---	---	---	0.001未満	---	---	---	---				1	0	0.001未満	0.001未満	0.001未満	---
塩化物イオン	mg/L	200mg/L以下	6.1	5.7	5.7	5.6	5.5	5.4	5.4	5.4	5.6				9	0	5.6	6.1	5.4	2025/04/02
カルシウム、マグネシウム等(硬度)	mg/L	300mg/L以下	---	58	---	---	57	---	56	---	56				3	0	57	58	56	2025/05/07
蒸発残留物	mg/L	500mg/L以下	---	130	---	---	110	---	110	---	110				3	0	117	130	110	2025/05/07
陰イオン界面活性剤	mg/L	0.2mg/L以下	---	---	---	---	0.02未満	---	---	---	---				1	0	0.02未満	0.02未満	0.02未満	---
ジェオスミン	mg/L	0.00001mg/L以下	---	---	---	---	0.000001未満	---	---	---	---				1	0	0.000001未満	0.000001未満	0.000001未満	---
2-メチルイソポルネオール	mg/L	0.00001mg/L以下	---	---	---	---	0.000001未満	---	---	---	---				1	0	0.000001未満	0.000001未満	0.000001未満	---
非イオン界面活性剤	mg/L	0.02mg/L以下	---	---	---	---	0.002未満	---	---	---	---				1	0	0.002未満	0.002未満	0.002未満	---
フェノール類	mg/L	0.005mg/L以下	---	---	---	---	0.0005未満	---	---	---	---				1	0	0.0005未満	0.0005未満	0.0005未満	---
有機物(全有機炭素(TOC)の量)	mg/L	3mg/L以下	0.2未満				9	0	0.2未満	0.2未満	0.2未満	---								
pH値	-	5.8以上6.6以下	6.8	6.8	6.8	6.9	6.8	6.9	6.7	6.8	6.8				9	0	6.8	6.9	6.7	2025/07/02
味	-	異常でないこと	異常なし				9	0	---	---	---	---								
臭気	-	異常でないこと	異常なし				9	0	---	---	---	---								
色度	度	5度以下	0.5未満				9	0	0.5未満	0.5未満	0.5未満	---								
濁度	度	2度以下	0.1未満				9	0	0.1未満	0.1未満	0.1未満	---								

上記項目についての水質基準適合判定

適合 合格 合格