

## 施設名：焼津市上水（八楠公園） 採水場所：焼津市八楠4-4-41 八楠公園

項目	単位	基準値	2025/04/02	2025/05/07	2025/06/04	2025/07/02	2025/08/06	2025/09/03	2025/10/01	2025/11/05	2025/12/03					測定回数	不適回数	平均値	最大値	最小値	最大値検出日
			25-SS-00031	25-SS-00426	25-SS-00929	25-SS-01460	25-SS-02037	25-SS-02614	25-SS-02977	25-SS-03416	25-SS-03842										
			SS																		
			上水道																		
水温	°C	-	16.0	19.5	20.1	24.0	27.2	26.8	26.0	19.8	17.0					9	0	21.8	27.2	16.0	2025/08/06
气温	°C	-	17.7	23.6	27.3	28.2	39.2	36.4	23.2	18.3	14.6					9	0	25.4	39.2	14.6	2025/08/06
残留塩素濃度	mg/L	-	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2					9	0	0.2	0.2	0.2	---
一般細菌	CFU/mL	100CFU/mL以下	0	0	0	0	0	0	0	0	0					9	0	0	0	0	---
大腸菌	-	検出されないこと	検出しない					9	0	---	---	---	---								
カドミウム及びその化合物	mg/L	0.003mg/L以下	---	---	---	---	0.00015未満	---	---	---	---					1	0	0.00015未満	0.00015未満	0.00015未満	---
水銀及びその化合物	mg/L	0.005mg/L以下	---	---	---	---	0.00005未満	---	---	---	---					1	0	0.00005未満	0.00005未満	0.00005未満	---
セレン及びその化合物	mg/L	0.01mg/L以下	---	---	---	---	0.0005未満	---	---	---	---					1	0	0.0005未満	0.0005未満	0.0005未満	---
鉛及びその化合物	mg/L	0.01mg/L以下	---	---	---	---	0.0005未満	---	---	---	---					1	0	0.0005未満	0.0005未満	0.0005未満	---
ヒ素及びその化合物	mg/L	0.01mg/L以下	---	---	---	---	0.0005未満	---	---	---	---					1	0	0.0005未満	0.0005未満	0.0005未満	---
六価クロム化合物	mg/L	0.02mg/L以下	---	---	---	---	0.002未満	---	---	---	---					1	0	0.002未満	0.002未満	0.002未満	---
亜硝酸態窒素	mg/L	0.04mg/L以下	---	---	---	---	0.004未満	---	---	---	---					1	0	0.004未満	0.004未満	0.004未満	---
シアノ化物イオン及び塩化シアノ	mg/L	0.01mg/L以下	---	0.001未満	---	---	0.001未満	---	0.001未満	---	---					3	0	0.001未満	0.001未満	0.001未満	---
硝酸態窒素及び亜硝酸態窒素	mg/L	10mg/L以下	---	---	---	---	0.9	---	---	---	---					1	0	0.90	0.90	0.90	2025/08/06
フッ素及びその化合物	mg/L	0.8mg/L以下	---	---	---	---	0.05未満	---	---	---	---					1	0	0.05未満	0.05未満	0.05未満	---
ホウ素及びその化合物	mg/L	1.0mg/L以下	---	---	---	---	0.03	---	---	---	---					1	0	0.03	0.03	0.03	2025/08/06
四塩化炭素	mg/L	0.002mg/L以下	---	---	---	---	0.0002未満	---	---	---	---					1	0	0.0002未満	0.0002未満	0.0002未満	---
1,4-ジオキサン	mg/L	0.05mg/L以下	---	---	---	---	0.003未満	---	---	---	---					1	0	0.003未満	0.003未満	0.003未満	---
ジメチルエチレングリコール及びジメチルエチレングリコール	mg/L	0.04mg/L以下	---	---	---	---	0.0004未満	---	---	---	---					1	0	0.0004未満	0.0004未満	0.0004未満	---
ジクロロメタン	mg/L	0.02mg/L以下	---	---	---	---	0.0002未満	---	---	---	---					1	0	0.0002未満	0.0002未満	0.0002未満	---
トライクロロエチレン	mg/L	0.01mg/L以下	---	---	---	---	0.0002未満	---	---	---	---					1	0	0.0002未満	0.0002未満	0.0002未満	---
トリクロロエチレン	mg/L	0.01mg/L以下	---	---	---	---	0.0002未満	---	---	---	---					1	0	0.0002未満	0.0002未満	0.0002未満	---
ベンゼン	mg/L	0.01mg/L以下	---	---	---	---	0.0002未満	---	---	---	---					1	0	0.0002未満	0.0002未満	0.0002未満	---
塩素酸	mg/L	0.6mg/L以下	---	0.06未満	---	---	0.06未満	---	0.06未満	---	0.06未満	---	---	---	3	0	0.06未満	0.06未満	0.06未満	---	
クロロ酢酸	mg/L	0.02mg/L以下	---	0.002未満	---	---	0.002未満	---	0.002未満	---	0.002未満	---	---	---	3	0	0.002未満	0.002未満	0.002未満	---	
クロロホルム	mg/L	0.06mg/L以下	---	0.009	---	---	0.0014	---	0.0008	---	0.0008	---	---	---	3	0	0.0010	0.0014	0.0008	2025/08/06	
ジクロロ酢酸	mg/L	0.03mg/L以下	---	0.002未満	---	---	0.002未満	---	0.002未満	---	0.002未満	---	---	---	3	0	0.002未満	0.002未満	0.002未満	---	
ジプロモクロロメタン	mg/L	0.1mg/L以下	---	0.0003	---	---	0.0003	---	0.0002	---	0.0002	---	---	---	3	0	0.0003	0.0003	0.0002	2025/05/07	
臭素酸	mg/L	0.01mg/L以下	---	0.001未満	---	---	0.001未満	---	0.001未満	---	0.001未満	---	---	---	3	0	0.001未満	0.001未満	0.001未満	---	
総トリハロメタン	mg/L	0.1mg/L以下	---	0.01未満	---	---	0.01未満	---	0.01未満	---	0.01未満	---	---	---	3	0	0.01未満	0.01未満	0.01未満	---	
トリクロロ酢酸	mg/L	0.03mg/L以下	---	0.002未満	---	---	0.002未満	---	0.002未満	---	0.002未満	---	---	---	3	0	0.002未満	0.002未満	0.002未満	---	
ブロモジクロロメタン	mg/L	0.03mg/L以下	---	0.0003	---	---	0.0003	---	0.0002	---	0.0002	---	---	---	3	0	0.0003	0.0003	0.0002	2025/05/07	
ブロモホルム	mg/L	0.09mg/L以下	---	0.0002未満	---	---	0.0002未満	---	0.0002未満	---	0.0002未満	---	---	---	3	0	0.0002未満	0.0002未満	0.0002未満	---	
ホルムアルデヒド	mg/L	0.08mg/L以下	---	0.004未満	---	---	0.004未満	---	0.004未満	---	0.004未満	---	---	---	3	0	0.004未満	0.004未満	0.004未満	---	
亜鉛及びその化合物	mg/L	1.0mg/L以下	---	---	---	---	0.002	---	---	---	---	---	---	---	1	0	0.002	0.002	0.002	2025/08/06	
アルミニウム及びその化合物	mg/L	0.2mg/L以下	---	---	---	---	0.016	---	---	---	---	---	---	---	1	0	0.016	0.016	0.016	2025/08/06	
鉄及びその化合物	mg/L	0.3mg/L以下	---	---	---	---	0.02未満	---	---	---	---	---	---	---	1	0	0.02未満	0.02未満	0.02未満	---	
銅及びその化合物	mg/L	1.0mg/L以下	---	---	---	---	0.009	---	---	---	---	---	---	---	1	0	0.009	0.009	0.009	2025/08/06	
ナトリウム及びその化合物	mg/L	200mg/L以下	---	---	---	---	8.2	---	---	---	---	---	---	---	1	0	8.2	8.2	8.2	2025/08/06	
マンガン及びその化合物	mg/L	0.05mg/L以下	---	---	---	---	0.001	---	---	---	---	---	---	---	1	0	0.001	0.001	0.001	2025/08/06	
塩化物イオン	mg/L	200mg/L以下	5.3	4.7	4.9	4.8	4.7	4.3	4.5	4.8	4.9	---	---	---	9	0	4.8	5.3	4.3	2025/04/02	
カルシウム、マグネシウム等(硬度)	mg/L	300mg/L以下	---	68	---	---	63	---	64	---	120	---	---	---	3	0	65	68	63	2025/05/07	
蒸発残留物	mg/L	500mg/L以下	---	130	---	---	120	---	120	---	120	---	---	---	3	0	123	130	120	2025/05/07	
陰イオン界面活性剤	mg/L	0.2mg/L以下	---	---	---	---	0.02未満	---	---	---	---	---	---	---	1	0	0.02未満	0.02未満	0.02未満	---	
ジェオスミン	mg/L	0.00001mg/L以下	---	---	---	---	0.000001未満	---	---	---	---	---	---	---	1	0	0.000001未満	0.000001未満	0.000001未満	---	
2-メチルイソポルネオール	mg/L	0.00001mg/L以下	---	---	---	---	0.000001未満	---	---	---	---	---	---	---	1	0	0.000001未満	0.000001未満	0.000001未満	---	
非イオン界面活性剤	mg/L	0.02mg/L以下	---	---	---	---	0.002未満	---	---	---	---	---	---	---	1	0	0.002未満	0.002未満	0.002未満	---	
フェノール類	mg/L	0.005mg/L以下	---	---	---	---	0.0005未満	---	---	---	---	---	---	---	1	0	0.0005未満	0.0005未満	0.0005未満	---	
有機物(全有機炭素(TOC)の量)	mg/L	3mg/L以下	0.2未満	---	---	---	9	0	0.2未満	0.2未満	0.2未満	---									
pH値	-	5.8以上6.8以下	7.5	7.6	7.5	7.0	7.6	7.6	7.6	7.6	7.6	---	---	---	9	0	7.5	7.7	7.0	2025/09/03	
味	-	異常でないこと	異常なし	---	---	---	9	0	---	---	---	---									
臭気	-	異常でないこと	異常なし	---	---	---	9	0	---	---	---	---									
色度	度	5度以下	0.5未満	---	---	---	9	0	0.5未満	0.5未満	0.5未満	---									
濁度	度	2度以下	0.1未満	---	---	---	9	0	0.1未満	0.1未満	0.1未満	---									

上記項目についての水質基準適合判定

適合 合格 合格