

施設名：焼津市上水（下小杉児童公園） 採水場所：焼津市下小杉4 8 0－1 下小杉児童公園

項目	単位	基準値	2024/04/03	2024/05/08	2024/06/05	2024/07/03	2024/08/07	2024/09/04	2024/10/02	2024/11/06	2024/12/04	2025/01/08	2025/02/05	2025/03/05	測定回数	不適回数	平均値	最大値	最小値	最大値検出日
			24-SS-00039	24-SS-00427	24-SS-00908	24-SS-01444	24-SS-02062	24-SS-02566	24-SS-03028	24-SS-03435	24-SS-03883	24-SS-04272	24-SS-04705	24-SS-05072						
			SS 上水道	SS 上水道	SS 上水道	SS 上水道	SS 上水道	SS 上水道	SS 上水道	SS 上水道	SS 上水道	SS 上水道	SS 上水道	SS 上水道						
水温	℃	－	15.5	21.0	22.0	25.5	30.5	27.5	28.0	21.5	16.0	11.0	12.0	11.5	12	0	20.2	30.5	11.0	2024/08/07
気温	℃	－	13.7	24.6	26.1	30.0	34.6	30.3	29.1	22.3	17.8	5.7	8.3	10.9	12	0	21.1	34.6	5.7	2024/08/07
残留塩素濃度	mg/L	－	0.3	0.3	0.3	0.3	0.3	0.3	0.2	0.2	0.2	0.2	0.2	0.2	12	0	0.3	0.3	0.2	2024/04/03
一般細菌	CFU/mL	100CFU/mL以下	0	0	0	0	0	0	0	1	0	0	0	0	12	0	0	1	0	2024/11/06
大腸菌	－	検出されないこと	検出しない	検出しない	検出しない	検出しない	検出しない	検出しない	検出しない	検出しない	検出しない	検出しない	検出しない	検出しない	12	0	---	---	---	---
カドミウム及びその化合物	mg/L	0.003mg/L以下	---	---	---	---	0.00015未満	---	---	---	---	---	---	---	1	0	0.00015未満	0.00015未満	0.00015未満	---
水銀及びその化合物	mg/L	0.0005mg/L以下	---	---	---	---	0.00005未満	---	---	---	---	---	---	---	1	0	0.00005未満	0.00005未満	0.00005未満	---
セレン及びその化合物	mg/L	0.01mg/L以下	---	---	---	---	0.0005未満	---	---	---	---	---	---	---	1	0	0.0005未満	0.0005未満	0.0005未満	---
鉛及びその化合物	mg/L	0.01mg/L以下	---	---	---	---	0.0005未満	---	---	---	---	---	---	---	1	0	0.0005未満	0.0005未満	0.0005未満	---
ヒ素及びその化合物	mg/L	0.01mg/L以下	---	---	---	---	0.0005未満	---	---	---	---	---	---	---	1	0	0.0005未満	0.0005未満	0.0005未満	---
六価クロム化合物	mg/L	0.02mg/L以下	---	---	---	---	0.002未満	---	---	---	---	---	---	---	1	0	0.002未満	0.002未満	0.002未満	---
亜硝酸態窒素	mg/L	0.04mg/L以下	---	---	---	---	0.004未満	---	---	---	---	---	---	---	1	0	0.004未満	0.004未満	0.004未満	---
シアン化物イオン及び塩化シアン	mg/L	0.01mg/L以下	---	0.001未満	---	---	0.001未満	---	---	0.001未満	---	---	0.001未満	---	4	0	0.001未満	0.001未満	0.001未満	---
硝酸態窒素及び亜硝酸態窒素	mg/L	10mg/L以下	---	---	---	---	0.3	---	---	---	---	---	---	---	1	0	0.3	0.3	0.3	2024/08/07
フッ素及びその化合物	mg/L	0.8mg/L以下	---	---	---	---	0.05未満	---	---	---	---	---	---	---	1	0	0.05未満	0.05未満	0.05未満	---
ホウ素及びその化合物	mg/L	1.0mg/L以下	---	---	---	---	0.03	---	---	---	---	---	---	---	1	0	0.03	0.03	0.03	2024/08/07
四塩化炭素	mg/L	0.002mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---	---	---	1	0	0.0002未満	0.0002未満	0.0002未満	---
1,4-ジオキサン	mg/L	0.05mg/L以下	---	---	---	---	0.003未満	---	---	---	---	---	---	---	1	0	0.003未満	0.003未満	0.003未満	---
シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン	mg/L	0.04mg/L以下	---	---	---	---	0.0004未満	---	---	---	---	---	---	---	1	0	0.0004未満	0.0004未満	0.0004未満	---
ジクロロメタン	mg/L	0.02mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---	---	---	1	0	0.0002未満	0.0002未満	0.0002未満	---
テトラクロロエチレン	mg/L	0.01mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---	---	---	1	0	0.0002未満	0.0002未満	0.0002未満	---
トリクロロエチレン	mg/L	0.01mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---	---	---	1	0	0.0002未満	0.0002未満	0.0002未満	---
ベンゼン	mg/L	0.01mg/L以下	---	---	---	---	0.0002未満	---	---	---	---	---	---	---	1	0	0.0002未満	0.0002未満	0.0002未満	---
塩素酸	mg/L	0.06mg/L以下	---	0.06未満	---	---	0.06未満	---	---	0.06未満	---	---	0.06未満	---	4	0	0.06未満	0.06未満	0.06未満	---
クロロ酢酸	mg/L	0.02mg/L以下	---	0.002未満	---	---	0.002未満	---	---	0.002未満	---	---	0.002未満	---	4	0	0.002未満	0.002未満	0.002未満	---
クロロホルム	mg/L	0.06mg/L以下	---	0.0008	---	---	0.0015	---	---	0.0010	---	---	0.0004	---	4	0	0.0009	0.0015	0.0004	2024/08/07
ジクロロ酢酸	mg/L	0.03mg/L以下	---	0.002未満	---	---	0.002未満	---	---	0.002未満	---	---	0.002未満	---	4	0	0.002未満	0.002未満	0.002未満	---
ジブromクロロメタン	mg/L	0.1mg/L以下	---	0.0003	---	---	0.0004	---	---	0.0003	---	---	0.0002未満	---	4	0	0.0003	0.0004	0.0002未満	2024/08/07
臭素酸	mg/L	0.01mg/L以下	---	0.001未満	---	---	0.001未満	---	---	0.001未満	---	---	0.001未満	---	4	0	0.001未満	0.001未満	0.001未満	---
総トリハロメタン	mg/L	0.1mg/L以下	---	0.01未満	---	---	0.01未満	---	---	0.01未満	---	---	0.01未満	---	4	0	0.01未満	0.01未満	0.01未満	---
トリクロロ酢酸	mg/L	0.03mg/L以下	---	0.002未満	---	---	0.002未満	---	---	0.002未満	---	---	0.002未満	---	4	0	0.002未満	0.002未満	0.002未満	---
ブromジクロロメタン	mg/L	0.03mg/L以下	---	0.0003	---	---	0.0005	---	---	0.0003	---	---	0.0002未満	---	4	0	0.0003	0.0005	0.0002未満	2024/08/07
ブromホルム	mg/L	0.09mg/L以下	---	0.0002未満	---	---	0.0002	---	---	0.0002未満	---	---	0.0002未満	---	4	0	0.0002	0.0002	0.0002未満	2024/08/07
ホルムアルデヒド	mg/L	0.08mg/L以下	---	0.004未満	---	---	0.004未満	---	---	0.004未満	---	---	0.004未満	---	4	0	0.004未満	0.004未満	0.004未満	---
亜鉛及びその化合物	mg/L	1.0mg/L以下	---	---	---	---	0.008	---	---	---	---	---	---	---	1	0	0.008	0.008	0.008	2024/08/07
アルミニウム及びその化合物	mg/L	0.2mg/L以下	---	---	---	---	0.011	---	---	---	---	---	---	---	1	0	0.011	0.011	0.011	2024/08/07
鉄及びその化合物	mg/L	0.3mg/L以下	---	---	---	---	0.02未満	---	---	---	---	---	---	---	1	0	0.02未満	0.02未満	0.02未満	---
銅及びその化合物	mg/L	1.0mg/L以下	---	---	---	---	0.016	---	---	---	---	---	---	---	1	0	0.016	0.016	0.016	2024/08/07
ナトリウム及びその化合物	mg/L	200mg/L以下	---	---	---	---	7.6	---	---	---	---	---	---	---	1	0	7.6	7.6	7.6	2024/08/07
マンガン及びその化合物	mg/L	0.05mg/L以下	---	---	---	---	0.001未満	---	---	---	---	---	---	---	1	0	0.001未満	0.001未満	0.001未満	---
塩化物イオン	mg/L	200mg/L以下	4.0	3.7	3.8	3.6	3.5	3.7	3.6	3.7	3.5	3.6	3.3	3.2	12	0	3.6	4.0	3.2	2024/04/03
カルシウム、マグネシウム等(硬度)	mg/L	300mg/L以下	---	65	---	---	59	---	---	61	---	---	61	---	4	0	62	65	59	2024/05/08
蒸発残留物	mg/L	500mg/L以下	---	120	---	---	110	---	---	120	---	---	120	---	4	0	118	120	110	2024/05/08
陰イオン界面活性剤	mg/L	0.2mg/L以下	---	---	---	---	0.02未満	---	---	---	---	---	---	---	1	0	0.02未満	0.02未満	0.02未満	---
ジェオスミン	mg/L	0.00001mg/L以下	---	---	---	---	0.000001未満	---	---	---	---	---	---	---	1	0	0.000001未満	0.000001未満	0.000001未満	---
2-メチルイソボルネオール	mg/L	0.00001mg/L以下	---	---	---	---	0.000001未満	---	---	---	---	---	---	---	1	0	0.000001未満	0.000001未満	0.000001未満	---
非イオン界面活性剤	mg/L	0.02mg/L以下	---	---	---	---	0.002未満	---	---	---	---	---	---	---	1	0	0.002未満	0.002未満	0.002未満	---
フェノール類	mg/L	0.005mg/L以下	---	---	---	---	0.0005未満	---	---	---	---	---	---	---	1	0	0.0005未満	0.0005未満	0.0005未満	---
有機物(全有機炭素(TOC)の量)	mg/L	3mg/L以下	0.2未満	0.2未満	0.2未満	0.2未満	0.2未満	0.2未満	0.2未満	0.2未満	0.2未満	0.2未満	0.2未満	0.2未満	12	0	0.2未満	0.2未満	0.2未満	---
pH値	－	5.8以上8.6以下	7.2	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.2	7.2	7.2	12	0	7.3	7.3	7.2	2024/05/08
味	－	異常でないこと	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	12	0	---	---	---	---
臭気	－	異常でないこと	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	12	0	---	---	---	---
色度	度	5度以下	0.5未満	0.5未満	0.5未満	0.5未満	0.5未満	0.5未満	0.5未満	0.5未満	0.5未満	0.5未満	0.5未満	0.5未満	12	0	0.5未満	0.5未満	0.5未満	---
濁度	度	2度以下	0.1未満	0.1未満	0.1未満	0.1未満	0.1未満	0.1未満	0.1未満	0.1未満	0.1未満	0.1未満	0.1未満	0.1未満	12	0	0.1未満	0.1未満	0.1未満	---
上記項目についての水質基準適合判定			適合	適合	適合	適合	適合	適合	適合	適合	適合	適合	適合	適合						